
509 Fabrications, Inc.

Project # 24-265

Model: Mini Me Pellet

Type: Pellet-Fired Room Heater

Original Report Date: October 11, 2024

Revision Date: March 10, 2025

**ASTM E2779 Standard Test Method for
Determining Particulate Matter
Emissions from Pellet Heaters (EPA
ALT-146)**

Contact: Mr. Dusty Henderson
6512 W. Seltice Way
Post Falls, ID 83854
dusty@509fab.com
(509) 993-3767

Prepared by: Aaron Kravitz, Laboratory
Manager



11785 SE Highway 212 – Suite 305

Clackamas, OR 97015-9050

(503) 650-0088

WWW.PFSTECO.COM

Revision History

October 11, 2024– Original Issue

March 10, 2025 – Added revised manual including a specific section on Warranty (p. 114 of report). Replacement parts (such as door gaskets) were included in the original manual (see the Glass Gasket Replacement section on p. 138 of the report). New Certificate of Conformity (COC) also provided.

Contents


| | |
|---|----|
| Affidavit | 4 |
| Introduction | 5 |
| Notes | 5 |
| Pellet Heater Identification and Testing | 6 |
| Test Procedures and Equipment | 7 |
| Results | 8 |
| Summary Table | 8 |
| Test Run Narrative | 9 |
| Run 1 | 9 |
| Test Conditions Summary | 9 |
| Appliance Operation and Test Settings | 10 |
| Settings & Run Notes | 10 |
| Appliance Description | 11 |
| Appliance Dimensions | 11 |
| Test Fuel Properties | 14 |
| Pellet Fuel Analysis | 15 |
| Sampling Locations and Descriptions | 16 |
| Sampling Methods | 17 |
| Analytical Methods Description | 17 |
| Calibration, Quality Control and Assurances | 17 |
| Appliance Sealing and Storage | 17 |
| Sealing Label | 17 |
| Sealed Unit | 18 |
| List of Appendices | 18 |

Affidavit

PFS-TECO was contracted by 509 Fabrications, Inc. to provide testing services for the Mini Me Pellet Pellet-Fired Room Heater per ASTM E2779, *Determining PM Emissions from Pellet Heaters*. All testing and associated procedures were conducted at PFS-TECO's Portland Laboratory on 8/14/2024. PFS-TECO's Portland Laboratory is located at 11785 SE Highway 212 – Suite 305, Clackamas, Oregon 97015. Testing procedures followed EPA ALT-146 / ASTM E2779. Particulate sampling was performed per ASTM E2515, *Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel*.

PFS-TECO is accredited by the U.S. Environmental Protection Agency for the certification and auditing of wood heaters pursuant to subpart AAA of 40 CFR Part 60, New Source Performance Standards for Residential Wood Heaters and subpart QQQQ of 40 CFR Part 60, Standards of Performance for New Hydronic Heaters and Forced Air Furnaces, Methods 28R, 28WHH, 28 WHH-PTS, and all methods listed in Sections 60.534 and 60.5476. PFS-TECO holds EPA Accreditation Certificate Numbers 4 and 4M (mobile). PFS-TECO is accredited by IAS to ISO 17020:2012 "Criteria for Bodies Performing Inspections", and ISO 17025:2005 "Requirements for Testing Laboratories." PFS-TECO is also accredited by Standards Council of Canada to ISO 17065:2012 "Requirements for Bodies Operating Product Certification Systems."

The following people were associated with the testing, analysis and report writing associated with this project.



Aaron Kravitz, Laboratory Manager

Introduction

509 Fabrications of Post Falls, ID, contracted with PFS-TECO to perform EPA certification testing on the Mini Me Pellet Pellet-Fired Room Heater. All testing was performed at PFS-TECO's Portland Laboratory. Testing was performed by Mr. Aaron Kravitz.

Notes

- Prior to start of testing, 50 hours of conditioning was performed by the manufacturer at a medium heat setting, per ASTM E2779
- Prior to start of testing, the dilution tunnel was cleaned with a steel brush.
- A separate, independent sample train was utilized to determine 1st hour emissions.
- Two test runs were performed in accordance with EPA ALT-146 burn rate settings:
 - 1 Hour at Maximum Burn Setting
 - 2 Hours at Medium Burn Setting (less than the mid-point of the high and low rates)
 - 3 Hours at Minimum Burn Setting
- Of the two test runs, only Run 2 was valid, as the medium burn rate of Run 1 was outside of the permitted burn rate range.

Pellet Heater Identification and Testing

- Appliance Tested: **Mini Me Pellet**
- Serial Number: **N/A – Prototype Unit; PFS Tracking #212**
- Manufacturer: **509 Fabrication, Inc.**
- Catalyst: **No**
- Heat exchange blower: **None**
- Type: **Pellet Stove**
- Style: **Free Standing**
- Date Received: **Wednesday, July 24, 2024**
- Testing Period – Start: **Tuesday, August 13, 2024** Finish: **Wednesday, August 14, 2024**
- Test Location: **PFS-TECO Portland Laboratory, 11785 SE HWY 212 - Suite 305, Clackamas, OR 97015**
- Elevation: **≈131 Feet above sea level**
- Test Technician(s): **Aaron Kravitz**
- Observers: **N/A**

Test Procedures and Equipment

All Sampling and analytical procedures were performed by Aaron Kravitz. All procedures used are directly from ASTM E2779 and ASTM E2515. See the list below for equipment used. See Appendix C submitted with this report for calibration data.

Equipment List:

| Equipment ID# | Equipment Description |
|---------------|--|
| 189 | Mettler Toledo 3'x3' floor scale w/digital weight indicator |
| 053 | APEX XC-60 Digital Emissions Sampling Box A |
| 054 | APEX XC-60 Digital Emissions Sampling Box B |
| 203 | APEX XC-50-DIR Digital Emissions Sampling Box C |
| 055 | APEX Ambient sampling box |
| 215 | NI Temperature DAQ |
| 057 | California Analytical ZRE CO ₂ /CO/O ₂ IR ANALYZER |
| 109A/B | Troemner 100mg/200mg Audit Weights |
| 107 | Sartorius Analytical Balance |
| 097 | 10 lb audit weight |
| 095 | Anemometer |
| 217 | Microtector |
| CC505834 | Gas Analyzer Calibration Span Gas |
| CC341544 | Gas Analyzer Calibration Mid Gas |

Barometric pressure data was taken from local National Weather Service station KPDX. As PFS and KPDX are at the same altitude, the correction for altitude per ASTM E2515 6.1.2 is 1:1.

Results

The integrated test run emission rate for test Run 2 was measured to be **0.36 g/hr** with a Higher Heating Value efficiency of **76%** and a CO emission rate of **0.22 g/min**. The calculated first hour particulate emission rate was **1.2 g/hr**. The 509 Fabrications Model Mini Me Pellet Pellet-Fired Room Heater meets the 2020 PM emission standard of ≤ 2.0 g/hr per CFR 40 part 60, §60.532 (b).

Detailed individual run data can be found in Appendix A submitted with this report.

Summary Table

| Run Number | Date | Segments | | Run Time (min) | Heat Output (BTU/hr) | 1st Hr Emissions (g/hr) | Integrated Total (g/hr) | CO Emissions (g/min) | Overall CO Emissions (g/min) | Heating Efficiency (%HHV) | Overall Heating Efficiency (%HHV) |
|------------|-----------|----------|------|----------------|----------------------|-------------------------|-------------------------|----------------------|------------------------------|---------------------------|-----------------------------------|
| | | Setting | BR | | | | | | | | |
| 1 | 8/13/2024 | OA | 1.27 | 360 | 18096 | 0.78 | 0.38 | 0.25 | 0.25 | 75% | 75% |
| | | H | 1.98 | 60 | 27803 | | | 0.16 | | 74% | |
| | | M | 1.55 | 120 | 22096 | | | 0.25 | | 75% | |
| | | L | 0.85 | 180 | 12088 | | | 0.27 | | 75% | |

*Run #1 is invalid due to its medium burn rate and is included here for informational purposes only.

| Run Number | Date | Segments | | Run Time (min) | Heat Output (BTU/hr) | 1st Hr Emissions (g/hr) | Integrated Total (g/hr) | CO Emissions (g/min) | Overall CO Emissions (g/min) | Heating Efficiency (%HHV) | Overall Heating Efficiency (%HHV) |
|------------|-----------|----------|------|----------------|----------------------|-------------------------|-------------------------|----------------------|------------------------------|---------------------------|-----------------------------------|
| | | Setting | BR | | | | | | | | |
| 2 | 8/14/2024 | OA | 1.22 | 360 | 17609 | 1.2 | 0.36 | 0.22 | 0.22 | 76% | 76% |
| | | H | 2.07 | 60 | 29388 | | | 0.17 | | 74% | |
| | | M | 1.34 | 120 | 19167 | | | 0.23 | | 75% | |
| | | L | 0.86 | 180 | 12567 | | | 0.23 | | 77% | |

Test Run Narrative

Run 1

Run 1 was performed on 8/13/2024 as an attempted integrated test run per EPA ALT-146/ ASTM E2779. The overall test duration was 360 minutes. The particulate emissions rate for the integrated test run was 0.38 g/hr. The run had an overall HHV efficiency of 75%. A separate filter train C was run for the first hour of the run only. The burn rate of the medium segment was 1.55 kg/hr, which is outside the acceptable range, per EPA ALT-146, of 0.85 kg/hr – 1.41 kg/hr. Therefore, this run is deemed invalid and its results are not used for evaluating emissions compliance.

Run 2

Run 2 was performed on 8/14/2024 as an attempted integrated test run per EPA ALT-146/ ASTM E2779. The overall test duration was 360 minutes. The particulate emissions rate for the integrated test run was 0.36 g/hr. The run had an overall HHV efficiency of 76%. A separate filter train C was run for the first hour of the run only. All test results were appropriate and valid and the burn rate requirement for the integrated test run were achieved. There were no anomalies and all criteria were met.

Test Conditions Summary

Testing conditions for all runs fell within allowable specifications of ASTM E2779 and ASTM E2515. A summary of facility conditions, fuel burned, and run times is listed below.

| Runs | Ambient (°F) | | Relative Humidity (%) | | Average Barometric Pressure (In. Hg.) | Preburn Fuel Weight (lbs) | Test Fuel Weight (lbs) | Test Fuel Moisture (%DB) | Test Run Time (Min) |
|------|--------------|------|-----------------------|------|---------------------------------------|---------------------------|------------------------|--------------------------|---------------------|
| | Pre | Post | Pre | Post | | | | | |
| 1 | 71 | 73 | 41.8 | 33.9 | 30.00 | 4.1 | 17.2 | 2.2% | 360 |
| 2 | 71 | 76 | 39.7 | 37.2 | 29.95 | 3.9 | 16.5 | 2.2% | 360 |

Appliance Operation and Test Settings

The appliance was operated according to procedures as described in the Operations Manual, found in Appendix B submitted with this report. Detailed run information can be found in Appendix A submitted with this report.

Settings & Run Notes

| | Pre-Burn | Test Run | | |
|--------------|------------------------|--|--|--|
| Run 1 | Damper full open (max) | Maximum Segment Damper full open (max) | Medium Segment Damper open 3/32" | Minimum Segment Damper full closed (min) |
| Run 2 | Damper full open (max) | Maximum Segment Damper full open (max) | Medium Segment Damper open 1/16" | Minimum Segment Damper full closed (min) |

Appliance Description

Model(s): Mini Me Pellet

Appliance Type: Gravity-Fed Pellet-Fired Room Heater

Additional Models: None

Air Introduction System: Air is introduced to the pellet burn pot by several stainless steel tubes angled as to create a swirl pattern.

Combustion Control: A control slide located under the firebox regulates combustion air intake.

Fueling System: The unit is entirely gravity-fed; fuel is loaded into a hopper above the firebox and fuel feed can be turned on or off via actuation of a sliding gate.

Baffles: N/A

Flue Outlet: Venting is through a 4" diameter steel pipe, which exits through the top of the unit.

Appliance Dimensions

Mini Me Pellet Dimensions

| Height | Width | Depth | Weight |
|--------|-------|-------|--------|
| 35" | 22.5" | 22.5" | 140 lb |

Appliance design drawings can be found in Appendix D submitted with the CBI copy of this report.

Appliance Front



Appliance Left



Appliance Right



Appliance Rear



Test Fuel Properties

Test fuel used was Lignetics Pellet Fuel, a PFI Certified Premium Pellet Brand. A sample of pellets was sent to Twin Ports Testing for analysis, see report below.



Pellet Fuel Analysis



Twin Ports Testing, Inc.
 1301 North 3rd Street
 Superior, WI 54880
 p: 715-392-7114
 p: 800-373-2562
 f: 715-392-7163
 www.twinportstesting.com

Report No: USR:W224-0189-01
Issue No: 1

Analytical Test Report

Client: PFS-TECO
 11785 SE Hwy 212, Ste 305
 Clackamas, OR 97015
Attention: Sebastian Button
PO No:

Signed: *Katy Jahr*
 Katy Jahr
 Chemistry Lab Supervisor
Date of Issue: 5/13/2024
THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

Sample Details
Sample Log No: W224-0189-01 **Sample Date:**
Sample Designation: Lignetics Pellets (Mill # 16036) **Sample Time:**
Sample Recognized As: Wood Pellets **Arrival Date:** 4/26/2024

Test Results

| | METHOD | UNITS | MOISTURE FREE | AS RECEIVED |
|-----------------------------------|------------|----------|---------------|-------------|
| Moisture Total | ASTM E871 | wt. % | | 2.10 |
| Ash | ASTM D1102 | wt. % | 0.17 | 0.17 |
| Volatile Matter | ASTM D3175 | wt. % | 80.51 | 78.82 |
| Fixed Carbon by Difference | ASTM D3172 | wt. % | 19.31 | 18.91 |
| Sulfur | ASTM D4239 | wt. % | 0.070 | 0.069 |
| SO ₂ | Calculated | lb/mmbtu | | 0.163 |
| Net Cal. Value at Const. Pressure | ISO 1928 | GJ/tonne | 18.71 | 18.27 |
| Gross Cal. Value at Const. Vol. | ASTM E711 | Btu/lb | 8627 | 8445 |
| Carbon | ASTM D5373 | wt. % | 49.48 | 48.44 |
| Hydrogen* | ASTM D5373 | wt. % | 6.22 | 6.09 |
| Nitrogen | ASTM D5373 | wt. % | < 0.20 | < 0.20 |
| Oxygen* | ASTM D3176 | wt. % | > 43.86 | > 42.94 |

*Note: As received values do not include hydrogen and oxygen in the total moisture.

| | | | | |
|--------------------------------|--------------|---------------------|--|----|
| Chlorine | ASTM D6721 | mg/kg | | |
| Fluorine | ASTM D3761 | mg/kg | | |
| Mercury | ASTM D6722 | mg/kg | | |
| Bulk Density | ASTM E873 | lbs/ft ³ | | |
| Fines (Less than 1/8") | TPT CH-P-06 | wt. % | | |
| Durability Index | Kansas State | PDI | | |
| Sample Above 1.50" | TPT CH-P-06 | wt. % | | |
| Maximum Length (Single Pellet) | TPT CH-P-06 | inch | | |
| Diameter, Range | TPT CH-P-05 | inch | | to |
| Diameter, Average | TPT CH-P-05 | inch | | |
| Stated Bag Weight | TPT CH-P-01 | lbs | | |
| Actual Bag Weight | TPT CH-P-01 | lbs | | |

Comments:




Accreditation #60243

Results issued on this report only reflect the analysis of the sample submitted. Our reports and letters are for the exclusive and confidential use of our clients and may not be reproduced, except in their entirety, without the written approval of Twin Ports Testing. Twin Ports Testing Laboratory is accredited to the ISO/IEC 17025:2017 standard by PJLA.

Sampling Locations and Descriptions

Sample ports are located 14 feet downstream from any disturbances and 2 feet upstream from any disturbances. Flow rate traverse data was collected 12 feet downstream from any disturbances and 4 feet upstream from any disturbances. (See below).



Sampling Methods

ASTM E2515 was used in collecting particulate samples. The dilution tunnel is 6 inches in diameter. All sampling conditions per ASTM E2515 were followed. No alternate procedures were used.

Analytical Methods Description

All sample recovery and analysis procedures followed ASTM E2515 procedures. At the end of each test run, filters, O-Rings and probes were removed from their housings, dessicated for a minimum of 24 hours, and then weighed in pairs at 6 hour intervals to a constant weight per ASTM E2515-11 Section 10.

Calibration, Quality Control and Assurances

Calibration procedures and results were conducted per EPA Method 28R, ASTM E2515-11 and ASTM E2780-10. Test method quality control procedures (leak checks, volume meter checks, stratification checks, proportionality results) followed the procedures outlined.

Appliance Sealing and Storage

Upon completion of testing, the appliance was secured with metal strapping and the seal below was applied, the appliance was then returned to the manufacturer's location at: 6512 W. Seltice Way, Post Falls, ID 83854 for archival.

Sealing Label

ATTENTION:

THIS SEAL IS NOT TO BE BROKEN WITHOUT PRIOR AUTHORIZATION FROM THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY.

THIS APPLIANCE HAS BEEN SEALED INACCORDANCE WITH REQUIREMNTS OF 40CFR PART 60 SUBPART AAA §60.535 (a)(2)(vii)

REPORT # _____

DATE SEALED _____

MANUFACTURER _____

MODEL # _____

Sealed Unit



List of Appendices

The following appendices have been submitted electronically in conjunction with this report:

Appendix A – Test Run Data, Technician Notes, and Sample Analysis- Page 20 of Non-CBI PDF

Appendix B – Labels and Manuals- Page 111 Non-CBI PDF

Appendix C –Equipment Calibration Records- Page 143 Non-CBI PDF

Appendix D – Design Drawings (CBI Report Only)

Appendix E – Manufacturer QAP (CBI Report Only)

PELLET TEST DATA PACKET
ASTM E2779/E2515



Run 1 Data Summary

Client: 509 Fabrications
Model: Mini Me
Job #: 24-265
Tracking #: 212
Test Date: 8/13/2024



Technician Signature

8/28/2024

Date

TEST RESULTS - ASTM E2779 / ASTM E2515

Client: 509 FabricationsModel: Mini MeRun #: 1Job #: 24-265Tracking #: 212Technician: AKDate: 8/13/2024

| Burn Rate Summary | |
|-------------------------------|------|
| High Burn Rate (dry kg/hr) | 1.98 |
| Medium Burn Rate (dry kg/hr) | 1.55 |
| Low Burn Rate (dry kg/hr) | 0.85 |
| Overall Burn Rate (dry kg/hr) | 1.27 |

Medium Burn Rate Target: < 1.41 dry kg/hr

| | Ambient Sample | Sample Train A | Sample Train B | 1st Hour Filter - Train C |
|---|-------------------|-------------------|-------------------|------------------------------|
| Total Sample Volume (ft ³) | 82.541 | 56.412 | 56.204 | 9.113 |
| Average Gas Velocity in Dilution Tunnel (ft/sec) | 18.3 | | | |
| Average Gas Flow Rate in Dilution Tunnel (dscf/hr) | 11833.0 | | | |
| Average Gas Meter Temperature (°F) | 72.2 | 90.7 | 95.6 | 82.5 |
| Total Sample Volume (dscf) | 82.397 | 54.311 | 54.486 | 8.982 |
| Average Tunnel Temperature (°F) | 105.7 | | | |
| Total Time of Test (min) | 360 | | | |
| Total Particulate Catch (mg) | 0.1 | 1.9 | 1.7 | 0.6 |
| Particulate Concentration, dry-standard (g/dscf) | 0.0000012 | 0.0000350 | 0.0000312 | 0.0000668 |
| Total PM Emissions (g) | 0.09 | 2.40 | 2.13 | 0.78 |
| Particulate Emission Rate (g/hr) | 0.01 | 0.40 | 0.35 | 0.78 |
| Emissions Factor (g/kg) | - | 0.31 | 0.28 | 0.39 |
| Difference from Average Total Particulate Emissions (g) | - | 0.13 | 0.13 | - |
| Difference from Average Total Particulate Emissions (%) | - | 5.9% | 5.9% | - |
| Difference from Average Emissions Factor (g/kg) | - | 0.02 | 0.02 | - |

| Final Average Results | |
|----------------------------------|-------|
| Total Particulate Emissions (g) | 2.26 |
| Particulate Emission Rate (g/hr) | 0.38 |
| Emissions Factor (g/kg) | 0.30 |
| HHV Efficiency (%) | 74.7% |
| LHV Efficiency (%) | 80.1% |
| CO Emissions (g/min) | 0.25 |

| Quality Checks | Requirement | Observed | Result |
|----------------------------------|---|--------------------------|----------------|
| Dual Train Precision | Each train within 7.5% of average emissions (in grams), or emission factors within 0.5 g/kg | See Above | OK |
| Filter Temps | <90 °F | 81.6 | OK |
| Face Velocity | < 30 ft/min | 8.8 | OK |
| Leakage Rate | Less than 4% of average sample rate | 0.001 cfm | OK |
| Ambient Temp | 55-90 °F | 70.7 / 73 | OK |
| Negative Probe Weight Evaluation | <5% of Total Catch | Probe Catch Not Negative | OK |
| Pro-Rate Variation | 90% of readings between 90-110%; none greater than 120% or less than 80% | See Data Tabs | OK |
| Medium Burn Rate | < midpoint of the high and low burn rates | 1.55 | Not Acceptable |

Overall Pellet Test Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/13/24
Run: 1
Control #: 24-265
Test Duration: 360
Output Category: Integrated

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 74.7% | 80.1% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 75.1% | 80.5% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 19,077 | 18,096 | (Btu/h) |
| Burn Rate (kg/h) | 1.27 | 2.81 | (lb/h) |
| Input (kJ/h) | 25,534 | 24,222 | (Btu/h) |

| | | | |
|----------------------------------|------|-------|---------------|
| Test Load Weight (dry kg) | 7.64 | 16.84 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | 2.26 | | |
| CO (g) | 88 | | |
| Test Duration (h) | 6.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | 0.02 | 0.77 |
| g/kg Dry Fuel | 0.30 | 11.57 |
| g/h | 0.38 | 14.74 |
| g/min | 0.01 | 0.25 |
| lb/MM Btu Output | 0.05 | 1.80 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 13.57 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

Max Burn Rate Segment Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/13/24
Run: 1
Control #: 24-265
Test Duration: 60
Output Category: Maximum

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 73.9% | 79.2% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 74.3% | 79.6% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 29,310 | 27,803 | (Btu/h) |
| Burn Rate (kg/h) | 1.98 | 4.36 | (lb/h) |
| Input (kJ/h) | 39,638 | 37,601 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 1.98 | 4.36 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | N/A | | |
| CO (g) | 10 | | |
| Test Duration (h) | 1.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|------|
| g/MJ Output | N/A | 0.33 |
| g/kg Dry Fuel | N/A | 4.95 |
| g/h | N/A | 9.79 |
| g/min | N/A | 0.16 |
| lb/MM Btu Output | N/A | 0.78 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 10.19 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

Medium Burn Rate Segment Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/13/24
Run: 1
Control #: 24-265
Test Duration: 120
Output Category: Medium

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 74.8% | 80.2% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 75.2% | 80.6% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 23,293 | 22,096 | (Btu/h) |
| Burn Rate (kg/h) | 1.55 | 3.42 | (lb/h) |
| Input (kJ/h) | 31,131 | 29,531 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 3.10 | 6.84 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | N/A | | |
| CO (g) | 30 | | |
| Test Duration (h) | 2.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | N/A | 0.64 |
| g/kg Dry Fuel | N/A | 9.53 |
| g/h | N/A | 14.80 |
| g/min | N/A | 0.25 |
| lb/MM Btu Output | N/A | 1.48 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 11.37 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

Minimum Burn Rate Segment Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/13/24
Run: 1
Control #: 24-265
Test Duration: 180
Output Category: Minimum

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 74.5% | 79.8% |
| Combustion Efficiency | 99.2% | 99.2% |
| Heat Transfer Efficiency | 75.1% | 80.5% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 12,743 | 12,088 | (Btu/h) |
| Burn Rate (kg/h) | 0.85 | 1.88 | (lb/h) |
| Input (kJ/h) | 17,102 | 16,223 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 2.56 | 5.64 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | N/A | | |
| CO (g) | 49 | | |
| Test Duration (h) | 3.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | N/A | 1.28 |
| g/kg Dry Fuel | N/A | 19.18 |
| g/h | N/A | 16.36 |
| g/min | N/A | 0.27 |
| lb/MM Btu Output | N/A | 2.98 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 17.76 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

DILUTION TUNNEL & MISC. DATA - ASTM E2779 / E2515

Client: 509 Fabrications
 Model: Mini Me
 Run #: 1
 Test Start Time: 9:28

Job #: 24-265
 Tracking #: 212
 Technician: AK
 Date: 8/13/2024

High Burn End Time (min): 60
 Medium Burn End Time (min): 180
 Total Sampling Time (min): 360
 Recording Interval (min): 1

Meter Box γ Factor: 0.996 (A)
 Meter Box γ Factor: 1.012 (B)
 Meter Box γ Factor: 1.008 (C)
 Meter Box γ Factor: 1.004 (Ambient)
 Induced Draft Check (in. H₂O): 0
 Smoke Capture Check (%): 100%
 Date Flue Pipe Last Cleaned: 8/12/2024
 Platform Scale Audit (lbs): 10.0

| | Pre-Test | Post Test | Avg. |
|------------------------------|------------------------|-----------|-------|
| Barometric Pressure (in. Hg) | 30.01 | 29.98 | 30.00 |
| Relative Humidity (%) | 41.8 | 33.9 | |
| Room Air Velocity (ft/min) | <50 | <50 | |
| Pitot Tube Leak Check | 0 | 0 | |
| Ambient Sample Volume: | 82.541 ft ³ | | |

Sample Train Leak Checks

| | Pre-test | Post-test | | |
|-----------|----------|-----------|-------|------------|
| (A) | 0.000 | 0.001 | cfm @ | -6 in. Hg |
| (B) | 0.000 | 0.000 | cfm @ | -7 in. Hg |
| (C) | 0.001 | 0.001 | cfm @ | -6 in. Hg |
| (Ambient) | 0.000 | 0.000 | cfm @ | -14 in. Hg |

DILUTION TUNNEL FLOW

Traverse Data

| Point | dP (in H ₂ O) | Temp (°F) |
|--------|--------------------------|-----------|
| 1 | 0.052 | 74 |
| 2 | 0.090 | 74 |
| 3 | 0.090 | 74 |
| 4 | 0.052 | 74 |
| 5 | 0.054 | 74 |
| 6 | 0.092 | 74 |
| 7 | 0.092 | 74 |
| 8 | 0.054 | 74 |
| Center | 0.096 | 74 |

Dilution Tunnel H₂O: 2.00 percent
 Tunnel Diameter: 6 inches
 Pitot Tube C_p: 0.99 [unitless]
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Tunnel Area: 0.1963 ft²

V_{strav}: 17.701 ft/sec
 V_{scent}: 20.624 ft/sec
 F_p: 0.858 [ratio]
 Initial Tunnel Flow: 202.5 scf/min

Static Pressure: -0.160 in. H₂O

TEST FUEL PROPERTIES

Default Fuel Values

| Fuel Type: | D. Fir | Oak |
|-------------|--------|--------|
| HHV (kJ/kg) | 19,810 | 19,887 |
| %C | 48.73 | 50 |
| %H | 6.87 | 6.6 |
| %O | 43.9 | 42.9 |
| %Ash | 0.5 | 0.5 |

Actual Fuel Used Properties

| | |
|--------------------|-------------|
| Pellet Brand: | Lignetics |
| Pellet Fuel Grade: | PFI Premium |
| HHV (BTU/lb) | 8627 |
| %C | 49.48 |
| %H | 6.22 |
| %O | 44.13 |
| %Ash | 0.17 |
| MC (%WB) | 2.1 |

PELLET STOVE PREBURN DATA - ASTM E2779

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024
 Recording Interval (min): 1
 Run Time (min): 60

| Elapsed Time (min) | Scale Reading (lbs) | Average: | | | |
|--------------------|---------------------|---------------------|----------------------------------|-----------|--------------|
| | | Weight Change (lbs) | Flue Draft (in H ₂ O) | Flue (°F) | Ambient (°F) |
| 0 | 34.4 | - | -0.085 | 490 | 70 |
| 1 | 34.3 | -0.04 | -0.087 | 514 | 70 |
| 2 | 34.3 | -0.05 | -0.083 | 494 | 70 |
| 3 | 34.2 | -0.05 | -0.086 | 499 | 70 |
| 4 | 34.2 | -0.06 | -0.088 | 510 | 70 |
| 5 | 34.1 | -0.05 | -0.086 | 494 | 70 |
| 6 | 34.1 | -0.05 | -0.084 | 483 | 70 |
| 7 | 34.0 | -0.05 | -0.089 | 510 | 70 |
| 8 | 33.9 | -0.07 | -0.089 | 533 | 70 |
| 9 | 33.9 | -0.08 | -0.092 | 526 | 70 |
| 10 | 33.8 | -0.07 | -0.094 | 550 | 70 |
| 11 | 33.7 | -0.06 | -0.094 | 553 | 70 |
| 12 | 33.7 | -0.06 | -0.090 | 543 | 70 |
| 13 | 33.6 | -0.09 | -0.092 | 552 | 70 |
| 14 | 33.5 | -0.08 | -0.093 | 549 | 70 |
| 15 | 33.5 | -0.02 | -0.091 | 530 | 70 |
| 16 | 33.4 | -0.08 | -0.094 | 548 | 70 |
| 17 | 33.3 | -0.06 | -0.093 | 558 | 70 |
| 18 | 33.3 | -0.06 | -0.091 | 538 | 70 |
| 19 | 33.2 | -0.07 | -0.095 | 552 | 70 |
| 20 | 33.2 | -0.06 | -0.092 | 565 | 70 |
| 21 | 33.1 | -0.07 | -0.093 | 567 | 70 |
| 22 | 33.0 | -0.06 | -0.095 | 569 | 70 |
| 23 | 32.9 | -0.09 | -0.094 | 571 | 70 |
| 24 | 32.9 | -0.05 | -0.095 | 580 | 70 |
| 25 | 32.8 | -0.05 | -0.095 | 576 | 71 |
| 26 | 32.8 | -0.07 | -0.093 | 573 | 71 |
| 27 | 32.7 | -0.05 | -0.096 | 579 | 71 |
| 28 | 32.6 | -0.08 | -0.100 | 596 | 71 |
| 29 | 32.5 | -0.09 | -0.096 | 595 | 70 |
| 30 | 32.5 | -0.07 | -0.098 | 610 | 71 |
| 31 | 32.4 | -0.08 | -0.100 | 625 | 71 |
| 32 | 32.3 | -0.07 | -0.096 | 622 | 71 |
| 33 | 32.2 | -0.11 | -0.095 | 590 | 70 |
| 34 | 32.2 | -0.05 | -0.097 | 582 | 70 |
| 35 | 32.1 | -0.06 | -0.097 | 587 | 70 |
| 36 | 32.0 | -0.08 | -0.095 | 594 | 71 |
| 37 | 32.0 | -0.07 | -0.096 | 577 | 71 |
| 38 | 31.9 | -0.07 | -0.095 | 575 | 71 |
| 39 | 31.8 | -0.05 | -0.095 | 573 | 71 |
| 40 | 31.7 | -0.1 | -0.098 | 590 | 71 |
| 41 | 31.7 | -0.05 | -0.096 | 597 | 71 |
| 42 | 31.6 | -0.06 | -0.099 | 612 | 71 |
| 43 | 31.6 | -0.07 | -0.099 | 617 | 71 |
| 44 | 31.4 | -0.12 | -0.099 | 615 | 71 |
| 45 | 31.4 | -0.02 | -0.098 | 604 | 71 |
| 46 | 31.3 | -0.08 | -0.097 | 600 | 71 |

PELLET STOVE PREBURN DATA - ASTM E2779

Client: 509 Fabrications Job #: 24-265
Model: Mini Me Tracking #: 212
Run #: 1 Technician: AK
Date: 8/13/2024

| | | | | | |
|----|------|-------|--------|-----|----|
| 47 | 31.2 | -0.09 | -0.098 | 600 | 71 |
| 48 | 31.2 | -0.04 | -0.097 | 591 | 71 |
| 49 | 31.1 | -0.07 | -0.098 | 588 | 71 |
| 50 | 31.1 | -0.08 | -0.098 | 595 | 71 |
| 51 | 31.0 | -0.05 | -0.097 | 604 | 71 |
| 52 | 30.9 | -0.06 | -0.098 | 596 | 71 |
| 53 | 30.9 | -0.05 | -0.098 | 599 | 71 |
| 54 | 30.8 | -0.08 | -0.099 | 623 | 71 |
| 55 | 30.7 | -0.1 | -0.100 | 619 | 71 |
| 56 | 30.6 | -0.08 | -0.100 | 608 | 71 |
| 57 | 30.6 | -0.06 | -0.099 | 616 | 71 |
| 58 | 30.5 | -0.12 | -0.097 | 602 | 71 |
| 59 | 30.4 | -0.06 | -0.097 | 595 | 71 |
| 60 | 30.3 | -0.06 | -0.094 | 584 | 71 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 0 | 0.000 | | 0.093 | 0.01 | 74.7 | 0.07 | | 17.2 | | 114 | 585 | 72 | 71 |
| 1 | 0.092 | 0.092 | 0.095 | 2.03 | 74.5 | 0.88 | - | 17.1 | -0.1 | 114 | 586 | 74 | 71.3 |
| 2 | 0.234 | 0.142 | 0.096 | 2.09 | 74.6 | 0.88 | - | 17.1 | -0.1 | 114 | 612 | 74 | 71.2 |
| 3 | 0.381 | 0.147 | 0.092 | 2.14 | 74.6 | 0.91 | - | 17.0 | -0.1 | 114 | 605 | 75 | 71.2 |
| 4 | 0.522 | 0.141 | 0.096 | 2.18 | 74.6 | 0.93 | - | 16.9 | -0.1 | 114 | 609 | 75 | 71.2 |
| 5 | 0.671 | 0.149 | 0.095 | 2.22 | 74.7 | 0.88 | - | 16.8 | -0.1 | 114 | 608 | 75 | 71.4 |
| 6 | 0.815 | 0.144 | 0.096 | 2.24 | 74.8 | 0.89 | - | 16.8 | -0.1 | 114 | 596 | 76 | 71.4 |
| 7 | 0.966 | 0.151 | 0.096 | 2.28 | 74.9 | 0.87 | - | 16.7 | -0.1 | 114 | 595 | 76 | 71.3 |
| 8 | 1.111 | 0.145 | 0.094 | 2.29 | 75 | 0.87 | - | 16.7 | -0.1 | 114 | 587 | 76 | 71.5 |
| 9 | 1.263 | 0.152 | 0.098 | 2.31 | 75.2 | 0.93 | - | 16.6 | -0.1 | 113 | 587 | 77 | 71.3 |
| 10 | 1.410 | 0.147 | 0.095 | 2.32 | 75.3 | 0.89 | 94 | 16.5 | -0.1 | 113 | 591 | 77 | 71.3 |
| 11 | 1.564 | 0.154 | 0.095 | 2.34 | 75.5 | 0.93 | - | 16.4 | -0.1 | 114 | 621 | 77 | 71.1 |
| 12 | 1.712 | 0.148 | 0.095 | 2.36 | 75.6 | 0.88 | - | 16.4 | -0.1 | 115 | 640 | 78 | 71.4 |
| 13 | 1.866 | 0.154 | 0.096 | 2.36 | 75.9 | 0.88 | - | 16.3 | -0.1 | 116 | 649 | 78 | 71.5 |
| 14 | 2.014 | 0.148 | 0.097 | 2.36 | 76.1 | 0.91 | - | 16.2 | -0.1 | 117 | 665 | 78 | 71.3 |
| 15 | 2.169 | 0.155 | 0.097 | 2.37 | 76.3 | 0.9 | - | 16.1 | -0.1 | 117 | 653 | 78 | 71.4 |
| 16 | 2.317 | 0.148 | 0.097 | 2.37 | 76.5 | 0.94 | - | 16.0 | -0.1 | 118 | 661 | 78 | 71.5 |
| 17 | 2.473 | 0.156 | 0.095 | 2.39 | 76.7 | 0.91 | - | 16.0 | 0.0 | 118 | 659 | 79 | 71.5 |
| 18 | 2.622 | 0.149 | 0.095 | 2.38 | 77 | 0.91 | - | 15.8 | -0.1 | 118 | 639 | 79 | 71.4 |
| 19 | 2.778 | 0.156 | 0.095 | 2.40 | 77.3 | 0.93 | - | 15.8 | -0.1 | 117 | 626 | 79 | 71.2 |
| 20 | 2.928 | 0.150 | 0.095 | 2.40 | 77.5 | 0.92 | 101 | 15.7 | -0.1 | 117 | 620 | 79 | 71.1 |
| 21 | 3.083 | 0.155 | 0.094 | 2.40 | 77.8 | 0.92 | - | 15.7 | -0.1 | 116 | 613 | 79 | 71.1 |
| 22 | 3.233 | 0.150 | 0.094 | 2.41 | 78 | 0.91 | - | 15.6 | 0.0 | 116 | 617 | 79 | 71.2 |
| 23 | 3.389 | 0.156 | 0.096 | 2.42 | 78.3 | 0.91 | - | 15.6 | -0.1 | 116 | 606 | 79 | 71.2 |
| 24 | 3.541 | 0.152 | 0.094 | 2.42 | 78.6 | 0.93 | - | 15.5 | 0.0 | 115 | 597 | 79 | 71.3 |
| 25 | 3.696 | 0.155 | 0.094 | 2.42 | 78.9 | 0.92 | - | 15.4 | -0.1 | 115 | 604 | 79 | 71.2 |
| 26 | 3.851 | 0.155 | 0.094 | 2.44 | 79.2 | 0.94 | - | 15.3 | -0.1 | 115 | 605 | 79 | 71.3 |
| 27 | 4.004 | 0.153 | 0.095 | 2.44 | 79.5 | 0.91 | - | 15.3 | -0.1 | 116 | 626 | 80 | 71.8 |
| 28 | 4.160 | 0.156 | 0.095 | 2.45 | 79.8 | 0.91 | - | 15.2 | -0.1 | 116 | 616 | 80 | 71.6 |
| 29 | 4.311 | 0.151 | 0.095 | 2.46 | 80.1 | 0.94 | - | 15.1 | -0.1 | 116 | 632 | 80 | 71.4 |
| 30 | 4.469 | 0.158 | 0.094 | 2.45 | 80.3 | 0.94 | 102 | 15.0 | -0.1 | 116 | 627 | 80 | 71.5 |
| 31 | 4.621 | 0.152 | 0.094 | 2.46 | 80.7 | 0.92 | - | 15.0 | -0.1 | 116 | 604 | 80 | 71.2 |
| 32 | 4.779 | 0.158 | 0.093 | 2.46 | 80.9 | 0.97 | - | 14.9 | -0.1 | 115 | 601 | 80 | 71.1 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 33 | 4.931 | 0.152 | 0.095 | 2.46 | 81.2 | 0.94 | - | 14.8 | -0.1 | 115 | 597 | 80 | 71.1 |
| 34 | 5.088 | 0.157 | 0.094 | 2.47 | 81.5 | 0.92 | - | 14.7 | -0.1 | 115 | 596 | 80 | 71.2 |
| 35 | 5.244 | 0.156 | 0.093 | 2.47 | 81.7 | 0.94 | - | 14.7 | -0.1 | 116 | 631 | 80 | 71.3 |
| 36 | 5.399 | 0.155 | 0.095 | 2.48 | 82 | 0.95 | - | 14.6 | -0.1 | 116 | 647 | 80 | 71.3 |
| 37 | 5.557 | 0.158 | 0.094 | 2.47 | 82.3 | 0.95 | - | 14.5 | -0.1 | 116 | 628 | 80 | 71.1 |
| 38 | 5.710 | 0.153 | 0.094 | 2.48 | 82.5 | 0.94 | - | 14.4 | -0.1 | 116 | 614 | 80 | 71 |
| 39 | 5.869 | 0.159 | 0.093 | 2.49 | 82.8 | 0.94 | - | 14.3 | -0.1 | 116 | 612 | 80 | 71 |
| 40 | 6.023 | 0.154 | 0.097 | 2.49 | 83 | 0.95 | 102 | 14.3 | -0.1 | 116 | 630 | 80 | 71.2 |
| 41 | 6.181 | 0.158 | 0.095 | 2.49 | 83.3 | 0.94 | - | 14.2 | -0.1 | 115 | 601 | 80 | 71.1 |
| 42 | 6.336 | 0.155 | 0.095 | 2.51 | 83.5 | 0.96 | - | 14.1 | -0.1 | 115 | 598 | 80 | 70.8 |
| 43 | 6.493 | 0.157 | 0.095 | 2.50 | 83.7 | 0.95 | - | 14.0 | -0.1 | 115 | 612 | 80 | 70.8 |
| 44 | 6.651 | 0.158 | 0.096 | 2.49 | 84 | 0.95 | - | 14.0 | -0.1 | 115 | 613 | 80 | 70.9 |
| 45 | 6.805 | 0.154 | 0.097 | 2.50 | 84.2 | 0.95 | - | 13.9 | -0.1 | 115 | 603 | 80 | 71.2 |
| 46 | 6.964 | 0.159 | 0.096 | 2.50 | 84.4 | 0.95 | - | 13.9 | -0.1 | 116 | 609 | 80 | 71.1 |
| 47 | 7.119 | 0.155 | 0.097 | 2.50 | 84.7 | 0.95 | - | 13.7 | -0.1 | 116 | 646 | 80 | 71.2 |
| 48 | 7.279 | 0.160 | 0.095 | 2.51 | 84.9 | 0.94 | - | 13.7 | 0.0 | 117 | 642 | 80 | 71.1 |
| 49 | 7.433 | 0.154 | 0.095 | 2.51 | 85 | 0.96 | - | 13.6 | -0.1 | 116 | 636 | 80 | 71.2 |
| 50 | 7.591 | 0.158 | 0.095 | 2.51 | 85.3 | 0.95 | 102 | 13.6 | 0.0 | 117 | 636 | 80 | 71.4 |
| 51 | 7.750 | 0.159 | 0.094 | 2.51 | 85.4 | 0.95 | - | 13.5 | -0.1 | 117 | 639 | 80 | 71.1 |
| 52 | 7.904 | 0.154 | 0.097 | 2.52 | 85.7 | 0.94 | - | 13.4 | -0.1 | 118 | 643 | 80 | 71.2 |
| 53 | 8.064 | 0.160 | 0.093 | 2.51 | 85.9 | 0.96 | - | 13.3 | -0.1 | 118 | 627 | 80 | 71.4 |
| 54 | 8.220 | 0.156 | 0.095 | 2.52 | 86.1 | 0.97 | - | 13.3 | 0.0 | 117 | 624 | 80 | 71.4 |
| 55 | 8.380 | 0.160 | 0.095 | 2.51 | 86.3 | 0.97 | - | 13.2 | -0.1 | 117 | 635 | 80 | 71.6 |
| 56 | 8.535 | 0.155 | 0.097 | 2.52 | 86.5 | 0.97 | - | 13.1 | -0.1 | 118 | 655 | 80 | 71.5 |
| 57 | 8.693 | 0.158 | 0.096 | 2.51 | 86.7 | 0.95 | - | 13.0 | -0.1 | 119 | 678 | 81 | 71.4 |
| 58 | 8.853 | 0.160 | 0.096 | 2.53 | 86.9 | 0.96 | - | 12.9 | -0.1 | 120 | 670 | 81 | 71.5 |
| 59 | 9.007 | 0.154 | 0.097 | 2.53 | 87.1 | 0.95 | - | 12.8 | -0.1 | 119 | 667 | 80 | 71.4 |
| 60 | 9.169 | 0.162 | 0.096 | 2.51 | 87.2 | 0.96 | 103 | 12.8 | -0.1 | 119 | 688 | 80 | 71.2 |
| 61 | 9.324 | 0.155 | 0.094 | 2.52 | 87.3 | 0.98 | - | 12.7 | 0.0 | 116 | 590 | 80 | 70.7 |
| 62 | 9.482 | 0.158 | 0.096 | 2.53 | 87.5 | 0.96 | - | 12.7 | 0.0 | 112 | 489 | 80 | 71.3 |
| 63 | 9.640 | 0.158 | 0.094 | 2.51 | 87.6 | 0.98 | - | 12.6 | -0.1 | 112 | 569 | 80 | 71.6 |
| 64 | 9.798 | 0.158 | 0.096 | 2.50 | 87.8 | 0.99 | - | 12.5 | -0.1 | 112 | 594 | 80 | 71.5 |
| 65 | 9.956 | 0.158 | 0.095 | 2.51 | 87.9 | 1 | - | 12.4 | -0.1 | 113 | 598 | 80 | 71.3 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 66 | 10.111 | 0.155 | 0.096 | 2.50 | 88.1 | 1.02 | - | 12.3 | -0.1 | 113 | 598 | 80 | 71.3 |
| 67 | 10.272 | 0.161 | 0.096 | 2.51 | 88.3 | 0.99 | - | 12.3 | -0.1 | 113 | 583 | 80 | 71.1 |
| 68 | 10.427 | 0.155 | 0.094 | 2.51 | 88.4 | 1.01 | - | 12.2 | -0.1 | 113 | 585 | 80 | 71.1 |
| 69 | 10.586 | 0.159 | 0.094 | 2.51 | 88.5 | 0.98 | - | 12.1 | -0.1 | 113 | 589 | 80 | 71.2 |
| 70 | 10.745 | 0.159 | 0.095 | 2.52 | 88.6 | 1 | 102 | 12.1 | 0.0 | 112 | 579 | 80 | 71.5 |
| 71 | 10.901 | 0.156 | 0.094 | 2.52 | 88.7 | 1.01 | - | 12.0 | -0.1 | 112 | 583 | 80 | 71.7 |
| 72 | 11.061 | 0.160 | 0.095 | 2.51 | 88.9 | 1 | - | 12.0 | -0.1 | 112 | 580 | 80 | 71.3 |
| 73 | 11.216 | 0.155 | 0.095 | 2.52 | 89.1 | 1 | - | 11.9 | -0.1 | 112 | 581 | 80 | 71.7 |
| 74 | 11.377 | 0.161 | 0.095 | 2.52 | 89.1 | 0.99 | - | 11.8 | -0.1 | 112 | 591 | 80 | 71.4 |
| 75 | 11.532 | 0.155 | 0.094 | 2.52 | 89.2 | 0.99 | - | 11.8 | 0.0 | 112 | 605 | 80 | 71.3 |
| 76 | 11.691 | 0.159 | 0.097 | 2.50 | 89.4 | 0.99 | - | 11.7 | -0.1 | 113 | 634 | 80 | 71.4 |
| 77 | 11.852 | 0.161 | 0.095 | 2.52 | 89.4 | 1.02 | - | 11.6 | -0.1 | 114 | 634 | 80 | 71.3 |
| 78 | 12.006 | 0.154 | 0.096 | 2.53 | 89.5 | 1 | - | 11.5 | -0.1 | 114 | 620 | 80 | 71.3 |
| 79 | 12.167 | 0.161 | 0.095 | 2.52 | 89.6 | 0.99 | - | 11.5 | -0.1 | 114 | 610 | 80 | 71.3 |
| 80 | 12.323 | 0.156 | 0.095 | 2.52 | 89.7 | 0.99 | 102 | 11.4 | -0.1 | 114 | 618 | 80 | 71.3 |
| 81 | 12.482 | 0.159 | 0.097 | 2.52 | 89.8 | 1.01 | - | 11.3 | -0.1 | 113 | 580 | 80 | 71.5 |
| 82 | 12.640 | 0.158 | 0.095 | 2.51 | 89.9 | 1 | - | 11.3 | 0.0 | 112 | 570 | 80 | 71.8 |
| 83 | 12.798 | 0.158 | 0.096 | 2.51 | 90.1 | 1.01 | - | 11.2 | -0.1 | 113 | 593 | 80 | 71.4 |
| 84 | 12.957 | 0.159 | 0.096 | 2.53 | 90.2 | 0.99 | - | 11.1 | -0.1 | 113 | 596 | 80 | 71.5 |
| 85 | 13.112 | 0.155 | 0.096 | 2.51 | 90.2 | 1.01 | - | 11.1 | -0.1 | 113 | 583 | 80 | 71.3 |
| 86 | 13.274 | 0.162 | 0.095 | 2.52 | 90.3 | 1.01 | - | 11.0 | -0.1 | 113 | 583 | 80 | 71.3 |
| 87 | 13.428 | 0.154 | 0.096 | 2.52 | 90.4 | 1.02 | - | 10.9 | -0.1 | 112 | 567 | 80 | 71.4 |
| 88 | 13.588 | 0.160 | 0.096 | 2.51 | 90.4 | 1.04 | - | 10.9 | -0.1 | 112 | 572 | 80 | 71.3 |
| 89 | 13.748 | 0.160 | 0.096 | 2.51 | 90.5 | 1 | - | 10.8 | -0.1 | 112 | 578 | 80 | 71.4 |
| 90 | 13.902 | 0.154 | 0.095 | 2.52 | 90.6 | 0.99 | 102 | 10.8 | 0.0 | 112 | 589 | 80 | 71.4 |
| 91 | 14.064 | 0.162 | 0.095 | 2.52 | 90.7 | 1.02 | - | 10.7 | -0.1 | 112 | 558 | 80 | 71.5 |
| 92 | 14.220 | 0.156 | 0.096 | 2.51 | 90.7 | 1.02 | - | 10.7 | 0.0 | 111 | 528 | 80 | 71.6 |
| 93 | 14.378 | 0.158 | 0.095 | 2.52 | 90.8 | 1.03 | - | 10.6 | -0.1 | 110 | 504 | 80 | 71.5 |
| 94 | 14.537 | 0.159 | 0.095 | 2.52 | 90.9 | 1 | - | 10.6 | 0.0 | 109 | 526 | 80 | 71.4 |
| 95 | 14.695 | 0.158 | 0.096 | 2.52 | 91 | 1.04 | - | 10.5 | -0.1 | 109 | 542 | 80 | 71.6 |
| 96 | 14.854 | 0.159 | 0.094 | 2.53 | 91 | 1.01 | - | 10.4 | -0.1 | 110 | 556 | 80 | 71.5 |
| 97 | 15.010 | 0.156 | 0.095 | 2.51 | 91.1 | 1.02 | - | 10.4 | 0.0 | 110 | 542 | 80 | 71.7 |
| 98 | 15.172 | 0.162 | 0.095 | 2.52 | 91.1 | 1 | - | 10.4 | -0.1 | 109 | 539 | 80 | 71.5 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 99 | 15.327 | 0.155 | 0.096 | 2.53 | 91.2 | 1.03 | - | 10.3 | -0.1 | 109 | 534 | 80 | 71.6 |
| 100 | 15.487 | 0.160 | 0.095 | 2.51 | 91.3 | 1.03 | 102 | 10.2 | 0.0 | 109 | 529 | 80 | 71.6 |
| 101 | 15.648 | 0.161 | 0.094 | 2.52 | 91.3 | 1.02 | - | 10.2 | 0.0 | 109 | 536 | 80 | 71.5 |
| 102 | 15.803 | 0.155 | 0.095 | 2.53 | 91.4 | 1.02 | - | 10.1 | -0.1 | 110 | 555 | 80 | 71.6 |
| 103 | 15.964 | 0.161 | 0.095 | 2.51 | 91.5 | 1.01 | - | 10.1 | -0.1 | 109 | 533 | 80 | 71.5 |
| 104 | 16.121 | 0.157 | 0.096 | 2.53 | 91.5 | 1.02 | - | 10.0 | -0.1 | 109 | 542 | 79 | 71.6 |
| 105 | 16.280 | 0.159 | 0.096 | 2.53 | 91.6 | 0.99 | - | 10.0 | 0.0 | 109 | 552 | 79 | 71.6 |
| 106 | 16.439 | 0.159 | 0.095 | 2.51 | 91.7 | 1.03 | - | 9.9 | -0.1 | 110 | 572 | 80 | 71.4 |
| 107 | 16.596 | 0.157 | 0.094 | 2.53 | 91.7 | 1.02 | - | 9.8 | -0.1 | 110 | 588 | 80 | 71.5 |
| 108 | 16.756 | 0.160 | 0.095 | 2.53 | 91.8 | 1.01 | - | 9.8 | 0.0 | 111 | 594 | 80 | 71.6 |
| 109 | 16.913 | 0.157 | 0.096 | 2.53 | 91.8 | 1.03 | - | 9.7 | 0.0 | 111 | 599 | 80 | 71.7 |
| 110 | 17.074 | 0.161 | 0.094 | 2.53 | 91.8 | 1.02 | 103 | 9.6 | -0.1 | 112 | 603 | 80 | 71.8 |
| 111 | 17.230 | 0.156 | 0.095 | 2.52 | 91.9 | 1.04 | - | 9.6 | -0.1 | 112 | 592 | 80 | 71.9 |
| 112 | 17.390 | 0.160 | 0.097 | 2.53 | 92 | 1.03 | - | 9.5 | 0.0 | 112 | 593 | 80 | 71.8 |
| 113 | 17.550 | 0.160 | 0.094 | 2.53 | 92 | 1.02 | - | 9.4 | -0.1 | 112 | 577 | 80 | 71.9 |
| 114 | 17.705 | 0.155 | 0.096 | 2.52 | 92 | 1.02 | - | 9.3 | -0.1 | 112 | 595 | 80 | 72.1 |
| 115 | 17.867 | 0.162 | 0.095 | 2.52 | 92.2 | 1.04 | - | 9.2 | -0.1 | 113 | 605 | 80 | 71.9 |
| 116 | 18.023 | 0.156 | 0.093 | 2.52 | 92.1 | 1.04 | - | 9.2 | -0.1 | 114 | 610 | 80 | 72.3 |
| 117 | 18.182 | 0.159 | 0.096 | 2.51 | 92.2 | 1.04 | - | 9.1 | -0.1 | 114 | 599 | 80 | 72.1 |
| 118 | 18.342 | 0.160 | 0.096 | 2.51 | 92.2 | 1.03 | - | 9.1 | 0.0 | 113 | 594 | 80 | 72.2 |
| 119 | 18.498 | 0.156 | 0.096 | 2.52 | 92.4 | 1.04 | - | 9.0 | -0.1 | 112 | 574 | 80 | 72.2 |
| 120 | 18.659 | 0.161 | 0.098 | 2.52 | 92.4 | 1.05 | 102 | 9.0 | -0.1 | 112 | 563 | 80 | 72 |
| 121 | 18.816 | 0.157 | 0.095 | 2.51 | 92.4 | 1.03 | - | 8.9 | -0.1 | 112 | 573 | 80 | 72.1 |
| 122 | 18.975 | 0.159 | 0.095 | 2.52 | 92.5 | 1.05 | - | 8.8 | -0.1 | 113 | 587 | 80 | 72.3 |
| 123 | 19.133 | 0.158 | 0.097 | 2.51 | 92.5 | 1.03 | - | 8.8 | -0.1 | 113 | 571 | 80 | 72.2 |
| 124 | 19.292 | 0.159 | 0.094 | 2.51 | 92.5 | 1.03 | - | 8.7 | 0.0 | 112 | 550 | 80 | 72.5 |
| 125 | 19.451 | 0.159 | 0.096 | 2.52 | 92.5 | 1.03 | - | 8.7 | -0.1 | 112 | 558 | 80 | 72.4 |
| 126 | 19.607 | 0.156 | 0.096 | 2.51 | 92.6 | 1.02 | - | 8.6 | -0.1 | 112 | 554 | 80 | 72.4 |
| 127 | 19.769 | 0.162 | 0.095 | 2.52 | 92.6 | 1.06 | - | 8.5 | -0.1 | 112 | 562 | 80 | 72.5 |
| 128 | 19.925 | 0.156 | 0.095 | 2.52 | 92.7 | 1.03 | - | 8.5 | -0.1 | 112 | 560 | 80 | 72.7 |
| 129 | 20.084 | 0.159 | 0.095 | 2.51 | 92.8 | 1.06 | - | 8.4 | 0.0 | 111 | 562 | 80 | 72.9 |
| 130 | 20.245 | 0.161 | 0.095 | 2.52 | 92.8 | 1.07 | 101 | 8.4 | 0.0 | 112 | 582 | 80 | 72.8 |
| 131 | 20.399 | 0.154 | 0.098 | 2.53 | 92.8 | 1.05 | - | 8.3 | -0.1 | 112 | 573 | 80 | 72.8 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 132 | 20.561 | 0.162 | 0.096 | 2.51 | 92.9 | 1.03 | - | 8.2 | -0.1 | 112 | 550 | 80 | 72.7 |
| 133 | 20.717 | 0.156 | 0.095 | 2.52 | 92.9 | 1.05 | - | 8.2 | -0.1 | 111 | 523 | 80 | 72.7 |
| 134 | 20.876 | 0.159 | 0.095 | 2.53 | 92.9 | 1.04 | - | 8.1 | 0.0 | 110 | 503 | 80 | 72.3 |
| 135 | 21.035 | 0.159 | 0.096 | 2.51 | 93 | 1.03 | - | 8.1 | -0.1 | 110 | 513 | 80 | 72.4 |
| 136 | 21.193 | 0.158 | 0.096 | 2.52 | 93 | 1.05 | - | 8.0 | 0.0 | 110 | 547 | 80 | 72.7 |
| 137 | 21.353 | 0.160 | 0.095 | 2.53 | 93.1 | 1.03 | - | 8.0 | 0.0 | 110 | 527 | 80 | 72.5 |
| 138 | 21.508 | 0.155 | 0.095 | 2.51 | 93 | 1.05 | - | 8.0 | -0.1 | 109 | 518 | 80 | 72.7 |
| 139 | 21.670 | 0.162 | 0.094 | 2.52 | 93.1 | 1.04 | - | 7.9 | -0.1 | 109 | 509 | 80 | 72.7 |
| 140 | 21.826 | 0.156 | 0.095 | 2.51 | 93.1 | 1.03 | 102 | 7.9 | -0.1 | 109 | 519 | 80 | 72.6 |
| 141 | 21.985 | 0.159 | 0.094 | 2.51 | 93.2 | 1.05 | - | 7.8 | -0.1 | 109 | 523 | 80 | 72.8 |
| 142 | 22.146 | 0.161 | 0.095 | 2.52 | 93.2 | 1.05 | - | 7.7 | 0.0 | 110 | 546 | 80 | 72.7 |
| 143 | 22.300 | 0.154 | 0.096 | 2.52 | 93.2 | 1.04 | - | 7.7 | 0.0 | 111 | 547 | 80 | 72.9 |
| 144 | 22.463 | 0.163 | 0.095 | 2.52 | 93.2 | 1.05 | - | 7.6 | -0.1 | 111 | 550 | 80 | 72.5 |
| 145 | 22.618 | 0.155 | 0.096 | 2.52 | 93.3 | 1.04 | - | 7.5 | -0.1 | 111 | 567 | 80 | 72.8 |
| 146 | 22.777 | 0.159 | 0.094 | 2.51 | 93.4 | 1.07 | - | 7.5 | 0.0 | 112 | 569 | 80 | 72.8 |
| 147 | 22.937 | 0.160 | 0.095 | 2.50 | 93.4 | 1.06 | - | 7.4 | -0.1 | 112 | 562 | 80 | 72.5 |
| 148 | 23.093 | 0.156 | 0.097 | 2.50 | 93.4 | 1.06 | - | 7.3 | -0.1 | 112 | 549 | 80 | 72.6 |
| 149 | 23.253 | 0.160 | 0.097 | 2.50 | 93.4 | 1.06 | - | 7.3 | -0.1 | 111 | 526 | 80 | 72.8 |
| 150 | 23.410 | 0.157 | 0.097 | 2.50 | 93.5 | 1.06 | 101 | 7.3 | 0.0 | 111 | 542 | 80 | 72.8 |
| 151 | 23.570 | 0.160 | 0.096 | 2.50 | 93.5 | 1.06 | - | 7.2 | -0.1 | 112 | 545 | 80 | 72.9 |
| 152 | 23.726 | 0.156 | 0.095 | 2.50 | 93.5 | 1.07 | - | 7.1 | -0.1 | 111 | 517 | 80 | 72.7 |
| 153 | 23.886 | 0.160 | 0.097 | 2.50 | 93.5 | 1.06 | - | 7.1 | 0.0 | 110 | 471 | 80 | 72.5 |
| 154 | 24.045 | 0.159 | 0.095 | 2.51 | 93.5 | 1.06 | - | 7.1 | 0.0 | 108 | 439 | 80 | 72.7 |
| 155 | 24.200 | 0.155 | 0.098 | 2.50 | 93.5 | 1.07 | - | 7.0 | 0.0 | 107 | 434 | 80 | 72.8 |
| 156 | 24.363 | 0.163 | 0.097 | 2.51 | 93.6 | 1.04 | - | 7.0 | 0.0 | 107 | 479 | 80 | 72.4 |
| 157 | 24.518 | 0.155 | 0.095 | 2.51 | 93.6 | 1.06 | - | 7.0 | 0.0 | 107 | 480 | 80 | 72.5 |
| 158 | 24.677 | 0.159 | 0.097 | 2.51 | 93.6 | 1.06 | - | 6.9 | -0.1 | 108 | 480 | 80 | 72.4 |
| 159 | 24.837 | 0.160 | 0.097 | 2.50 | 93.6 | 1.08 | - | 6.9 | 0.0 | 108 | 508 | 80 | 72.3 |
| 160 | 24.993 | 0.156 | 0.097 | 2.51 | 93.7 | 1.08 | 101 | 6.8 | -0.1 | 108 | 509 | 80 | 72.6 |
| 161 | 25.154 | 0.161 | 0.098 | 2.50 | 93.7 | 1.06 | - | 6.8 | -0.1 | 109 | 522 | 80 | 72.4 |
| 162 | 25.311 | 0.157 | 0.098 | 2.50 | 93.6 | 1.06 | - | 6.7 | -0.1 | 109 | 521 | 80 | 72.4 |
| 163 | 25.470 | 0.159 | 0.097 | 2.51 | 93.7 | 1.09 | - | 6.6 | -0.1 | 110 | 551 | 80 | 72.5 |
| 164 | 25.628 | 0.158 | 0.097 | 2.51 | 93.8 | 1.08 | - | 6.6 | 0.0 | 110 | 517 | 80 | 72.7 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 165 | 25.787 | 0.159 | 0.097 | 2.50 | 93.7 | 1.05 | - | 6.5 | -0.1 | 109 | 500 | 80 | 72.7 |
| 166 | 25.946 | 0.159 | 0.096 | 2.50 | 93.8 | 1.11 | - | 6.5 | 0.0 | 110 | 515 | 80 | 72.5 |
| 167 | 26.102 | 0.156 | 0.098 | 2.50 | 93.8 | 1.07 | - | 6.4 | -0.1 | 110 | 513 | 80 | 72.7 |
| 168 | 26.264 | 0.162 | 0.096 | 2.51 | 93.9 | 1.08 | - | 6.4 | -0.1 | 110 | 524 | 80 | 72.8 |
| 169 | 26.419 | 0.155 | 0.095 | 2.52 | 93.8 | 1.05 | - | 6.3 | -0.1 | 110 | 518 | 80 | 72.5 |
| 170 | 26.579 | 0.160 | 0.096 | 2.51 | 93.8 | 1.05 | 101 | 6.3 | 0.0 | 110 | 529 | 80 | 72.7 |
| 171 | 26.740 | 0.161 | 0.097 | 2.50 | 93.9 | 1.09 | - | 6.2 | -0.1 | 111 | 543 | 80 | 72.5 |
| 172 | 26.895 | 0.155 | 0.098 | 2.52 | 93.9 | 1.07 | - | 6.2 | -0.1 | 111 | 540 | 80 | 72.7 |
| 173 | 27.057 | 0.162 | 0.095 | 2.50 | 93.9 | 1.07 | - | 6.1 | -0.1 | 111 | 527 | 80 | 72.7 |
| 174 | 27.213 | 0.156 | 0.096 | 2.51 | 93.9 | 1.05 | - | 6.1 | -0.1 | 111 | 519 | 80 | 72.5 |
| 175 | 27.372 | 0.159 | 0.097 | 2.51 | 94 | 1.09 | - | 6.0 | -0.1 | 111 | 526 | 80 | 72.8 |
| 176 | 27.531 | 0.159 | 0.098 | 2.50 | 94 | 1.09 | - | 6.0 | 0.0 | 110 | 507 | 80 | 72.8 |
| 177 | 27.688 | 0.157 | 0.097 | 2.51 | 94.1 | 1.1 | - | 5.9 | 0.0 | 109 | 498 | 80 | 72.8 |
| 178 | 27.848 | 0.160 | 0.097 | 2.51 | 94.1 | 1.07 | - | 5.9 | -0.1 | 110 | 511 | 80 | 72.8 |
| 179 | 28.004 | 0.156 | 0.096 | 2.50 | 94.1 | 1.09 | - | 5.8 | -0.1 | 110 | 514 | 80 | 72.6 |
| 180 | 28.166 | 0.162 | 0.097 | 2.51 | 94.1 | 1.11 | 101 | 5.8 | -0.1 | 110 | 515 | 80 | 72.7 |
| 181 | 28.322 | 0.156 | 0.095 | 2.52 | 94.1 | 1.08 | - | 5.7 | -0.1 | 109 | 494 | 80 | 72.8 |
| 182 | 28.481 | 0.159 | 0.096 | 2.52 | 94.1 | 1.08 | - | 5.7 | -0.1 | 108 | 475 | 80 | 73 |
| 183 | 28.641 | 0.160 | 0.096 | 2.51 | 94.2 | 1.07 | - | 5.6 | 0.0 | 107 | 468 | 80 | 72.8 |
| 184 | 28.796 | 0.155 | 0.096 | 2.51 | 94.2 | 1.06 | - | 5.6 | 0.0 | 107 | 462 | 80 | 72.5 |
| 185 | 28.959 | 0.163 | 0.097 | 2.51 | 94.2 | 1.09 | - | 5.6 | 0.0 | 107 | 474 | 80 | 72.6 |
| 186 | 29.114 | 0.155 | 0.096 | 2.52 | 94.3 | 1.08 | - | 5.5 | -0.1 | 106 | 461 | 80 | 72.8 |
| 187 | 29.273 | 0.159 | 0.095 | 2.52 | 94.3 | 1.06 | - | 5.5 | 0.0 | 106 | 448 | 80 | 72.6 |
| 188 | 29.434 | 0.161 | 0.097 | 2.51 | 94.3 | 1.08 | - | 5.4 | -0.1 | 105 | 428 | 80 | 72.4 |
| 189 | 29.589 | 0.155 | 0.099 | 2.52 | 94.3 | 1.1 | - | 5.4 | 0.0 | 104 | 418 | 80 | 72.5 |
| 190 | 29.750 | 0.161 | 0.098 | 2.51 | 94.3 | 1.07 | 100 | 5.4 | 0.0 | 103 | 406 | 80 | 72.7 |
| 191 | 29.907 | 0.157 | 0.098 | 2.50 | 94.3 | 1.1 | - | 5.3 | -0.1 | 103 | 401 | 80 | 72.7 |
| 192 | 30.067 | 0.160 | 0.095 | 2.51 | 94.4 | 1.09 | - | 5.3 | 0.0 | 103 | 406 | 80 | 72.6 |
| 193 | 30.225 | 0.158 | 0.096 | 2.52 | 94.4 | 1.07 | - | 5.3 | -0.1 | 102 | 411 | 80 | 72.6 |
| 194 | 30.384 | 0.159 | 0.096 | 2.50 | 94.4 | 1.09 | - | 5.2 | 0.0 | 102 | 412 | 80 | 72.5 |
| 195 | 30.543 | 0.159 | 0.095 | 2.51 | 94.4 | 1.1 | - | 5.2 | 0.0 | 102 | 430 | 80 | 72.4 |
| 196 | 30.699 | 0.156 | 0.098 | 2.50 | 94.4 | 1.08 | - | 5.2 | 0.0 | 103 | 437 | 79 | 72.4 |
| 197 | 30.861 | 0.162 | 0.096 | 2.50 | 94.5 | 1.09 | - | 5.2 | 0.0 | 103 | 419 | 79 | 72.4 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 198 | 31.017 | 0.156 | 0.098 | 2.52 | 94.5 | 1.05 | - | 5.1 | 0.0 | 102 | 410 | 79 | 72.3 |
| 199 | 31.177 | 0.160 | 0.097 | 2.51 | 94.5 | 1.08 | - | 5.1 | -0.1 | 102 | 437 | 79 | 72.5 |
| 200 | 31.338 | 0.161 | 0.098 | 2.50 | 94.5 | 1.06 | 100 | 5.0 | -0.1 | 103 | 466 | 79 | 72.5 |
| 201 | 31.492 | 0.154 | 0.097 | 2.51 | 94.5 | 1.07 | - | 5.0 | 0.0 | 103 | 466 | 79 | 72.6 |
| 202 | 31.654 | 0.162 | 0.098 | 2.51 | 94.5 | 1.09 | - | 4.9 | 0.0 | 104 | 468 | 79 | 72.5 |
| 203 | 31.811 | 0.157 | 0.097 | 2.51 | 94.6 | 1.1 | - | 4.9 | 0.0 | 104 | 451 | 79 | 72.3 |
| 204 | 31.815 | 0.004 | 0.098 | 2.51 | 92.3 | 1.09 | - | 4.9 | 0.0 | 103 | 463 | 75 | 72.1 |
| 205 | 31.968 | 0.153 | 0.097 | 2.36 | 91.2 | 1.04 | - | 4.8 | 0.0 | 102 | 443 | 76 | 72.4 |
| 206 | 32.121 | 0.153 | 0.097 | 2.37 | 90.7 | 1.08 | - | 4.8 | 0.0 | 102 | 439 | 76 | 72.3 |
| 207 | 32.279 | 0.158 | 0.096 | 2.38 | 90.4 | 1.1 | - | 4.8 | 0.0 | 102 | 407 | 76 | 72.4 |
| 208 | 32.432 | 0.153 | 0.097 | 2.39 | 90.2 | 1.04 | - | 4.7 | 0.0 | 101 | 383 | 77 | 72.4 |
| 209 | 32.588 | 0.156 | 0.097 | 2.41 | 90 | 1.05 | - | 4.7 | 0.0 | 100 | 387 | 77 | 72.4 |
| 210 | 32.740 | 0.152 | 0.099 | 2.42 | 89.9 | 1.09 | 88 | 4.7 | 0.0 | 100 | 407 | 77 | 72.5 |
| 211 | 32.897 | 0.157 | 0.098 | 2.41 | 89.8 | 1.09 | - | 4.6 | 0.0 | 100 | 405 | 77 | 72.5 |
| 212 | 33.050 | 0.153 | 0.098 | 2.41 | 89.8 | 1.06 | - | 4.6 | 0.0 | 100 | 404 | 77 | 72.5 |
| 213 | 33.206 | 0.156 | 0.098 | 2.42 | 89.7 | 1.08 | - | 4.6 | 0.0 | 100 | 387 | 77 | 72.5 |
| 214 | 33.359 | 0.153 | 0.097 | 2.43 | 89.7 | 1.09 | - | 4.6 | 0.0 | 99 | 374 | 77 | 72.5 |
| 215 | 33.514 | 0.155 | 0.098 | 2.44 | 89.7 | 1.03 | - | 4.5 | 0.0 | 98 | 363 | 77 | 72.6 |
| 216 | 33.669 | 0.155 | 0.096 | 2.43 | 89.6 | 1.03 | - | 4.5 | -0.1 | 99 | 404 | 77 | 72.5 |
| 217 | 33.826 | 0.157 | 0.098 | 2.43 | 89.7 | 1.07 | - | 4.5 | 0.0 | 99 | 404 | 78 | 72.3 |
| 218 | 33.986 | 0.160 | 0.098 | 2.43 | 89.7 | 1.06 | - | 4.4 | 0.0 | 99 | 403 | 78 | 72.3 |
| 219 | 34.138 | 0.152 | 0.098 | 2.44 | 89.7 | 1.09 | - | 4.4 | -0.1 | 99 | 400 | 78 | 72.1 |
| 220 | 34.297 | 0.159 | 0.098 | 2.44 | 89.8 | 1.07 | 98 | 4.4 | 0.0 | 99 | 391 | 78 | 72.3 |
| 221 | 34.451 | 0.154 | 0.097 | 2.43 | 89.8 | 1.09 | - | 4.4 | 0.0 | 100 | 435 | 78 | 72.3 |
| 222 | 34.610 | 0.159 | 0.099 | 2.44 | 89.9 | 1.06 | - | 4.3 | -0.1 | 101 | 477 | 78 | 72.1 |
| 223 | 34.762 | 0.152 | 0.096 | 2.45 | 89.9 | 1.06 | - | 4.2 | 0.0 | 101 | 458 | 78 | 72.2 |
| 224 | 34.919 | 0.157 | 0.097 | 2.44 | 90 | 1.11 | - | 4.2 | -0.1 | 102 | 477 | 78 | 72.1 |
| 225 | 35.078 | 0.159 | 0.098 | 2.45 | 90.1 | 1.1 | - | 4.2 | 0.0 | 102 | 471 | 78 | 72.4 |
| 226 | 35.230 | 0.152 | 0.097 | 2.44 | 90.1 | 1.06 | - | 4.1 | 0.0 | 102 | 446 | 78 | 72.1 |
| 227 | 35.387 | 0.157 | 0.098 | 2.45 | 90.2 | 1.04 | - | 4.1 | 0.0 | 102 | 433 | 78 | 72.3 |
| 228 | 35.541 | 0.154 | 0.097 | 2.46 | 90.3 | 1.07 | - | 4.1 | 0.0 | 101 | 415 | 78 | 72.3 |
| 229 | 35.701 | 0.160 | 0.098 | 2.45 | 90.3 | 1.1 | - | 4.0 | 0.0 | 101 | 408 | 78 | 72.2 |
| 230 | 35.856 | 0.155 | 0.097 | 2.45 | 90.4 | 1.04 | 98 | 4.0 | 0.0 | 100 | 389 | 78 | 72.3 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 231 | 36.013 | 0.157 | 0.098 | 2.46 | 90.5 | 1.06 | - | 4.0 | 0.0 | 100 | 377 | 78 | 72.4 |
| 232 | 36.173 | 0.160 | 0.097 | 2.45 | 90.7 | 1.06 | - | 3.9 | 0.0 | 99 | 378 | 79 | 72.4 |
| 233 | 36.329 | 0.156 | 0.098 | 2.45 | 90.7 | 1.08 | - | 3.9 | -0.1 | 99 | 404 | 79 | 72.3 |
| 234 | 36.487 | 0.158 | 0.097 | 2.46 | 90.8 | 1.09 | - | 3.9 | 0.0 | 99 | 403 | 79 | 72.4 |
| 235 | 36.640 | 0.153 | 0.098 | 2.46 | 90.9 | 1.09 | - | 3.8 | 0.0 | 99 | 394 | 79 | 72.4 |
| 236 | 36.801 | 0.161 | 0.097 | 2.46 | 91 | 1.07 | - | 3.8 | 0.0 | 99 | 384 | 79 | 72.3 |
| 237 | 36.956 | 0.155 | 0.097 | 2.47 | 91.1 | 1.08 | - | 3.8 | 0.0 | 99 | 388 | 79 | 72.3 |
| 238 | 37.114 | 0.158 | 0.096 | 2.48 | 91.2 | 1.09 | - | 3.7 | 0.0 | 99 | 409 | 79 | 72.3 |
| 239 | 37.267 | 0.153 | 0.097 | 2.46 | 91.3 | 1.07 | - | 3.7 | 0.0 | 99 | 421 | 79 | 72.3 |
| 240 | 37.427 | 0.160 | 0.096 | 2.46 | 91.3 | 1.08 | 100 | 3.7 | -0.1 | 100 | 448 | 79 | 72.3 |
| 241 | 37.586 | 0.159 | 0.097 | 2.47 | 91.5 | 1.07 | - | 3.6 | 0.0 | 101 | 450 | 79 | 72.4 |
| 242 | 37.740 | 0.154 | 0.096 | 2.46 | 91.5 | 1.11 | - | 3.6 | -0.1 | 101 | 443 | 79 | 72.1 |
| 243 | 37.898 | 0.158 | 0.097 | 2.47 | 91.6 | 1.07 | - | 3.5 | 0.0 | 101 | 441 | 79 | 72.3 |
| 244 | 38.053 | 0.155 | 0.097 | 2.47 | 91.7 | 1.09 | - | 3.5 | 0.0 | 101 | 422 | 79 | 72.3 |
| 245 | 38.211 | 0.158 | 0.097 | 2.47 | 91.7 | 1.08 | - | 3.5 | 0.0 | 100 | 415 | 79 | 72.3 |
| 246 | 38.368 | 0.157 | 0.097 | 2.47 | 91.9 | 1.05 | - | 3.5 | 0.0 | 100 | 401 | 79 | 72.2 |
| 247 | 38.526 | 0.158 | 0.096 | 2.46 | 91.9 | 1.09 | - | 3.4 | 0.0 | 99 | 408 | 79 | 72.4 |
| 248 | 38.684 | 0.158 | 0.098 | 2.48 | 92 | 1.08 | - | 3.4 | 0.0 | 99 | 399 | 79 | 72.2 |
| 249 | 38.841 | 0.157 | 0.096 | 2.48 | 92.1 | 1.06 | - | 3.4 | 0.0 | 99 | 385 | 79 | 72.3 |
| 250 | 39.002 | 0.161 | 0.096 | 2.48 | 92.2 | 1.09 | 100 | 3.3 | 0.0 | 98 | 374 | 79 | 72.2 |
| 251 | 39.157 | 0.155 | 0.097 | 2.49 | 92.3 | 1.08 | - | 3.3 | 0.0 | 98 | 375 | 79 | 72.5 |
| 252 | 39.315 | 0.158 | 0.098 | 2.48 | 92.3 | 1.08 | - | 3.3 | 0.0 | 98 | 373 | 79 | 72.2 |
| 253 | 39.474 | 0.159 | 0.097 | 2.48 | 92.4 | 1.08 | - | 3.3 | 0.0 | 98 | 377 | 79 | 72.4 |
| 254 | 39.630 | 0.156 | 0.097 | 2.48 | 92.4 | 1.1 | - | 3.3 | 0.0 | 98 | 358 | 79 | 72.4 |
| 255 | 39.790 | 0.160 | 0.098 | 2.49 | 92.5 | 1.07 | - | 3.2 | -0.1 | 97 | 362 | 78 | 72.3 |
| 256 | 39.941 | 0.151 | 0.097 | 2.48 | 92.5 | 1.08 | - | 3.2 | 0.0 | 97 | 358 | 78 | 72.5 |
| 257 | 40.103 | 0.162 | 0.098 | 2.48 | 92.6 | 1.07 | - | 3.1 | 0.0 | 97 | 360 | 78 | 72.4 |
| 258 | 40.257 | 0.154 | 0.098 | 2.49 | 92.7 | 1.1 | - | 3.1 | 0.0 | 97 | 359 | 78 | 72.2 |
| 259 | 40.416 | 0.159 | 0.097 | 2.47 | 92.7 | 1.09 | - | 3.1 | 0.0 | 97 | 363 | 78 | 72.4 |
| 260 | 40.576 | 0.160 | 0.099 | 2.49 | 92.8 | 1.09 | 99 | 3.1 | 0.0 | 96 | 362 | 78 | 72.3 |
| 261 | 40.731 | 0.155 | 0.097 | 2.49 | 92.9 | 1.07 | - | 3.0 | 0.0 | 97 | 368 | 78 | 72.4 |
| 262 | 40.895 | 0.164 | 0.097 | 2.49 | 92.9 | 1.09 | - | 3.0 | -0.1 | 97 | 401 | 78 | 72.4 |
| 263 | 41.050 | 0.155 | 0.095 | 2.48 | 93 | 1.1 | - | 2.9 | 0.0 | 98 | 412 | 78 | 72.6 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 264 | 41.209 | 0.159 | 0.095 | 2.49 | 93.1 | 1.1 | - | 2.9 | 0.0 | 98 | 424 | 78 | 72.6 |
| 265 | 41.367 | 0.158 | 0.097 | 2.49 | 93.1 | 1.06 | - | 2.9 | 0.0 | 98 | 429 | 78 | 72.6 |
| 266 | 41.525 | 0.158 | 0.097 | 2.49 | 93.2 | 1.11 | - | 2.9 | 0.0 | 99 | 422 | 78 | 72.4 |
| 267 | 41.684 | 0.159 | 0.097 | 2.49 | 93.3 | 1.08 | - | 2.8 | 0.0 | 99 | 416 | 78 | 72.3 |
| 268 | 41.839 | 0.155 | 0.098 | 2.48 | 93.3 | 1.06 | - | 2.8 | -0.1 | 98 | 394 | 78 | 72.4 |
| 269 | 42.001 | 0.162 | 0.098 | 2.48 | 93.3 | 1.1 | - | 2.7 | 0.0 | 98 | 382 | 78 | 72.4 |
| 270 | 42.153 | 0.152 | 0.099 | 2.49 | 93.4 | 1.07 | 98 | 2.7 | 0.0 | 98 | 391 | 78 | 72.5 |
| 271 | 42.312 | 0.159 | 0.098 | 2.49 | 93.4 | 1.1 | - | 2.7 | 0.0 | 97 | 386 | 78 | 72.5 |
| 272 | 42.472 | 0.160 | 0.099 | 2.50 | 93.5 | 1.07 | - | 2.7 | 0.0 | 97 | 370 | 78 | 72.4 |
| 273 | 42.628 | 0.156 | 0.098 | 2.49 | 93.5 | 1.11 | - | 2.6 | 0.0 | 97 | 367 | 78 | 72.4 |
| 274 | 42.788 | 0.160 | 0.097 | 2.50 | 93.6 | 1.09 | - | 2.6 | 0.0 | 97 | 374 | 78 | 72.5 |
| 275 | 42.944 | 0.156 | 0.097 | 2.49 | 93.6 | 1.08 | - | 2.6 | 0.0 | 97 | 380 | 78 | 72.6 |
| 276 | 43.106 | 0.162 | 0.098 | 2.49 | 93.7 | 1.1 | - | 2.6 | 0.0 | 97 | 388 | 78 | 72.5 |
| 277 | 43.263 | 0.157 | 0.098 | 2.49 | 93.8 | 1.07 | - | 2.5 | 0.0 | 98 | 401 | 78 | 72.3 |
| 278 | 43.422 | 0.159 | 0.099 | 2.50 | 93.8 | 1.05 | - | 2.5 | -0.1 | 99 | 439 | 78 | 72.6 |
| 279 | 43.581 | 0.159 | 0.098 | 2.49 | 93.8 | 1.08 | - | 2.4 | 0.0 | 98 | 406 | 78 | 72.5 |
| 280 | 43.736 | 0.155 | 0.098 | 2.49 | 93.9 | 1.07 | 99 | 2.4 | 0.0 | 98 | 375 | 78 | 72.5 |
| 281 | 43.899 | 0.163 | 0.097 | 2.49 | 93.9 | 1.08 | - | 2.4 | 0.0 | 97 | 361 | 78 | 72.5 |
| 282 | 44.054 | 0.155 | 0.098 | 2.49 | 94 | 1.09 | - | 2.4 | 0.0 | 97 | 364 | 78 | 72.6 |
| 283 | 44.210 | 0.156 | 0.099 | 2.50 | 94 | 1.11 | - | 2.3 | 0.0 | 97 | 380 | 78 | 72.3 |
| 284 | 44.370 | 0.160 | 0.098 | 2.49 | 94.1 | 1.08 | - | 2.3 | 0.0 | 97 | 383 | 78 | 72.5 |
| 285 | 44.527 | 0.157 | 0.098 | 2.50 | 94.1 | 1.08 | - | 2.3 | 0.0 | 97 | 365 | 79 | 72.3 |
| 286 | 44.687 | 0.160 | 0.098 | 2.50 | 94.1 | 1.09 | - | 2.3 | 0.0 | 97 | 362 | 78 | 72.5 |
| 287 | 44.843 | 0.156 | 0.098 | 2.50 | 94.2 | 1.07 | - | 2.2 | 0.0 | 96 | 349 | 78 | 72.6 |
| 288 | 45.005 | 0.162 | 0.097 | 2.49 | 94.1 | 1.1 | - | 2.2 | 0.0 | 96 | 362 | 78 | 72.6 |
| 289 | 45.162 | 0.157 | 0.097 | 2.50 | 94.2 | 1.06 | - | 2.2 | 0.0 | 97 | 386 | 78 | 72.6 |
| 290 | 45.321 | 0.159 | 0.098 | 2.50 | 94.3 | 1.1 | 99 | 2.1 | 0.0 | 98 | 401 | 79 | 72.6 |
| 291 | 45.480 | 0.159 | 0.097 | 2.51 | 94.3 | 1.09 | - | 2.1 | 0.0 | 97 | 391 | 79 | 72.7 |
| 292 | 45.636 | 0.156 | 0.096 | 2.49 | 94.3 | 1.11 | - | 2.1 | 0.0 | 97 | 378 | 78 | 72.7 |
| 293 | 45.798 | 0.162 | 0.098 | 2.49 | 94.4 | 1.1 | - | 2.0 | -0.1 | 97 | 389 | 78 | 72.7 |
| 294 | 45.953 | 0.155 | 0.099 | 2.49 | 94.4 | 1.05 | - | 2.0 | 0.0 | 97 | 376 | 78 | 72.5 |
| 295 | 46.110 | 0.157 | 0.097 | 2.49 | 94.4 | 1.06 | - | 2.0 | 0.0 | 96 | 367 | 78 | 72.7 |
| 296 | 46.271 | 0.161 | 0.096 | 2.49 | 94.5 | 1.1 | - | 2.0 | 0.0 | 96 | 349 | 78 | 72.6 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 297 | 46.428 | 0.157 | 0.097 | 2.50 | 94.4 | 1.06 | - | 2.0 | 0.0 | 96 | 346 | 78 | 72.6 |
| 298 | 46.587 | 0.159 | 0.097 | 2.50 | 94.5 | 1.09 | - | 1.9 | 0.0 | 96 | 366 | 78 | 72.5 |
| 299 | 46.743 | 0.156 | 0.098 | 2.50 | 94.5 | 1.09 | - | 1.9 | 0.0 | 96 | 377 | 78 | 72.3 |
| 300 | 46.903 | 0.160 | 0.097 | 2.51 | 94.6 | 1.1 | 99 | 1.9 | 0.0 | 96 | 372 | 78 | 72.5 |
| 301 | 47.060 | 0.157 | 0.098 | 2.49 | 94.6 | 1.11 | - | 1.8 | 0.0 | 96 | 370 | 78 | 72.6 |
| 302 | 47.219 | 0.159 | 0.099 | 2.50 | 94.6 | 1.07 | - | 1.8 | 0.0 | 96 | 382 | 78 | 72.5 |
| 303 | 47.379 | 0.160 | 0.098 | 2.50 | 94.7 | 1.08 | - | 1.8 | 0.0 | 97 | 392 | 78 | 72.5 |
| 304 | 47.538 | 0.159 | 0.097 | 2.49 | 94.6 | 1.08 | - | 1.7 | 0.0 | 96 | 382 | 78 | 72.4 |
| 305 | 47.699 | 0.161 | 0.097 | 2.50 | 94.6 | 1.08 | - | 1.7 | 0.0 | 96 | 379 | 78 | 72.5 |
| 306 | 47.855 | 0.156 | 0.098 | 2.51 | 94.7 | 1.07 | - | 1.7 | 0.0 | 96 | 363 | 78 | 72.5 |
| 307 | 48.014 | 0.159 | 0.098 | 2.49 | 94.7 | 1.08 | - | 1.7 | 0.0 | 96 | 352 | 78 | 72.5 |
| 308 | 48.172 | 0.158 | 0.097 | 2.49 | 94.8 | 1.12 | - | 1.7 | 0.0 | 95 | 346 | 78 | 72.4 |
| 309 | 48.326 | 0.154 | 0.098 | 2.50 | 94.8 | 1.08 | - | 1.7 | 0.0 | 95 | 356 | 78 | 72.5 |
| 310 | 48.488 | 0.162 | 0.099 | 2.50 | 94.8 | 1.13 | 99 | 1.6 | 0.0 | 95 | 372 | 78 | 72.4 |
| 311 | 48.645 | 0.157 | 0.098 | 2.49 | 94.8 | 1.1 | - | 1.6 | 0.0 | 96 | 390 | 78 | 72.4 |
| 312 | 48.804 | 0.159 | 0.098 | 2.50 | 94.8 | 1.1 | - | 1.6 | 0.0 | 97 | 425 | 78 | 72.6 |
| 313 | 48.966 | 0.162 | 0.098 | 2.49 | 94.8 | 1.1 | - | 1.5 | 0.0 | 98 | 448 | 78 | 72.6 |
| 314 | 49.123 | 0.157 | 0.098 | 2.49 | 94.8 | 1.1 | - | 1.5 | 0.0 | 99 | 453 | 78 | 72.6 |
| 315 | 49.283 | 0.160 | 0.097 | 2.50 | 94.9 | 1.09 | - | 1.4 | 0.0 | 98 | 418 | 78 | 72.5 |
| 316 | 49.439 | 0.156 | 0.098 | 2.49 | 94.9 | 1.07 | - | 1.4 | -0.1 | 98 | 391 | 78 | 72.4 |
| 317 | 49.600 | 0.161 | 0.099 | 2.50 | 94.9 | 1.06 | - | 1.4 | 0.0 | 97 | 365 | 78 | 72.5 |
| 318 | 49.756 | 0.156 | 0.099 | 2.51 | 94.9 | 1.11 | - | 1.3 | 0.0 | 96 | 366 | 78 | 72.6 |
| 319 | 49.913 | 0.157 | 0.096 | 2.49 | 95 | 1.08 | - | 1.3 | 0.0 | 96 | 372 | 78 | 72.6 |
| 320 | 50.074 | 0.161 | 0.097 | 2.50 | 95 | 1.09 | 99 | 1.3 | 0.0 | 96 | 368 | 78 | 72.7 |
| 321 | 50.228 | 0.154 | 0.098 | 2.50 | 95 | 1.12 | - | 1.2 | -0.1 | 96 | 377 | 78 | 72.6 |
| 322 | 50.390 | 0.162 | 0.098 | 2.49 | 95 | 1.08 | - | 1.2 | 0.0 | 96 | 380 | 78 | 72.7 |
| 323 | 50.548 | 0.158 | 0.096 | 2.50 | 95.1 | 1.07 | - | 1.2 | 0.0 | 96 | 376 | 78 | 72.5 |
| 324 | 50.708 | 0.160 | 0.099 | 2.50 | 95.1 | 1.07 | - | 1.2 | 0.0 | 96 | 377 | 78 | 72.6 |
| 325 | 50.868 | 0.160 | 0.097 | 2.49 | 95 | 1.13 | - | 1.1 | 0.0 | 96 | 384 | 78 | 72.6 |
| 326 | 51.024 | 0.156 | 0.097 | 2.50 | 95.1 | 1.11 | - | 1.1 | 0.0 | 96 | 380 | 78 | 72.5 |
| 327 | 51.185 | 0.161 | 0.099 | 2.49 | 95.1 | 1.11 | - | 1.1 | 0.0 | 96 | 365 | 78 | 72.7 |
| 328 | 51.339 | 0.154 | 0.099 | 2.49 | 95.1 | 1.12 | - | 1.0 | 0.0 | 96 | 366 | 78 | 72.7 |
| 329 | 51.499 | 0.160 | 0.098 | 2.50 | 95.1 | 1.08 | - | 1.0 | 0.0 | 97 | 408 | 78 | 72.8 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 330 | 51.656 | 0.157 | 0.099 | 2.49 | 95.1 | 1.1 | 99 | 1.0 | 0.0 | 97 | 424 | 79 | 72.8 |
| 331 | 51.818 | 0.162 | 0.098 | 2.50 | 95.1 | 1.09 | - | 0.9 | 0.0 | 98 | 419 | 79 | 72.7 |
| 332 | 51.977 | 0.159 | 0.097 | 2.50 | 95.1 | 1.14 | - | 0.9 | 0.0 | 98 | 412 | 78 | 72.8 |
| 333 | 52.133 | 0.156 | 0.098 | 2.49 | 95.2 | 1.12 | - | 0.9 | 0.0 | 98 | 392 | 79 | 72.7 |
| 334 | 52.296 | 0.163 | 0.097 | 2.50 | 95.2 | 1.06 | - | 0.9 | 0.0 | 97 | 401 | 79 | 72.7 |
| 335 | 52.448 | 0.152 | 0.098 | 2.50 | 95.2 | 1.1 | - | 0.8 | 0.0 | 98 | 403 | 79 | 72.8 |
| 336 | 52.607 | 0.159 | 0.097 | 2.49 | 95.2 | 1.09 | - | 0.8 | 0.0 | 98 | 419 | 79 | 72.8 |
| 337 | 52.771 | 0.164 | 0.097 | 2.49 | 95.2 | 1.08 | - | 0.8 | 0.0 | 98 | 422 | 79 | 72.6 |
| 338 | 52.926 | 0.155 | 0.098 | 2.50 | 95.2 | 1.07 | - | 0.7 | -0.1 | 99 | 428 | 79 | 72.7 |
| 339 | 53.088 | 0.162 | 0.096 | 2.49 | 95.3 | 1.13 | - | 0.7 | 0.0 | 98 | 414 | 79 | 72.8 |
| 340 | 53.244 | 0.156 | 0.097 | 2.49 | 95.2 | 1.11 | 99 | 0.6 | 0.0 | 98 | 420 | 79 | 72.7 |
| 341 | 53.400 | 0.156 | 0.097 | 2.51 | 95.3 | 1.08 | - | 0.6 | 0.0 | 99 | 415 | 79 | 72.6 |
| 342 | 53.559 | 0.159 | 0.097 | 2.50 | 95.3 | 1.08 | - | 0.6 | 0.0 | 99 | 411 | 79 | 72.7 |
| 343 | 53.718 | 0.159 | 0.097 | 2.50 | 95.3 | 1.12 | - | 0.6 | 0.0 | 98 | 398 | 79 | 72.7 |
| 344 | 53.877 | 0.159 | 0.097 | 2.51 | 95.3 | 1.1 | - | 0.5 | 0.0 | 98 | 391 | 79 | 72.6 |
| 345 | 54.033 | 0.156 | 0.099 | 2.50 | 95.3 | 1.08 | - | 0.5 | 0.0 | 98 | 387 | 79 | 72.7 |
| 346 | 54.195 | 0.162 | 0.098 | 2.50 | 95.3 | 1.09 | - | 0.5 | 0.0 | 97 | 382 | 79 | 72.8 |
| 347 | 54.351 | 0.156 | 0.098 | 2.50 | 95.4 | 1.1 | - | 0.4 | 0.0 | 97 | 370 | 79 | 72.7 |
| 348 | 54.513 | 0.162 | 0.094 | 2.49 | 95.3 | 1.08 | - | 0.4 | 0.0 | 97 | 377 | 79 | 72.8 |
| 349 | 54.673 | 0.160 | 0.098 | 2.50 | 95.4 | 1.1 | - | 0.4 | 0.0 | 97 | 369 | 79 | 72.9 |
| 350 | 54.827 | 0.154 | 0.098 | 2.49 | 95.4 | 1.08 | 99 | 0.4 | 0.0 | 97 | 379 | 79 | 72.9 |
| 351 | 54.990 | 0.163 | 0.097 | 2.49 | 95.4 | 1.08 | - | 0.3 | 0.0 | 97 | 389 | 79 | 72.8 |
| 352 | 55.144 | 0.154 | 0.097 | 2.50 | 95.4 | 1.12 | - | 0.3 | -0.1 | 97 | 400 | 79 | 73 |
| 353 | 55.303 | 0.159 | 0.098 | 2.51 | 95.4 | 1.14 | - | 0.3 | 0.0 | 97 | 380 | 79 | 72.8 |
| 354 | 55.465 | 0.162 | 0.097 | 2.49 | 95.5 | 1.12 | - | 0.3 | 0.0 | 96 | 348 | 79 | 72.8 |
| 355 | 55.621 | 0.156 | 0.098 | 2.49 | 95.5 | 1.11 | - | 0.2 | 0.0 | 96 | 330 | 79 | 72.9 |
| 356 | 55.782 | 0.161 | 0.097 | 2.49 | 95.5 | 1.11 | - | 0.2 | 0.0 | 96 | 352 | 79 | 72.8 |
| 357 | 55.938 | 0.156 | 0.098 | 2.49 | 95.4 | 1.08 | - | 0.2 | 0.0 | 96 | 362 | 79 | 72.7 |
| 358 | 56.096 | 0.158 | 0.098 | 2.49 | 95.5 | 1.08 | - | 0.1 | -0.1 | 97 | 393 | 79 | 72.8 |
| 359 | 56.253 | 0.157 | 0.097 | 2.49 | 95.5 | 1.1 | - | 0.1 | 0.0 | 98 | 433 | 79 | 73 |
| 360 | 56.412 | 0.159 | 0.095 | 2.49 | 95.5 | 1.09 | 100 | 0.0 | -0.1 | 99 | 466 | 79 | 73 |
| Avg/Tot | 56.412 | 0.157 | 0.096 | 2.48 | 91 | 1.04 | 100 | | | 106 | 488 | 79 | 72 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 0 | 0.000 | | 0.01 | 75.4 | 0.69 | | 74 | -0.098 | 9.53 | 0.08 |
| 1 | 0.107 | 0.107 | 2.43 | 75.3 | 1.6 | - | 76 | -0.098 | 10.72 | 0.06 |
| 2 | 0.260 | 0.153 | 2.43 | 75.2 | 1.84 | - | 76 | -0.099 | 13.70 | 0.03 |
| 3 | 0.412 | 0.152 | 2.44 | 75.3 | 1.84 | - | 77 | -0.098 | 11.94 | 0.07 |
| 4 | 0.566 | 0.154 | 2.45 | 75.3 | 2.08 | - | 77 | -0.099 | 11.64 | 0.06 |
| 5 | 0.716 | 0.150 | 2.46 | 75.3 | 1.53 | - | 78 | -0.098 | 10.59 | 0.06 |
| 6 | 0.870 | 0.154 | 2.45 | 75.4 | 1.96 | - | 78 | -0.098 | 10.52 | 0.07 |
| 7 | 1.020 | 0.150 | 2.44 | 75.6 | 1.58 | - | 78 | -0.097 | 10.27 | 0.05 |
| 8 | 1.176 | 0.156 | 2.45 | 75.7 | 1.94 | - | 79 | -0.096 | 9.12 | 0.10 |
| 9 | 1.327 | 0.151 | 2.46 | 75.8 | 1.69 | - | 79 | -0.098 | 11.98 | 0.04 |
| 10 | 1.482 | 0.155 | 2.45 | 76 | 1.8 | 100 | 79 | -0.099 | 11.93 | 0.04 |
| 11 | 1.633 | 0.151 | 2.46 | 76.2 | 2.12 | - | 79 | -0.101 | 11.44 | 0.05 |
| 12 | 1.787 | 0.154 | 2.46 | 76.4 | 2.04 | - | 80 | -0.102 | 13.30 | 0.03 |
| 13 | 1.938 | 0.151 | 2.44 | 76.7 | 1.89 | - | 80 | -0.100 | 12.90 | 0.04 |
| 14 | 2.093 | 0.155 | 2.46 | 76.8 | 1.72 | - | 80 | -0.104 | 14.20 | 0.04 |
| 15 | 2.247 | 0.154 | 2.46 | 77.1 | 1.64 | - | 80 | -0.102 | 11.68 | 0.04 |
| 16 | 2.399 | 0.152 | 2.46 | 77.3 | 2.07 | - | 80 | -0.102 | 13.95 | 0.04 |
| 17 | 2.553 | 0.154 | 2.46 | 77.6 | 1.58 | - | 80 | -0.102 | 13.38 | 0.04 |
| 18 | 2.704 | 0.151 | 2.46 | 77.9 | 1.57 | - | 81 | -0.098 | 11.80 | 0.05 |
| 19 | 2.860 | 0.156 | 2.46 | 78.1 | 1.79 | - | 81 | -0.102 | 10.37 | 0.06 |
| 20 | 3.012 | 0.152 | 2.46 | 78.5 | 1.74 | 103 | 81 | -0.098 | 10.35 | 0.06 |
| 21 | 3.168 | 0.156 | 2.47 | 78.8 | 1.82 | - | 81 | -0.101 | 11.95 | 0.04 |
| 22 | 3.319 | 0.151 | 2.46 | 79.1 | 2.06 | - | 81 | -0.101 | 10.37 | 0.07 |
| 23 | 3.474 | 0.155 | 2.46 | 79.4 | 2.02 | - | 81 | -0.097 | 11.05 | 0.07 |
| 24 | 3.627 | 0.153 | 2.46 | 79.7 | 1.71 | - | 81 | -0.097 | 10.11 | 0.08 |
| 25 | 3.782 | 0.155 | 2.47 | 80 | 1.89 | - | 81 | -0.096 | 11.63 | 0.04 |
| 26 | 3.938 | 0.156 | 2.47 | 80.4 | 1.85 | - | 81 | -0.098 | 11.95 | 0.04 |
| 27 | 4.090 | 0.152 | 2.47 | 80.7 | 2.04 | - | 81 | -0.100 | 13.24 | 0.04 |
| 28 | 4.246 | 0.156 | 2.46 | 81 | 1.68 | - | 81 | -0.100 | 11.08 | 0.07 |
| 29 | 4.399 | 0.153 | 2.47 | 81.4 | 1.89 | - | 81 | -0.101 | 12.79 | 0.04 |
| 30 | 4.556 | 0.157 | 2.48 | 81.7 | 1.98 | 104 | 81 | -0.100 | 11.90 | 0.04 |
| 31 | 4.708 | 0.152 | 2.47 | 82 | 1.71 | - | 81 | -0.097 | 11.43 | 0.05 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 32 | 4.864 | 0.156 | 2.47 | 82.3 | 1.95 | - | 81 | -0.097 | 12.38 | 0.04 |
| 33 | 5.020 | 0.156 | 2.48 | 82.7 | 2.04 | - | 81 | -0.096 | 12.34 | 0.05 |
| 34 | 5.175 | 0.155 | 2.48 | 83 | 1.67 | - | 81 | -0.098 | 10.73 | 0.04 |
| 35 | 5.330 | 0.155 | 2.48 | 83.3 | 1.59 | - | 81 | -0.100 | 12.32 | 0.05 |
| 36 | 5.483 | 0.153 | 2.47 | 83.6 | 1.79 | - | 81 | -0.102 | 12.82 | 0.04 |
| 37 | 5.642 | 0.159 | 2.49 | 84 | 1.59 | - | 81 | -0.100 | 12.77 | 0.03 |
| 38 | 5.795 | 0.153 | 2.49 | 84.3 | 1.57 | - | 81 | -0.097 | 10.27 | 0.07 |
| 39 | 5.952 | 0.157 | 2.48 | 84.6 | 2.08 | - | 81 | -0.097 | 9.52 | 0.09 |
| 40 | 6.106 | 0.154 | 2.49 | 84.9 | 1.85 | 103 | 81 | -0.099 | 12.37 | 0.06 |
| 41 | 6.263 | 0.157 | 2.48 | 85.2 | 2.06 | - | 81 | -0.099 | 10.90 | 0.05 |
| 42 | 6.419 | 0.156 | 2.48 | 85.5 | 1.7 | - | 81 | -0.096 | 11.53 | 0.05 |
| 43 | 6.573 | 0.154 | 2.48 | 85.9 | 1.9 | - | 81 | -0.100 | 13.80 | 0.07 |
| 44 | 6.732 | 0.159 | 2.49 | 86.1 | 1.86 | - | 81 | -0.098 | 11.58 | 0.05 |
| 45 | 6.886 | 0.154 | 2.50 | 86.4 | 1.66 | - | 81 | -0.099 | 10.71 | 0.07 |
| 46 | 7.043 | 0.157 | 2.49 | 86.7 | 2.11 | - | 81 | -0.098 | 10.93 | 0.07 |
| 47 | 7.199 | 0.156 | 2.49 | 87 | 1.59 | - | 81 | -0.103 | 12.00 | 0.04 |
| 48 | 7.356 | 0.157 | 2.50 | 87.3 | 2.01 | - | 81 | -0.100 | 11.67 | 0.05 |
| 49 | 7.513 | 0.157 | 2.49 | 87.5 | 1.56 | - | 81 | -0.102 | 14.03 | 0.07 |
| 50 | 7.667 | 0.154 | 2.49 | 87.9 | 1.68 | 103 | 81 | -0.102 | 11.91 | 0.04 |
| 51 | 7.826 | 0.159 | 2.49 | 88.1 | 1.65 | - | 81 | -0.103 | 14.92 | 0.04 |
| 52 | 7.980 | 0.154 | 2.49 | 88.4 | 1.57 | - | 81 | -0.102 | 12.14 | 0.04 |
| 53 | 8.138 | 0.158 | 2.49 | 88.7 | 2.11 | - | 81 | -0.101 | 11.77 | 0.04 |
| 54 | 8.295 | 0.157 | 2.49 | 88.9 | 1.74 | - | 81 | -0.101 | 12.82 | 0.03 |
| 55 | 8.450 | 0.155 | 2.49 | 89.2 | 1.61 | - | 81 | -0.103 | 12.31 | 0.05 |
| 56 | 8.609 | 0.159 | 2.49 | 89.4 | 1.64 | - | 82 | -0.105 | 13.52 | 0.04 |
| 57 | 8.764 | 0.155 | 2.49 | 89.7 | 1.73 | - | 82 | -0.104 | 14.13 | 0.03 |
| 58 | 8.923 | 0.159 | 2.49 | 89.9 | 1.92 | - | 82 | -0.103 | 13.59 | 0.05 |
| 59 | 9.078 | 0.155 | 2.49 | 90.2 | 1.87 | - | 82 | -0.102 | 12.44 | 0.04 |
| 60 | 9.236 | 0.158 | 2.49 | 90.4 | 2.03 | 103 | 82 | -0.106 | 15.03 | 0.03 |
| 61 | 9.394 | 0.158 | 2.50 | 90.7 | 1.56 | - | 81 | -0.092 | 12.08 | 0.05 |
| 62 | 9.549 | 0.155 | 2.50 | 90.9 | 1.8 | - | 81 | -0.082 | 5.14 | 0.43 |
| 63 | 9.709 | 0.160 | 2.48 | 91.1 | 1.94 | - | 81 | -0.099 | 18.87 | 2.41 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 64 | 9.862 | 0.153 | 2.48 | 91.3 | 2.07 | - | 81 | -0.100 | 13.51 | 0.05 |
| 65 | 10.020 | 0.158 | 2.47 | 91.5 | 2.07 | - | 81 | -0.099 | 12.43 | 0.05 |
| 66 | 10.178 | 0.158 | 2.48 | 91.7 | 1.79 | - | 81 | -0.100 | 12.08 | 0.05 |
| 67 | 10.333 | 0.155 | 2.48 | 91.8 | 1.59 | - | 81 | -0.098 | 10.69 | 0.05 |
| 68 | 10.491 | 0.158 | 2.47 | 92 | 1.78 | - | 81 | -0.099 | 10.71 | 0.06 |
| 69 | 10.647 | 0.156 | 2.48 | 92.3 | 1.85 | - | 81 | -0.098 | 12.30 | 0.04 |
| 70 | 10.806 | 0.159 | 2.48 | 92.5 | 1.92 | 103 | 81 | -0.099 | 10.90 | 0.06 |
| 71 | 10.960 | 0.154 | 2.47 | 92.6 | 2 | - | 81 | -0.098 | 11.83 | 0.03 |
| 72 | 11.119 | 0.159 | 2.48 | 92.8 | 2.04 | - | 81 | -0.097 | 11.01 | 0.04 |
| 73 | 11.277 | 0.158 | 2.48 | 93 | 1.79 | - | 81 | -0.100 | 11.77 | 0.03 |
| 74 | 11.431 | 0.154 | 2.48 | 93.2 | 1.92 | - | 81 | -0.097 | 13.31 | 0.03 |
| 75 | 11.591 | 0.160 | 2.49 | 93.4 | 2.04 | - | 81 | -0.100 | 11.54 | 0.04 |
| 76 | 11.746 | 0.155 | 2.49 | 93.5 | 2 | - | 81 | -0.106 | 13.23 | 0.04 |
| 77 | 11.904 | 0.158 | 2.48 | 93.7 | 1.72 | - | 81 | -0.104 | 12.46 | 0.03 |
| 78 | 12.062 | 0.158 | 2.48 | 93.8 | 1.73 | - | 81 | -0.100 | 11.77 | 0.04 |
| 79 | 12.218 | 0.156 | 2.48 | 94 | 1.81 | - | 81 | -0.099 | 10.95 | 0.05 |
| 80 | 12.377 | 0.159 | 2.48 | 94.1 | 1.71 | 102 | 81 | -0.102 | 14.09 | 0.05 |
| 81 | 12.532 | 0.155 | 2.47 | 94.3 | 2.09 | - | 81 | -0.097 | 13.62 | 0.08 |
| 82 | 12.691 | 0.159 | 2.48 | 94.4 | 1.91 | - | 81 | -0.096 | 11.62 | 0.05 |
| 83 | 12.846 | 0.155 | 2.48 | 94.5 | 1.76 | - | 81 | -0.100 | 11.69 | 0.05 |
| 84 | 13.005 | 0.159 | 2.47 | 94.7 | 1.82 | - | 81 | -0.097 | 13.06 | 0.03 |
| 85 | 13.162 | 0.157 | 2.48 | 94.8 | 2.14 | - | 81 | -0.098 | 11.85 | 0.06 |
| 86 | 13.318 | 0.156 | 2.48 | 95 | 1.95 | - | 81 | -0.098 | 10.28 | 0.08 |
| 87 | 13.478 | 0.160 | 2.47 | 95.1 | 2.1 | - | 81 | -0.095 | 9.78 | 0.06 |
| 88 | 13.632 | 0.154 | 2.48 | 95.2 | 1.79 | - | 81 | -0.097 | 11.35 | 0.04 |
| 89 | 13.791 | 0.159 | 2.47 | 95.3 | 1.98 | - | 81 | -0.098 | 10.84 | 0.05 |
| 90 | 13.950 | 0.159 | 2.48 | 95.4 | 1.64 | 102 | 81 | -0.097 | 11.62 | 0.05 |
| 91 | 14.105 | 0.155 | 2.48 | 95.5 | 1.96 | - | 81 | -0.095 | 9.81 | 0.05 |
| 92 | 14.264 | 0.159 | 2.48 | 95.6 | 1.88 | - | 81 | -0.093 | 8.02 | 0.12 |
| 93 | 14.420 | 0.156 | 2.48 | 95.8 | 2.14 | - | 81 | -0.091 | 8.98 | 0.11 |
| 94 | 14.578 | 0.158 | 2.48 | 95.9 | 1.58 | - | 81 | -0.096 | 10.83 | 0.06 |
| 95 | 14.736 | 0.158 | 2.48 | 95.9 | 1.9 | - | 81 | -0.094 | 11.39 | 0.05 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 96 | 14.893 | 0.157 | 2.48 | 96 | 1.67 | - | 81 | -0.097 | 11.26 | 0.03 |
| 97 | 15.051 | 0.158 | 2.47 | 96.2 | 1.95 | - | 81 | -0.093 | 9.41 | 0.05 |
| 98 | 15.207 | 0.156 | 2.48 | 96.3 | 2.09 | - | 81 | -0.095 | 9.92 | 0.06 |
| 99 | 15.367 | 0.160 | 2.48 | 96.4 | 2.13 | - | 81 | -0.095 | 8.92 | 0.09 |
| 100 | 15.522 | 0.155 | 2.48 | 96.4 | 1.6 | 102 | 80 | -0.094 | 9.28 | 0.08 |
| 101 | 15.681 | 0.159 | 2.48 | 96.6 | 1.67 | - | 80 | -0.095 | 8.53 | 0.10 |
| 102 | 15.840 | 0.159 | 2.48 | 96.6 | 1.97 | - | 81 | -0.094 | 10.60 | 0.06 |
| 103 | 15.996 | 0.156 | 2.48 | 96.8 | 1.96 | - | 81 | -0.094 | 9.66 | 0.07 |
| 104 | 16.156 | 0.160 | 2.48 | 96.8 | 1.61 | - | 81 | -0.094 | 10.34 | 0.06 |
| 105 | 16.311 | 0.155 | 2.48 | 97 | 1.63 | - | 81 | -0.098 | 13.10 | 0.04 |
| 106 | 16.470 | 0.159 | 2.47 | 97 | 1.87 | - | 81 | -0.099 | 12.41 | 0.04 |
| 107 | 16.628 | 0.158 | 2.48 | 97.1 | 1.78 | - | 81 | -0.101 | 12.95 | 0.03 |
| 108 | 16.783 | 0.155 | 2.47 | 97.1 | 1.63 | - | 81 | -0.099 | 12.95 | 0.03 |
| 109 | 16.944 | 0.161 | 2.48 | 97.2 | 1.92 | - | 81 | -0.100 | 13.41 | 0.05 |
| 110 | 17.099 | 0.155 | 2.48 | 97.3 | 1.64 | 102 | 81 | -0.099 | 12.91 | 0.05 |
| 111 | 17.258 | 0.159 | 2.48 | 97.4 | 1.61 | - | 81 | -0.099 | 11.17 | 0.05 |
| 112 | 17.417 | 0.159 | 2.47 | 97.4 | 1.62 | - | 81 | -0.099 | 10.33 | 0.05 |
| 113 | 17.573 | 0.156 | 2.48 | 97.6 | 1.6 | - | 81 | -0.097 | 12.83 | 0.06 |
| 114 | 17.733 | 0.160 | 2.47 | 97.5 | 1.89 | - | 81 | -0.101 | 12.57 | 0.06 |
| 115 | 17.889 | 0.156 | 2.47 | 97.6 | 2.1 | - | 81 | -0.100 | 13.82 | 0.05 |
| 116 | 18.047 | 0.158 | 2.47 | 97.7 | 1.92 | - | 81 | -0.100 | 13.16 | 0.05 |
| 117 | 18.204 | 0.157 | 2.47 | 97.8 | 2.05 | - | 81 | -0.101 | 13.04 | 0.05 |
| 118 | 18.362 | 0.158 | 2.47 | 97.8 | 2.14 | - | 81 | -0.101 | 11.43 | 0.05 |
| 119 | 18.520 | 0.158 | 2.47 | 98 | 1.77 | - | 81 | -0.098 | 10.52 | 0.06 |
| 120 | 18.676 | 0.156 | 2.47 | 98 | 1.91 | 101 | 81 | -0.096 | 9.86 | 0.08 |
| 121 | 18.836 | 0.160 | 2.47 | 98.1 | 1.72 | - | 81 | -0.098 | 13.58 | 0.06 |
| 122 | 18.991 | 0.155 | 2.46 | 98.2 | 1.66 | - | 81 | -0.100 | 13.02 | 0.04 |
| 123 | 19.150 | 0.159 | 2.47 | 98.2 | 1.61 | - | 81 | -0.094 | 10.06 | 0.07 |
| 124 | 19.308 | 0.158 | 2.47 | 98.3 | 1.92 | - | 81 | -0.094 | 10.31 | 0.05 |
| 125 | 19.463 | 0.155 | 2.47 | 98.2 | 1.87 | - | 81 | -0.097 | 10.93 | 0.06 |
| 126 | 19.624 | 0.161 | 2.46 | 98.3 | 2.14 | - | 81 | -0.096 | 10.45 | 0.05 |
| 127 | 19.779 | 0.155 | 2.46 | 98.4 | 1.99 | - | 81 | -0.097 | 11.05 | 0.05 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 128 | 19.938 | 0.159 | 2.47 | 98.4 | 1.69 | - | 81 | -0.097 | 11.52 | 0.04 |
| 129 | 20.097 | 0.159 | 2.47 | 98.5 | 1.62 | - | 81 | -0.096 | 10.96 | 0.06 |
| 130 | 20.252 | 0.155 | 2.46 | 98.6 | 2.08 | 101 | 82 | -0.101 | 11.95 | 0.04 |
| 131 | 20.412 | 0.160 | 2.46 | 98.6 | 1.67 | - | 82 | -0.097 | 10.33 | 0.07 |
| 132 | 20.567 | 0.155 | 2.47 | 98.7 | 1.66 | - | 82 | -0.095 | 9.06 | 0.08 |
| 133 | 20.725 | 0.158 | 2.46 | 98.8 | 1.78 | - | 82 | -0.092 | 8.23 | 0.07 |
| 134 | 20.884 | 0.159 | 2.46 | 98.8 | 1.66 | - | 82 | -0.090 | 7.67 | 0.08 |
| 135 | 21.040 | 0.156 | 2.46 | 98.8 | 1.92 | - | 81 | -0.093 | 9.37 | 0.06 |
| 136 | 21.199 | 0.159 | 2.46 | 98.9 | 1.65 | - | 81 | -0.095 | 10.82 | 0.03 |
| 137 | 21.355 | 0.156 | 2.45 | 98.9 | 1.72 | - | 81 | -0.092 | 8.91 | 0.07 |
| 138 | 21.514 | 0.159 | 2.46 | 99 | 1.73 | - | 81 | -0.092 | 9.52 | 0.05 |
| 139 | 21.671 | 0.157 | 2.46 | 99 | 1.69 | - | 81 | -0.092 | 8.84 | 0.09 |
| 140 | 21.830 | 0.159 | 2.46 | 99 | 1.8 | 102 | 81 | -0.093 | 10.16 | 0.09 |
| 141 | 21.988 | 0.158 | 2.46 | 99 | 2.05 | - | 81 | -0.094 | 9.11 | 0.07 |
| 142 | 22.144 | 0.156 | 2.46 | 99.1 | 1.8 | - | 81 | -0.096 | 9.83 | 0.05 |
| 143 | 22.304 | 0.160 | 2.46 | 99.2 | 1.8 | - | 81 | -0.097 | 10.25 | 0.05 |
| 144 | 22.459 | 0.155 | 2.46 | 99.2 | 2.13 | - | 81 | -0.095 | 11.47 | 0.06 |
| 145 | 22.618 | 0.159 | 2.45 | 99.2 | 1.75 | - | 81 | -0.096 | 13.75 | 0.11 |
| 146 | 22.776 | 0.158 | 2.46 | 99.3 | 1.68 | - | 81 | -0.097 | 11.09 | 0.06 |
| 147 | 22.931 | 0.155 | 2.45 | 99.3 | 1.68 | - | 81 | -0.094 | 11.47 | 0.07 |
| 148 | 23.092 | 0.161 | 2.45 | 99.4 | 1.92 | - | 81 | -0.097 | 9.56 | 0.07 |
| 149 | 23.246 | 0.154 | 2.45 | 99.4 | 1.67 | - | 81 | -0.090 | 11.04 | 0.09 |
| 150 | 23.405 | 0.159 | 2.45 | 99.4 | 1.72 | 101 | 81 | -0.096 | 10.68 | 0.05 |
| 151 | 23.563 | 0.158 | 2.45 | 99.5 | 1.75 | - | 81 | -0.094 | 10.18 | 0.05 |
| 152 | 23.719 | 0.156 | 2.45 | 99.6 | 2.09 | - | 81 | -0.090 | 9.25 | 0.07 |
| 153 | 23.879 | 0.160 | 2.45 | 99.5 | 1.64 | - | 81 | -0.084 | 7.04 | 0.11 |
| 154 | 24.034 | 0.155 | 2.45 | 99.6 | 1.68 | - | 81 | -0.082 | 6.47 | 0.12 |
| 155 | 24.193 | 0.159 | 2.46 | 99.6 | 1.87 | - | 81 | -0.081 | 6.40 | 0.12 |
| 156 | 24.350 | 0.157 | 2.45 | 99.6 | 1.88 | - | 81 | -0.088 | 9.00 | 0.09 |
| 157 | 24.508 | 0.158 | 2.45 | 99.6 | 1.84 | - | 81 | -0.090 | 7.18 | 0.13 |
| 158 | 24.666 | 0.158 | 2.45 | 99.6 | 2.17 | - | 81 | -0.088 | 8.87 | 0.08 |
| 159 | 24.822 | 0.156 | 2.45 | 99.8 | 1.59 | - | 81 | -0.090 | 10.57 | 0.07 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 160 | 24.982 | 0.160 | 2.46 | 99.8 | 1.6 | 100 | 81 | -0.091 | 9.56 | 0.06 |
| 161 | 25.137 | 0.155 | 2.45 | 99.8 | 1.6 | - | 81 | -0.094 | 10.67 | 0.06 |
| 162 | 25.296 | 0.159 | 2.45 | 99.8 | 2.14 | - | 81 | -0.093 | 9.84 | 0.10 |
| 163 | 25.454 | 0.158 | 2.45 | 99.8 | 1.87 | - | 81 | -0.096 | 13.32 | 0.04 |
| 164 | 25.609 | 0.155 | 2.45 | 99.8 | 1.61 | - | 81 | -0.089 | 9.23 | 0.07 |
| 165 | 25.770 | 0.161 | 2.45 | 99.9 | 2.16 | - | 81 | -0.089 | 7.76 | 0.11 |
| 166 | 25.924 | 0.154 | 2.45 | 99.8 | 1.78 | - | 81 | -0.092 | 8.74 | 0.07 |
| 167 | 26.084 | 0.160 | 2.45 | 99.9 | 1.72 | - | 81 | -0.089 | 8.15 | 0.09 |
| 168 | 26.242 | 0.158 | 2.45 | 99.9 | 1.88 | - | 81 | -0.092 | 9.13 | 0.07 |
| 169 | 26.398 | 0.156 | 2.45 | 99.9 | 2.09 | - | 81 | -0.095 | 8.45 | 0.08 |
| 170 | 26.557 | 0.159 | 2.45 | 99.9 | 1.64 | 100 | 81 | -0.094 | 9.69 | 0.06 |
| 171 | 26.713 | 0.156 | 2.45 | 100 | 1.6 | - | 81 | -0.097 | 10.42 | 0.04 |
| 172 | 26.871 | 0.158 | 2.45 | 100 | 1.92 | - | 81 | -0.092 | 9.77 | 0.05 |
| 173 | 27.029 | 0.158 | 2.45 | 100.1 | 1.67 | - | 81 | -0.091 | 8.77 | 0.06 |
| 174 | 27.186 | 0.157 | 2.46 | 100 | 1.8 | - | 81 | -0.093 | 9.53 | 0.05 |
| 175 | 27.344 | 0.158 | 2.44 | 100.2 | 1.92 | - | 81 | -0.091 | 9.65 | 0.07 |
| 176 | 27.500 | 0.156 | 2.45 | 100.1 | 1.66 | - | 81 | -0.089 | 8.27 | 0.11 |
| 177 | 27.659 | 0.159 | 2.45 | 100.2 | 1.61 | - | 81 | -0.089 | 9.12 | 0.08 |
| 178 | 27.815 | 0.156 | 2.45 | 100.2 | 1.73 | - | 81 | -0.092 | 9.05 | 0.09 |
| 179 | 27.974 | 0.159 | 2.44 | 100.3 | 1.82 | - | 81 | -0.092 | 8.27 | 0.10 |
| 180 | 28.132 | 0.158 | 2.45 | 100.3 | 1.74 | 100 | 81 | -0.090 | 10.79 | 0.06 |
| 181 | 28.288 | 0.156 | 2.45 | 100.3 | 1.94 | - | 81 | -0.087 | 9.78 | 0.07 |
| 182 | 28.448 | 0.160 | 2.44 | 100.3 | 1.67 | - | 81 | -0.085 | 8.42 | 0.09 |
| 183 | 28.603 | 0.155 | 2.45 | 100.3 | 1.73 | - | 81 | -0.087 | 8.59 | 0.10 |
| 184 | 28.762 | 0.159 | 2.44 | 100.3 | 1.7 | - | 81 | -0.087 | 10.21 | 0.07 |
| 185 | 28.920 | 0.158 | 2.45 | 100.3 | 1.91 | - | 81 | -0.089 | 9.33 | 0.06 |
| 186 | 29.075 | 0.155 | 2.45 | 100.4 | 2.1 | - | 81 | -0.084 | 8.54 | 0.06 |
| 187 | 29.235 | 0.160 | 2.44 | 100.4 | 1.79 | - | 81 | -0.083 | 6.88 | 0.08 |
| 188 | 29.390 | 0.155 | 2.45 | 100.5 | 1.83 | - | 81 | -0.081 | 6.70 | 0.08 |
| 189 | 29.549 | 0.159 | 2.44 | 100.5 | 1.67 | - | 81 | -0.082 | 6.50 | 0.09 |
| 190 | 29.707 | 0.158 | 2.45 | 100.5 | 1.8 | 100 | 81 | -0.078 | 7.11 | 0.09 |
| 191 | 29.863 | 0.156 | 2.45 | 100.5 | 2.18 | - | 81 | -0.076 | 6.67 | 0.12 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 192 | 30.022 | 0.159 | 2.44 | 100.6 | 1.86 | - | 81 | -0.079 | 6.51 | 0.10 |
| 193 | 30.178 | 0.156 | 2.44 | 100.6 | 2.18 | - | 80 | -0.081 | 6.97 | 0.09 |
| 194 | 30.337 | 0.159 | 2.45 | 100.6 | 1.6 | - | 80 | -0.082 | 6.37 | 0.09 |
| 195 | 30.493 | 0.156 | 2.45 | 100.6 | 1.95 | - | 80 | -0.083 | 7.51 | 0.08 |
| 196 | 30.652 | 0.159 | 2.44 | 100.6 | 1.91 | - | 80 | -0.082 | 6.62 | 0.10 |
| 197 | 30.810 | 0.158 | 2.45 | 100.8 | 2.17 | - | 80 | -0.077 | 6.29 | 0.10 |
| 198 | 30.966 | 0.156 | 2.45 | 100.7 | 1.63 | - | 80 | -0.082 | 5.77 | 0.13 |
| 199 | 31.127 | 0.161 | 2.45 | 100.7 | 1.62 | - | 80 | -0.086 | 8.59 | 0.11 |
| 200 | 31.281 | 0.154 | 2.45 | 100.7 | 1.69 | 99 | 80 | -0.086 | 10.83 | 0.06 |
| 201 | 31.440 | 0.159 | 2.45 | 100.8 | 1.96 | - | 80 | -0.085 | 9.40 | 0.07 |
| 202 | 31.599 | 0.159 | 2.45 | 100.7 | 1.69 | - | 80 | -0.085 | 8.76 | 0.07 |
| 203 | 31.754 | 0.155 | 2.44 | 100.7 | 1.85 | - | 80 | -0.083 | 7.19 | 0.09 |
| 204 | 31.762 | 0.008 | 0.02 | 97.6 | 0.74 | - | 76 | -0.086 | 8.24 | 0.08 |
| 205 | 31.867 | 0.105 | 2.47 | 96.9 | 1.87 | - | 77 | -0.083 | 7.75 | 0.10 |
| 206 | 32.026 | 0.159 | 2.46 | 96.5 | 2.04 | - | 77 | -0.083 | 7.34 | 0.10 |
| 207 | 32.186 | 0.160 | 2.46 | 96.2 | 1.83 | - | 78 | -0.077 | 5.68 | 0.13 |
| 208 | 32.340 | 0.154 | 2.45 | 96 | 1.81 | - | 78 | -0.075 | 5.32 | 0.11 |
| 209 | 32.500 | 0.160 | 2.45 | 95.8 | 2.15 | - | 78 | -0.078 | 7.06 | 0.11 |
| 210 | 32.654 | 0.154 | 2.45 | 95.7 | 1.62 | 86 | 78 | -0.082 | 7.38 | 0.10 |
| 211 | 32.812 | 0.158 | 2.45 | 95.6 | 1.62 | - | 78 | -0.080 | 6.64 | 0.13 |
| 212 | 32.968 | 0.156 | 2.44 | 95.5 | 2.17 | - | 79 | -0.079 | 6.38 | 0.10 |
| 213 | 33.122 | 0.154 | 2.43 | 95.5 | 2.19 | - | 79 | -0.078 | 5.84 | 0.11 |
| 214 | 33.279 | 0.157 | 2.44 | 95.4 | 2.18 | - | 79 | -0.074 | 5.31 | 0.12 |
| 215 | 33.433 | 0.154 | 2.43 | 95.4 | 2.01 | - | 79 | -0.075 | 4.69 | 0.14 |
| 216 | 33.592 | 0.159 | 2.44 | 95.3 | 1.6 | - | 79 | -0.084 | 7.66 | 0.09 |
| 217 | 33.746 | 0.154 | 2.44 | 95.4 | 2.2 | - | 79 | -0.078 | 6.88 | 0.12 |
| 218 | 33.906 | 0.160 | 2.43 | 95.3 | 1.72 | - | 79 | -0.079 | 6.97 | 0.09 |
| 219 | 34.063 | 0.157 | 2.44 | 95.4 | 1.98 | - | 79 | -0.075 | 6.61 | 0.09 |
| 220 | 34.218 | 0.155 | 2.44 | 95.4 | 1.64 | 99 | 79 | -0.082 | 6.08 | 0.10 |
| 221 | 34.375 | 0.157 | 2.43 | 95.4 | 1.94 | - | 79 | -0.084 | 8.07 | 0.07 |
| 222 | 34.530 | 0.155 | 2.43 | 95.4 | 2.09 | - | 79 | -0.088 | 10.98 | 0.06 |
| 223 | 34.689 | 0.159 | 2.44 | 95.5 | 1.68 | - | 79 | -0.083 | 8.33 | 0.08 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 224 | 34.842 | 0.153 | 2.43 | 95.5 | 2.05 | - | 79 | -0.091 | 9.57 | 0.09 |
| 225 | 35.000 | 0.158 | 2.43 | 95.7 | 1.7 | - | 79 | -0.085 | 9.76 | 0.06 |
| 226 | 35.154 | 0.154 | 2.43 | 95.6 | 1.79 | - | 79 | -0.084 | 7.38 | 0.14 |
| 227 | 35.309 | 0.155 | 2.44 | 95.7 | 1.8 | - | 79 | -0.080 | 7.30 | 0.10 |
| 228 | 35.466 | 0.157 | 2.43 | 95.8 | 1.82 | - | 79 | -0.079 | 6.45 | 0.10 |
| 229 | 35.621 | 0.155 | 2.44 | 95.8 | 1.61 | - | 79 | -0.079 | 6.11 | 0.09 |
| 230 | 35.780 | 0.159 | 2.44 | 95.9 | 1.61 | 99 | 79 | -0.074 | 5.55 | 0.08 |
| 231 | 35.934 | 0.154 | 2.43 | 96 | 1.66 | - | 79 | -0.074 | 5.61 | 0.07 |
| 232 | 36.094 | 0.160 | 2.43 | 96.1 | 1.67 | - | 79 | -0.075 | 6.84 | 0.12 |
| 233 | 36.251 | 0.157 | 2.43 | 96.1 | 1.62 | - | 79 | -0.082 | 7.28 | 0.09 |
| 234 | 36.405 | 0.154 | 2.43 | 96.2 | 1.89 | - | 80 | -0.079 | 6.40 | 0.11 |
| 235 | 36.564 | 0.159 | 2.43 | 96.3 | 2.14 | - | 79 | -0.076 | 6.20 | 0.09 |
| 236 | 36.719 | 0.155 | 2.44 | 96.4 | 1.74 | - | 79 | -0.075 | 5.57 | 0.09 |
| 237 | 36.876 | 0.157 | 2.43 | 96.5 | 2.15 | - | 79 | -0.081 | 5.30 | 0.09 |
| 238 | 37.032 | 0.156 | 2.43 | 96.6 | 1.62 | - | 79 | -0.083 | 7.55 | 0.08 |
| 239 | 37.186 | 0.154 | 2.43 | 96.7 | 1.9 | - | 80 | -0.083 | 7.51 | 0.11 |
| 240 | 37.346 | 0.160 | 2.44 | 96.8 | 1.64 | 100 | 80 | -0.087 | 7.92 | 0.08 |
| 241 | 37.500 | 0.154 | 2.43 | 96.9 | 1.87 | - | 80 | -0.085 | 7.50 | 0.09 |
| 242 | 37.660 | 0.160 | 2.43 | 97 | 1.91 | - | 80 | -0.082 | 7.53 | 0.09 |
| 243 | 37.811 | 0.151 | 2.44 | 97 | 2.08 | - | 80 | -0.081 | 6.49 | 0.11 |
| 244 | 37.968 | 0.157 | 2.43 | 97.2 | 1.88 | - | 80 | -0.079 | 6.22 | 0.08 |
| 245 | 38.126 | 0.158 | 2.43 | 97.2 | 1.94 | - | 80 | -0.081 | 7.77 | 0.08 |
| 246 | 38.282 | 0.156 | 2.44 | 97.3 | 1.71 | - | 80 | -0.075 | 7.14 | 0.12 |
| 247 | 38.439 | 0.157 | 2.43 | 97.4 | 2.09 | - | 80 | -0.080 | 7.59 | 0.12 |
| 248 | 38.594 | 0.155 | 2.43 | 97.4 | 1.66 | - | 80 | -0.078 | 7.21 | 0.11 |
| 249 | 38.755 | 0.161 | 2.44 | 97.5 | 1.81 | - | 80 | -0.074 | 6.20 | 0.12 |
| 250 | 38.909 | 0.154 | 2.43 | 97.6 | 1.78 | 99 | 79 | -0.075 | 5.22 | 0.14 |
| 251 | 39.067 | 0.158 | 2.43 | 97.7 | 1.63 | - | 79 | -0.075 | 5.68 | 0.10 |
| 252 | 39.225 | 0.158 | 2.43 | 97.7 | 1.83 | - | 79 | -0.077 | 5.60 | 0.10 |
| 253 | 39.379 | 0.154 | 2.44 | 97.9 | 1.82 | - | 79 | -0.073 | 5.91 | 0.12 |
| 254 | 39.538 | 0.159 | 2.44 | 97.9 | 1.67 | - | 79 | -0.070 | 5.59 | 0.15 |
| 255 | 39.693 | 0.155 | 2.44 | 98 | 1.78 | - | 79 | -0.073 | 6.18 | 0.14 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 256 | 39.848 | 0.155 | 2.44 | 98.1 | 1.71 | - | 79 | -0.068 | 6.06 | 0.15 |
| 257 | 40.004 | 0.156 | 2.44 | 98.1 | 2.02 | - | 79 | -0.072 | 5.87 | 0.12 |
| 258 | 40.162 | 0.158 | 2.43 | 98.3 | 1.95 | - | 79 | -0.074 | 5.52 | 0.11 |
| 259 | 40.319 | 0.157 | 2.44 | 98.3 | 1.87 | - | 79 | -0.073 | 7.33 | 0.12 |
| 260 | 40.474 | 0.155 | 2.44 | 98.3 | 1.61 | 99 | 79 | -0.073 | 6.78 | 0.14 |
| 261 | 40.634 | 0.160 | 2.43 | 98.5 | 1.9 | - | 79 | -0.075 | 6.04 | 0.14 |
| 262 | 40.791 | 0.157 | 2.44 | 98.5 | 1.61 | - | 79 | -0.081 | 8.02 | 0.11 |
| 263 | 40.949 | 0.158 | 2.44 | 98.6 | 1.63 | - | 79 | -0.078 | 7.17 | 0.11 |
| 264 | 41.107 | 0.158 | 2.44 | 98.7 | 1.76 | - | 79 | -0.082 | 6.63 | 0.10 |
| 265 | 41.262 | 0.155 | 2.44 | 98.7 | 2 | - | 79 | -0.080 | 6.75 | 0.10 |
| 266 | 41.421 | 0.159 | 2.44 | 98.8 | 1.74 | - | 79 | -0.079 | 6.48 | 0.11 |
| 267 | 41.576 | 0.155 | 2.44 | 98.9 | 1.69 | - | 79 | -0.079 | 8.50 | 0.06 |
| 268 | 41.734 | 0.158 | 2.44 | 98.9 | 2.13 | - | 79 | -0.075 | 7.17 | 0.13 |
| 269 | 41.890 | 0.156 | 2.43 | 99 | 1.98 | - | 79 | -0.076 | 6.70 | 0.12 |
| 270 | 42.045 | 0.155 | 2.43 | 99.1 | 2.2 | 98 | 79 | -0.081 | 6.92 | 0.10 |
| 271 | 42.202 | 0.157 | 2.44 | 99.1 | 1.68 | - | 79 | -0.075 | 6.17 | 0.09 |
| 272 | 42.357 | 0.155 | 2.44 | 99.2 | 1.71 | - | 79 | -0.071 | 5.47 | 0.13 |
| 273 | 42.518 | 0.161 | 2.43 | 99.3 | 1.77 | - | 79 | -0.072 | 5.42 | 0.10 |
| 274 | 42.672 | 0.154 | 2.44 | 99.2 | 2.17 | - | 79 | -0.077 | 5.79 | 0.11 |
| 275 | 42.830 | 0.158 | 2.44 | 99.3 | 2.04 | - | 79 | -0.076 | 6.40 | 0.13 |
| 276 | 42.991 | 0.161 | 2.44 | 99.3 | 2.05 | - | 79 | -0.078 | 7.10 | 0.13 |
| 277 | 43.146 | 0.155 | 2.44 | 99.4 | 2.05 | - | 79 | -0.081 | 6.35 | 0.10 |
| 278 | 43.306 | 0.160 | 2.44 | 99.5 | 1.78 | - | 79 | -0.083 | 7.81 | 0.08 |
| 279 | 43.461 | 0.155 | 2.44 | 99.6 | 2.13 | - | 79 | -0.076 | 6.18 | 0.13 |
| 280 | 43.619 | 0.158 | 2.44 | 99.6 | 1.78 | 98 | 79 | -0.072 | 5.38 | 0.11 |
| 281 | 43.776 | 0.157 | 2.44 | 99.6 | 2.11 | - | 79 | -0.071 | 6.21 | 0.10 |
| 282 | 43.933 | 0.157 | 2.45 | 99.7 | 1.76 | - | 79 | -0.074 | 6.47 | 0.15 |
| 283 | 44.089 | 0.156 | 2.44 | 99.7 | 1.61 | - | 79 | -0.074 | 6.71 | 0.13 |
| 284 | 44.244 | 0.155 | 2.44 | 99.7 | 1.61 | - | 79 | -0.073 | 6.88 | 0.09 |
| 285 | 44.404 | 0.160 | 2.44 | 99.8 | 1.6 | - | 79 | -0.072 | 5.52 | 0.12 |
| 286 | 44.558 | 0.154 | 2.44 | 99.8 | 2.17 | - | 79 | -0.071 | 5.24 | 0.11 |
| 287 | 44.716 | 0.158 | 2.43 | 99.9 | 2.05 | - | 79 | -0.068 | 5.71 | 0.13 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 288 | 44.877 | 0.161 | 2.44 | 99.9 | 1.92 | - | 79 | -0.077 | 6.84 | 0.10 |
| 289 | 45.031 | 0.154 | 2.43 | 100 | 1.63 | - | 79 | -0.076 | 6.74 | 0.13 |
| 290 | 45.192 | 0.161 | 2.44 | 100 | 2.06 | 98 | 79 | -0.078 | 6.79 | 0.13 |
| 291 | 45.346 | 0.154 | 2.44 | 100.1 | 2.1 | - | 79 | -0.078 | 5.85 | 0.13 |
| 292 | 45.504 | 0.158 | 2.43 | 100.1 | 2.16 | - | 79 | -0.079 | 5.48 | 0.12 |
| 293 | 45.662 | 0.158 | 2.44 | 100.2 | 2.16 | - | 79 | -0.075 | 6.58 | 0.10 |
| 294 | 45.818 | 0.156 | 2.44 | 100.1 | 1.89 | - | 79 | -0.073 | 5.64 | 0.15 |
| 295 | 45.974 | 0.156 | 2.44 | 100.3 | 2.16 | - | 79 | -0.073 | 5.02 | 0.14 |
| 296 | 46.130 | 0.156 | 2.44 | 100.3 | 1.76 | - | 79 | -0.069 | 4.73 | 0.14 |
| 297 | 46.292 | 0.162 | 2.44 | 100.3 | 1.78 | - | 79 | -0.073 | 5.46 | 0.16 |
| 298 | 46.444 | 0.152 | 2.43 | 100.4 | 2.03 | - | 79 | -0.076 | 6.63 | 0.09 |
| 299 | 46.603 | 0.159 | 2.44 | 100.4 | 1.8 | - | 79 | -0.073 | 6.67 | 0.10 |
| 300 | 46.761 | 0.158 | 2.44 | 100.4 | 1.89 | 98 | 79 | -0.074 | 6.36 | 0.11 |
| 301 | 46.916 | 0.155 | 2.43 | 100.5 | 1.74 | - | 79 | -0.076 | 5.55 | 0.17 |
| 302 | 47.076 | 0.160 | 2.44 | 100.5 | 1.91 | - | 79 | -0.076 | 6.36 | 0.12 |
| 303 | 47.231 | 0.155 | 2.43 | 100.6 | 1.77 | - | 79 | -0.077 | 6.35 | 0.12 |
| 304 | 47.392 | 0.161 | 2.43 | 100.6 | 1.7 | - | 79 | -0.077 | 6.18 | 0.12 |
| 305 | 47.551 | 0.159 | 2.43 | 100.6 | 1.7 | - | 79 | -0.076 | 5.75 | 0.12 |
| 306 | 47.706 | 0.155 | 2.44 | 100.6 | 1.71 | - | 79 | -0.072 | 4.78 | 0.14 |
| 307 | 47.865 | 0.159 | 2.44 | 100.7 | 2.1 | - | 79 | -0.071 | 4.47 | 0.11 |
| 308 | 48.018 | 0.153 | 2.43 | 100.7 | 2.16 | - | 79 | -0.072 | 4.55 | 0.09 |
| 309 | 48.177 | 0.159 | 2.45 | 100.8 | 1.65 | - | 79 | -0.074 | 7.18 | 0.09 |
| 310 | 48.333 | 0.156 | 2.44 | 100.7 | 1.8 | 98 | 79 | -0.074 | 6.83 | 0.13 |
| 311 | 48.491 | 0.158 | 2.44 | 100.7 | 1.63 | - | 79 | -0.080 | 6.93 | 0.12 |
| 312 | 48.649 | 0.158 | 2.44 | 100.8 | 1.9 | - | 79 | -0.085 | 7.57 | 0.11 |
| 313 | 48.807 | 0.158 | 2.44 | 100.9 | 1.63 | - | 79 | -0.085 | 9.82 | 0.07 |
| 314 | 48.967 | 0.160 | 2.44 | 100.8 | 1.76 | - | 79 | -0.083 | 9.14 | 0.08 |
| 315 | 49.121 | 0.154 | 2.43 | 100.9 | 2.14 | - | 79 | -0.078 | 6.50 | 0.13 |
| 316 | 49.280 | 0.159 | 2.43 | 100.9 | 2.05 | - | 79 | -0.074 | 5.85 | 0.13 |
| 317 | 49.438 | 0.158 | 2.44 | 100.9 | 2.17 | - | 79 | -0.072 | 5.46 | 0.15 |
| 318 | 49.593 | 0.155 | 2.43 | 101 | 1.84 | - | 79 | -0.074 | 6.58 | 0.13 |
| 319 | 49.751 | 0.158 | 2.44 | 101 | 2.04 | - | 79 | -0.076 | 6.66 | 0.15 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 1Technician: AKDate: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 320 | 49.906 | 0.155 | 2.44 | 101.1 | 2 | 98 | 79 | -0.074 | 6.03 | 0.17 |
| 321 | 50.064 | 0.158 | 2.43 | 101.1 | 2.21 | - | 79 | -0.075 | 6.82 | 0.19 |
| 322 | 50.222 | 0.158 | 2.44 | 101.1 | 2.18 | - | 79 | -0.074 | 6.12 | 0.17 |
| 323 | 50.381 | 0.159 | 2.44 | 101 | 1.94 | - | 79 | -0.074 | 5.94 | 0.16 |
| 324 | 50.541 | 0.160 | 2.44 | 101.1 | 2.11 | - | 79 | -0.077 | 5.48 | 0.16 |
| 325 | 50.696 | 0.155 | 2.44 | 101 | 2.16 | - | 79 | -0.076 | 6.53 | 0.13 |
| 326 | 50.855 | 0.159 | 2.44 | 101.1 | 2.19 | - | 79 | -0.075 | 6.06 | 0.11 |
| 327 | 51.011 | 0.156 | 2.44 | 101.2 | 1.61 | - | 79 | -0.071 | 5.74 | 0.15 |
| 328 | 51.167 | 0.156 | 2.44 | 101.1 | 1.62 | - | 79 | -0.073 | 5.68 | 0.12 |
| 329 | 51.325 | 0.158 | 2.44 | 101.2 | 2.06 | - | 79 | -0.083 | 8.37 | 0.10 |
| 330 | 51.480 | 0.155 | 2.43 | 101.2 | 2.19 | 98 | 79 | -0.082 | 8.22 | 0.11 |
| 331 | 51.643 | 0.163 | 2.44 | 101.2 | 2.04 | - | 79 | -0.083 | 6.88 | 0.10 |
| 332 | 51.797 | 0.154 | 2.43 | 101.2 | 2.01 | - | 79 | -0.078 | 6.42 | 0.14 |
| 333 | 51.956 | 0.159 | 2.43 | 101.2 | 2.19 | - | 80 | -0.077 | 5.87 | 0.17 |
| 334 | 52.114 | 0.158 | 2.44 | 101.2 | 1.7 | - | 80 | -0.079 | 7.29 | 0.09 |
| 335 | 52.267 | 0.153 | 2.44 | 101.2 | 1.64 | - | 80 | -0.080 | 7.86 | 0.10 |
| 336 | 52.427 | 0.160 | 2.44 | 101.3 | 2.2 | - | 80 | -0.081 | 7.48 | 0.13 |
| 337 | 52.584 | 0.157 | 2.43 | 101.4 | 1.93 | - | 80 | -0.083 | 7.08 | 0.16 |
| 338 | 52.743 | 0.159 | 2.44 | 101.3 | 1.8 | - | 80 | -0.083 | 6.97 | 0.13 |
| 339 | 52.901 | 0.158 | 2.43 | 101.3 | 1.81 | - | 80 | -0.078 | 7.83 | 0.17 |
| 340 | 53.057 | 0.156 | 2.44 | 101.4 | 2.19 | 98 | 80 | -0.081 | 8.15 | 0.08 |
| 341 | 53.213 | 0.156 | 2.43 | 101.3 | 1.61 | - | 80 | -0.082 | 6.88 | 0.12 |
| 342 | 53.369 | 0.156 | 2.43 | 101.4 | 1.6 | - | 80 | -0.077 | 6.32 | 0.13 |
| 343 | 53.528 | 0.159 | 2.43 | 101.3 | 1.64 | - | 80 | -0.077 | 5.79 | 0.11 |
| 344 | 53.684 | 0.156 | 2.43 | 101.4 | 2.19 | - | 80 | -0.076 | 5.53 | 0.14 |
| 345 | 53.842 | 0.158 | 2.43 | 101.3 | 2.06 | - | 80 | -0.074 | 6.16 | 0.10 |
| 346 | 54.000 | 0.158 | 2.44 | 101.4 | 1.81 | - | 80 | -0.077 | 6.35 | 0.11 |
| 347 | 54.156 | 0.156 | 2.43 | 101.5 | 1.67 | - | 80 | -0.076 | 5.44 | 0.15 |
| 348 | 54.319 | 0.163 | 2.44 | 101.4 | 1.62 | - | 80 | -0.076 | 5.98 | 0.12 |
| 349 | 54.473 | 0.154 | 2.44 | 101.5 | 2.13 | - | 80 | -0.073 | 5.38 | 0.12 |
| 350 | 54.632 | 0.159 | 2.43 | 101.5 | 2.2 | 99 | 80 | -0.077 | 6.24 | 0.10 |
| 351 | 54.790 | 0.158 | 2.44 | 101.5 | 1.61 | - | 80 | -0.078 | 6.12 | 0.11 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 Fabrications
 Model: Mini Me
 Run #: 1

Job #: 24-265
 Tracking #: 212
 Technician: AK
 Date: 8/13/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 352 | 54.943 | 0.153 | 2.43 | 101.4 | 1.97 | - | 80 | -0.080 | 8.35 | 0.09 |
| 353 | 55.103 | 0.160 | 2.44 | 101.5 | 1.69 | - | 80 | -0.071 | 7.48 | 0.14 |
| 354 | 55.260 | 0.157 | 2.44 | 101.5 | 2.11 | - | 80 | -0.068 | 4.82 | 0.29 |
| 355 | 55.418 | 0.158 | 2.42 | 101.6 | 1.69 | - | 80 | -0.066 | 4.21 | 0.27 |
| 356 | 55.577 | 0.159 | 2.43 | 101.6 | 2.09 | - | 80 | -0.073 | 6.44 | 0.14 |
| 357 | 55.732 | 0.155 | 2.43 | 101.5 | 2.18 | - | 80 | -0.075 | 5.68 | 0.14 |
| 358 | 55.889 | 0.157 | 2.43 | 101.7 | 1.65 | - | 80 | -0.086 | 6.70 | 0.10 |
| 359 | 56.045 | 0.156 | 2.43 | 101.7 | 2.18 | - | 80 | -0.086 | 10.45 | 0.05 |
| 360 | 56.204 | 0.159 | 2.44 | 101.6 | 1.98 | 99 | 80 | -0.089 | 10.88 | 0.04 |
| Avg/Tot | 56.204 | 0.156 | 2.44 | 96 | 1.85 | 100 | | | 8.93 | 0.09 |

LAB SAMPLE DATA - ASTM E2515

Client: 509 Fabrications
 Model: Mini Me
 Run #: 1

Job #: 24-265
 Tracking #: 212
 Technician: AK
 Date: 8/13/2024

| | | Sample ID | Tare, mg | Final, mg | Catch, mg |
|----------------|---------------------|-----------|----------|-----------|-----------|
| Filters | A | G01125 | 245.5 | 247.1 | 1.6 |
| | B | G01126 | 245.5 | 246.9 | 1.4 |
| | C - 1st Hour | G01127 | 244.1 | 244.1 | 0.0 |
| | Amb | G01128 | 245.6 | 245.7 | 0.1 |
| Probes | A | 18A | 117501.0 | 117501.0 | 0.0 |
| | B | 18B | 117333.0 | 117333.0 | 0.0 |
| | C - 1st Hour | 18C | 114335.8 | 114335.9 | 0.1 |
| | | | | | |
| O-rings | A | 18A | 3602.7 | 3603.0 | 0.3 |
| | B | 18B | 3546.1 | 3546.4 | 0.3 |
| | C - 1st Hour | 18C | 3528.5 | 3529.0 | 0.5 |
| | | | | | |

Placed in Dessicator on: 8/13/2024

Balance Audit (mg): 200.0 200.0

| | | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time |
|----------------|---------------------|-------------|-----------|-------------|------------|-------------|-----------|-------------|-----------|
| Filters | A | 247.3 | 8/19 9:00 | 247.1 | 8/21 14:45 | | | | |
| | B | 246.8 | 8/19 9:00 | 246.9 | 8/21 14:45 | | | | |
| | C - 1st Hour | 244.1 | 8/19 9:00 | 244.1 | 8/21 14:45 | | | | |
| | Amb | 245.9 | 8/19 9:00 | 245.7 | 8/21 14:45 | | | | |
| Probes | A | 117501.2 | 8/19 9:00 | 117501.0 | 8/21 14:45 | | | | |
| | B | 117333.0 | 8/19 9:00 | 117333.0 | 8/21 14:45 | | | | |
| | C - 1st Hour | 114335.8 | 8/19 9:00 | 114335.9 | 8/21 14:45 | | | | |
| | | | | | | | | | |
| O-Rings | A | 3603.2 | 8/19 9:00 | 3603.0 | 8/21 14:45 | | | | |
| | B | 3546.8 | 8/19 9:00 | 3546.4 | 8/21 14:45 | | | | |
| | C - 1st Hour | 3529.5 | 8/19 9:00 | 3529.0 | 8/21 14:45 | | | | |
| | | | | | | | | | |

| | |
|-------------------------------|------------|
| Train A Aggregate, mg: | 1.9 |
| Train B Aggregate, mg: | 1.7 |
| Train C Aggregate, mg: | 0.6 |
| Ambient Aggregate, mg: | 0.1 |

ASTM E2779 Wood Heater Run Sheets

Client: 509 Fabrications Job Number: 24-265 Tracking #: 212
 Model: Mini Me Run Number: 1 Test Date: 8/13/24

Pellet Heater Control Settings

High Burn Rate Settings: Fully Open
 Medium Burn Rate Settings: Open 3/32"
 Low Burn Rate Settings: Fully closed

Preburn Notes

Preburn Start Time: 08:28

| Time | Notes |
|------|--------|
| | -None- |

Test Notes

Test Burn Start Time: 09:28

| Time | Notes |
|------|--------|
| | -None- |

Test Burn End Time: 15:28


Flue Gas Concentration Measurement

Calibration Gas Values: Span Gas CO₂ (%): 16.98 CO (%): 4.300
 Mid Gas CO₂ (%): 10.00 CO (%): 2.500

Calibration Results:

| | Pre Test | | | Post Test | | |
|-----------------|----------|-------|-------|------------|------------|------------|
| | Zero | Span | Mid | Zero | Span | Mid |
| Time | 08:44 | 08:45 | 08:46 | 8/14 08:56 | 8/14 08:57 | 8/14 08:58 |
| CO ₂ | 0.00 | 16.97 | 10.13 | 0.00 | 17.06 | 10.13 |
| CO | 0.000 | 4.302 | 2.509 | -0.001 | 4.315 | 2.522 |

Flue Gas Probe Leak Check: Initial: 0 Final: 0

Technician Signature: 

Date: 8/28/2024
Page 1 of 1

PELLET TEST DATA PACKET
ASTM E2779/E2515



Run 2 Data Summary

Client: 509 Fabrications
Model: Mini Me
Job #: 24-265
Tracking #: 212
Test Date: 8/14/2024



Technician Signature

9/3/2024

Date

TEST RESULTS - ASTM E2779 / ASTM E2515

Client: 509 FabricationsModel: Mini MeRun #: 2Job #: 24-265Tracking #: 212Technician: AKDate: 8/14/2024

| Burn Rate Summary | |
|-------------------------------|------|
| High Burn Rate (dry kg/hr) | 2.07 |
| Medium Burn Rate (dry kg/hr) | 1.34 |
| Low Burn Rate (dry kg/hr) | 0.86 |
| Overall Burn Rate (dry kg/hr) | 1.22 |

Medium Burn Rate Target: < 1.47 dry kg/hr

| | Ambient Sample | Sample Train A | Sample Train B | 1st Hour Filter - Train C |
|---|-------------------|-------------------|-------------------|------------------------------|
| Total Sample Volume (ft ³) | 84.753 | 57.378 | 56.636 | 9.131 |
| Average Gas Velocity in Dilution Tunnel (ft/sec) | 18.2 | | | |
| Average Gas Flow Rate in Dilution Tunnel (dscf/hr) | 11860.5 | | | |
| Average Gas Meter Temperature (°F) | 73.7 | 92.8 | 97.6 | 83.1 |
| Total Sample Volume (dscf) | 84.214 | 54.944 | 54.624 | 8.976 |
| Average Tunnel Temperature (°F) | 102.8 | | | |
| Total Time of Test (min) | 360 | | | |
| Total Particulate Catch (mg) | 0.1 | 1.8 | 1.7 | 0.9 |
| Particulate Concentration, dry-standard (g/dscf) | 0.0000012 | 0.0000328 | 0.0000311 | 0.0001003 |
| Total PM Emissions (g) | 0.08 | 2.25 | 2.13 | 1.18 |
| Particulate Emission Rate (g/hr) | 0.01 | 0.37 | 0.36 | 1.18 |
| Emissions Factor (g/kg) | - | 0.31 | 0.29 | 0.57 |
| Difference from Average Total Particulate Emissions (g) | - | 0.06 | 0.06 | - |
| Difference from Average Total Particulate Emissions (%) | - | 2.7% | 2.7% | - |
| Difference from Average Emissions Factor (g/kg) | - | 0.01 | 0.01 | - |

| Final Average Results | |
|----------------------------------|-------|
| Total Particulate Emissions (g) | 2.19 |
| Particulate Emission Rate (g/hr) | 0.36 |
| Emissions Factor (g/kg) | 0.30 |
| HHV Efficiency (%) | 75.6% |
| LHV Efficiency (%) | 81.0% |
| CO Emissions (g/min) | 0.22 |

| Quality Checks | Requirement | Observed | Result |
|----------------------------------|---|--------------------------|--------|
| Dual Train Precision | Each train within 7.5% of average emissions (in grams), or emission factors within 0.5 g/kg | See Above | OK |
| Filter Temps | <90 °F | 84 | OK |
| Face Velocity | < 30 ft/min | 13.3 | OK |
| Leakage Rate | Less than 4% of average sample rate | 0.001 cfm | OK |
| Ambient Temp | 55-90 °F | 70.5 / 76 | OK |
| Negative Probe Weight Evaluation | <5% of Total Catch | Probe Catch Not Negative | OK |
| Pro-Rate Variation | 90% of readings between 90-110%; none greater than 120% or less than 80% | See Data Tabs | OK |
| Medium Burn Rate | < midpoint of the high and low burn rates | 1.34 | OK |

Overall Pellet Test Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/14/24
Run: 2
Control #: 24-265
Test Duration: 360
Output Category: Integrated

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 75.6% | 81.0% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 76.0% | 81.4% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 18,563 | 17,609 | (Btu/h) |
| Burn Rate (kg/h) | 1.22 | 2.70 | (lb/h) |
| Input (kJ/h) | 24,555 | 23,293 | (Btu/h) |

| | | | |
|----------------------------------|------|-------|---------------|
| Test Load Weight (dry kg) | 7.35 | 16.19 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | 2.19 | | |
| CO (g) | 78 | | |
| Test Duration (h) | 6.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | 0.02 | 0.70 |
| g/kg Dry Fuel | 0.30 | 10.61 |
| g/h | 0.36 | 12.99 |
| g/min | 0.01 | 0.22 |
| lb/MM Btu Output | 0.05 | 1.63 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 13.47 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

Max Burn Rate Segment Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/14/24
Run: 2
Control #: 24-265
Test Duration: 60
Output Category: Maximum

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 74.5% | 79.8% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 74.8% | 80.2% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 30,980 | 29,388 | (Btu/h) |
| Burn Rate (kg/h) | 2.07 | 4.57 | (lb/h) |
| Input (kJ/h) | 41,597 | 39,460 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 2.07 | 4.57 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | N/A | | |
| CO (g) | 10 | | |
| Test Duration (h) | 1.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | N/A | 0.32 |
| g/kg Dry Fuel | N/A | 4.85 |
| g/h | N/A | 10.07 |
| g/min | N/A | 0.17 |
| lb/MM Btu Output | N/A | 0.76 |

| | |
|-----------------------------|------|
| Air/Fuel Ratio (A/F) | 9.49 |
|-----------------------------|------|

VERSION:

2.4

4/15/2010

Medium Burn Rate Segment Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/14/24
Run: 2
Control #: 24-265
Test Duration: 120
Output Category: Medium

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 75.0% | 80.4% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 75.4% | 80.8% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 20,206 | 19,167 | (Btu/h) |
| Burn Rate (kg/h) | 1.34 | 2.96 | (lb/h) |
| Input (kJ/h) | 26,945 | 25,560 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 2.69 | 5.92 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | N/A | | |
| CO (g) | 27 | | |
| Test Duration (h) | 2.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | N/A | 0.67 |
| g/kg Dry Fuel | N/A | 10.13 |
| g/h | N/A | 13.62 |
| g/min | N/A | 0.23 |
| lb/MM Btu Output | N/A | 1.57 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 12.77 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

Minimum Burn Rate Segment Efficiency Results

Manufacturer: 509 Fabrications
Model: Mini Me
Date: 08/14/24
Run: 2
Control #: 24-265
Test Duration: 180
Output Category: Minimum

Test Results in Accordance with CSA B415.1-10

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 76.7% | 82.2% |
| Combustion Efficiency | 99.4% | 99.4% |
| Heat Transfer Efficiency | 77.2% | 82.7% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 13,248 | 12,567 | (Btu/h) |
| Burn Rate (kg/h) | 0.86 | 1.90 | (lb/h) |
| Input (kJ/h) | 17,280 | 16,392 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 2.59 | 5.70 | dry lb |
| MC wet (%) | 2.10 | | |
| MC dry (%) | 2.15 | | |
| Particulate (g) | N/A | | |
| CO (g) | 41 | | |
| Test Duration (h) | 3.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | N/A | 1.02 |
| g/kg Dry Fuel | N/A | 15.70 |
| g/h | N/A | 13.53 |
| g/min | N/A | 0.23 |
| lb/MM Btu Output | N/A | 2.37 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 16.37 |
|-----------------------------|-------|

VERSION:

2.4

4/15/2010

DILUTION TUNNEL & MISC. DATA - ASTM E2779 / E2515

Client: 509 Fabrications
 Model: Mini Me
 Run #: 2
 Test Start Time: 9:29

Job #: 24-265
 Tracking #: 212
 Technician: AK
 Date: 8/14/2024

High Burn End Time (min): 60
 Medium Burn End Time (min): 180
 Total Sampling Time (min): 360
 Recording Interval (min): 1

Meter Box γ Factor: 0.996 (A)
 Meter Box γ Factor: 1.012 (B)
 Meter Box γ Factor: 1.008 (C)
 Meter Box γ Factor: 1.004 (Ambient)
 Induced Draft Check (in. H₂O): 0
 Smoke Capture Check (%): 100%
 Date Flue Pipe Last Cleaned: 8/12/2024
 Platform Scale Audit (lbs): 10.0

| | Pre-Test | Post Test | Avg. |
|------------------------------|----------|-----------|-----------------|
| Barometric Pressure (in. Hg) | 29.96 | 29.93 | 29.95 |
| Relative Humidity (%) | 39.7 | 37.2 | |
| Room Air Velocity (ft/min) | <50 | <50 | |
| Pitot Tube Leak Check | 0 | 0 | |
| Ambient Sample Volume: | 84.753 | | ft ³ |

Sample Train Leak Checks

| | Pre-test | Post-test | | |
|-----------|----------|-----------|-------|------------|
| (A) | 0.000 | 0.000 | cfm @ | -7 in. Hg |
| (B) | 0.000 | 0.000 | cfm @ | -7 in. Hg |
| (C) | 0.001 | 0.001 | cfm @ | -7 in. Hg |
| (Ambient) | 0.000 | 0.000 | cfm @ | -14 in. Hg |

DILUTION TUNNEL FLOW

Traverse Data

| Point | dP (in H ₂ O) | Temp (°F) |
|--------|--------------------------|-----------|
| 1 | 0.054 | 80 |
| 2 | 0.090 | 80 |
| 3 | 0.092 | 80 |
| 4 | 0.052 | 80 |
| 5 | 0.054 | 80 |
| 6 | 0.092 | 80 |
| 7 | 0.094 | 80 |
| 8 | 0.056 | 80 |
| Center | 0.097 | 80 |

Dilution Tunnel H₂O: 2.00 percent
 Tunnel Diameter: 6 inches
 Pitot Tube C_p: 0.99 [unitless]
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Tunnel Area: 0.1963 ft²

V_{strav}: 17.942 ft/sec
 V_{scent}: 20.864 ft/sec
 F_p: 0.860 [ratio]
 Initial Tunnel Flow: 202.7 scf/min

Static Pressure: -0.160 in. H₂O

TEST FUEL PROPERTIES

Default Fuel Values

| Fuel Type: | D. Fir | Oak |
|-------------|--------|--------|
| HHV (kJ/kg) | 19,810 | 19,887 |
| %C | 48.73 | 50 |
| %H | 6.87 | 6.6 |
| %O | 43.9 | 42.9 |
| %Ash | 0.5 | 0.5 |

Actual Fuel Used Properties

| | |
|--------------------|-------------|
| Pellet Brand: | Lignetics |
| Pellet Fuel Grade: | PFI Premium |
| HHV (BTU/lb) | 8627 |
| %C | 49.48 |
| %H | 6.22 |
| %O | 44.13 |
| %Ash | 0.17 |
| MC (%WB) | 2.1 |

PELLET STOVE PREBURN DATA - ASTM E2779

| | |
|---------------------------------|------------------------|
| Client: <u>509 Fabrications</u> | Job #: <u>24-265</u> |
| Model: <u>Mini Me</u> | Tracking #: <u>212</u> |
| Run #: <u>2</u> | Technician: <u>AK</u> |
| | Date: <u>8/14/2024</u> |

Recording Interval (min): 1
 Run Time (min): 60

| Elapsed Time (min) | Scale Reading (lbs) | Average: | | | |
|--------------------|---------------------|---------------------|----------------------------------|-----------|--------------|
| | | Weight Change (lbs) | Flue Draft (in H ₂ O) | Flue (°F) | Ambient (°F) |
| 0 | 35.9 | - | -0.096 | 572 | 72 |
| 1 | 35.8 | -0.06 | -0.097 | 581 | 71 |
| 2 | 35.8 | -0.08 | -0.095 | 572 | 71 |
| 3 | 35.7 | -0.07 | -0.096 | 565 | 71 |
| 4 | 35.7 | -0.03 | -0.089 | 545 | 71 |
| 5 | 35.6 | -0.06 | -0.091 | 537 | 71 |
| 6 | 35.5 | -0.07 | -0.097 | 552 | 71 |
| 7 | 35.4 | -0.11 | -0.100 | 573 | 71 |
| 8 | 35.3 | -0.08 | -0.102 | 615 | 71 |
| 9 | 35.3 | -0.06 | -0.096 | 597 | 72 |
| 10 | 35.2 | -0.09 | -0.095 | 576 | 72 |
| 11 | 35.2 | -0.04 | -0.096 | 569 | 72 |
| 12 | 35.1 | -0.06 | -0.099 | 563 | 72 |
| 13 | 35.0 | -0.05 | -0.091 | 552 | 72 |
| 14 | 35.0 | -0.06 | -0.094 | 556 | 72 |
| 15 | 34.9 | -0.07 | -0.097 | 554 | 72 |
| 16 | 34.9 | -0.04 | -0.093 | 547 | 72 |
| 17 | 34.8 | -0.08 | -0.098 | 567 | 72 |
| 18 | 34.7 | -0.08 | -0.099 | 589 | 72 |
| 19 | 34.6 | -0.07 | -0.100 | 588 | 72 |
| 20 | 34.6 | -0.04 | -0.097 | 598 | 72 |
| 21 | 34.6 | -0.05 | -0.094 | 566 | 72 |
| 22 | 34.5 | -0.07 | -0.097 | 575 | 72 |
| 23 | 34.4 | -0.07 | -0.095 | 567 | 73 |
| 24 | 34.3 | -0.07 | -0.099 | 596 | 73 |
| 25 | 34.3 | -0.08 | -0.098 | 596 | 73 |
| 26 | 34.2 | -0.05 | -0.095 | 584 | 72 |
| 27 | 34.1 | -0.07 | -0.094 | 570 | 72 |
| 28 | 34.1 | -0.07 | -0.091 | 553 | 72 |
| 29 | 34.0 | -0.05 | -0.092 | 536 | 72 |
| 30 | 34.0 | -0.06 | -0.091 | 533 | 72 |
| 31 | 33.9 | -0.09 | -0.093 | 537 | 72 |
| 32 | 33.9 | -0.02 | -0.098 | 572 | 72 |
| 33 | 33.8 | -0.09 | -0.092 | 570 | 72 |
| 34 | 33.7 | -0.08 | -0.095 | 563 | 72 |
| 35 | 33.6 | -0.06 | -0.093 | 558 | 72 |
| 36 | 33.6 | -0.03 | -0.097 | 570 | 72 |
| 37 | 33.5 | -0.08 | -0.097 | 571 | 72 |
| 38 | 33.5 | -0.06 | -0.098 | 595 | 72 |
| 39 | 33.4 | -0.1 | -0.097 | 587 | 72 |
| 40 | 33.3 | -0.03 | -0.097 | 593 | 72 |
| 41 | 33.2 | -0.1 | -0.093 | 580 | 72 |
| 42 | 33.2 | -0.05 | -0.095 | 568 | 72 |
| 43 | 33.1 | -0.07 | -0.093 | 564 | 72 |
| 44 | 33.1 | -0.05 | -0.095 | 542 | 71 |
| 45 | 33.0 | -0.05 | -0.091 | 526 | 71 |
| 46 | 32.9 | -0.06 | -0.091 | 523 | 71 |

PELLET STOVE PREBURN DATA - ASTM E2779

Client: 509 Fabrications Job #: 24-265
Model: Mini Me Tracking #: 212
Run #: 2 Technician: AK
Date: 8/14/2024

| | | | | | |
|----|------|-------|--------|-----|----|
| 47 | 32.9 | -0.07 | -0.094 | 509 | 71 |
| 48 | 32.8 | -0.06 | -0.098 | 568 | 71 |
| 49 | 32.7 | -0.09 | -0.102 | 611 | 71 |
| 50 | 32.6 | -0.08 | -0.101 | 627 | 70 |
| 51 | 32.5 | -0.1 | -0.100 | 599 | 71 |
| 52 | 32.5 | -0.06 | -0.099 | 610 | 70 |
| 53 | 32.4 | -0.08 | -0.096 | 597 | 71 |
| 54 | 32.4 | -0.05 | -0.096 | 591 | 70 |
| 55 | 32.3 | -0.06 | -0.099 | 588 | 71 |
| 56 | 32.2 | -0.06 | -0.101 | 603 | 70 |
| 57 | 32.1 | -0.09 | -0.100 | 603 | 71 |
| 58 | 32.1 | -0.06 | -0.097 | 593 | 71 |
| 59 | 32.0 | -0.05 | -0.097 | 574 | 71 |
| 60 | 32.0 | -0.05 | -0.098 | 570 | 71 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 0 | 0.000 | | 0.095 | 0.00 | 75.8 | 0.05 | | 16.5 | | 111 | 577 | 73 | 71 |
| 1 | 0.098 | 0.098 | 0.096 | 2.07 | 75.7 | 0.86 | - | 16.5 | -0.1 | 111 | 602 | 74 | 70.7 |
| 2 | 0.239 | 0.141 | 0.097 | 2.14 | 75.7 | 0.9 | - | 16.4 | -0.1 | 112 | 642 | 75 | 70.5 |
| 3 | 0.384 | 0.145 | 0.097 | 2.18 | 75.7 | 0.92 | - | 16.3 | 0.0 | 114 | 650 | 76 | 70.9 |
| 4 | 0.531 | 0.147 | 0.097 | 2.20 | 75.7 | 0.86 | - | 16.2 | -0.1 | 115 | 663 | 76 | 70.7 |
| 5 | 0.677 | 0.146 | 0.097 | 2.24 | 75.8 | 0.89 | - | 16.1 | -0.1 | 116 | 648 | 76 | 70.5 |
| 6 | 0.828 | 0.151 | 0.095 | 2.26 | 75.8 | 0.86 | - | 16.1 | -0.1 | 116 | 633 | 77 | 70.5 |
| 7 | 0.973 | 0.145 | 0.096 | 2.29 | 75.9 | 0.91 | - | 16.0 | -0.1 | 116 | 656 | 77 | 70.7 |
| 8 | 1.125 | 0.152 | 0.096 | 2.30 | 76.1 | 0.91 | - | 15.9 | -0.1 | 116 | 657 | 77 | 70.7 |
| 9 | 1.272 | 0.147 | 0.097 | 2.32 | 76.1 | 0.87 | - | 15.8 | -0.1 | 115 | 638 | 78 | 70.9 |
| 10 | 1.425 | 0.153 | 0.096 | 2.33 | 76.2 | 0.92 | 93 | 15.7 | -0.1 | 116 | 648 | 78 | 71.1 |
| 11 | 1.573 | 0.148 | 0.093 | 2.34 | 76.4 | 0.88 | - | 15.7 | -0.1 | 116 | 632 | 78 | 70.9 |
| 12 | 1.727 | 0.154 | 0.095 | 2.37 | 76.6 | 0.92 | - | 15.6 | -0.1 | 116 | 624 | 79 | 71.2 |
| 13 | 1.876 | 0.149 | 0.094 | 2.38 | 76.8 | 0.91 | - | 15.5 | -0.1 | 115 | 623 | 79 | 71.2 |
| 14 | 2.029 | 0.153 | 0.094 | 2.39 | 77 | 0.89 | - | 15.4 | -0.1 | 115 | 626 | 79 | 71.2 |
| 15 | 2.179 | 0.150 | 0.096 | 2.39 | 77.2 | 0.87 | - | 15.4 | -0.1 | 116 | 630 | 79 | 71.1 |
| 16 | 2.334 | 0.155 | 0.093 | 2.41 | 77.4 | 0.9 | - | 15.3 | -0.1 | 115 | 627 | 79 | 71.1 |
| 17 | 2.486 | 0.152 | 0.092 | 2.41 | 77.6 | 0.92 | - | 15.2 | -0.1 | 114 | 642 | 79 | 71.4 |
| 18 | 2.640 | 0.154 | 0.097 | 2.42 | 77.9 | 0.89 | - | 15.2 | -0.1 | 115 | 659 | 80 | 71.6 |
| 19 | 2.795 | 0.155 | 0.093 | 2.43 | 78.1 | 0.89 | - | 15.1 | -0.1 | 117 | 665 | 80 | 71.3 |
| 20 | 2.947 | 0.152 | 0.096 | 2.43 | 78.3 | 0.92 | 100 | 15.0 | -0.1 | 118 | 679 | 80 | 70.9 |
| 21 | 3.103 | 0.156 | 0.094 | 2.44 | 78.6 | 0.9 | - | 14.9 | -0.1 | 117 | 620 | 80 | 71.2 |
| 22 | 3.253 | 0.150 | 0.096 | 2.44 | 78.9 | 0.9 | - | 14.8 | -0.1 | 116 | 616 | 80 | 71 |
| 23 | 3.410 | 0.157 | 0.095 | 2.45 | 79.2 | 0.9 | - | 14.8 | -0.1 | 117 | 611 | 80 | 71.3 |
| 24 | 3.562 | 0.152 | 0.095 | 2.45 | 79.3 | 0.93 | - | 14.7 | -0.1 | 116 | 619 | 80 | 71.4 |
| 25 | 3.720 | 0.158 | 0.094 | 2.47 | 79.7 | 0.89 | - | 14.6 | -0.1 | 117 | 644 | 80 | 71.2 |
| 26 | 3.873 | 0.153 | 0.094 | 2.47 | 79.9 | 0.89 | - | 14.5 | -0.1 | 117 | 661 | 81 | 71.6 |
| 27 | 4.029 | 0.156 | 0.094 | 2.47 | 80.2 | 0.9 | - | 14.4 | -0.1 | 118 | 652 | 81 | 71.5 |
| 28 | 4.183 | 0.154 | 0.097 | 2.47 | 80.5 | 0.88 | - | 14.4 | 0.0 | 118 | 646 | 81 | 71.5 |
| 29 | 4.339 | 0.156 | 0.095 | 2.47 | 80.8 | 0.91 | - | 14.3 | -0.1 | 118 | 636 | 81 | 71.4 |
| 30 | 4.497 | 0.158 | 0.094 | 2.47 | 81 | 0.93 | 102 | 14.2 | -0.1 | 117 | 623 | 81 | 71.6 |
| 31 | 4.650 | 0.153 | 0.096 | 2.48 | 81.3 | 0.91 | - | 14.1 | -0.1 | 117 | 658 | 81 | 71.6 |
| 32 | 4.808 | 0.158 | 0.095 | 2.49 | 81.6 | 0.95 | - | 14.0 | -0.1 | 118 | 680 | 81 | 71.2 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 33 | 4.960 | 0.152 | 0.095 | 2.49 | 81.8 | 0.96 | - | 13.9 | -0.1 | 119 | 705 | 81 | 71.5 |
| 34 | 5.120 | 0.160 | 0.098 | 2.50 | 82.1 | 0.94 | - | 13.8 | -0.1 | 120 | 701 | 81 | 71.4 |
| 35 | 5.274 | 0.154 | 0.097 | 2.49 | 82.4 | 0.94 | - | 13.7 | -0.1 | 120 | 690 | 81 | 71.6 |
| 36 | 5.431 | 0.157 | 0.098 | 2.50 | 82.6 | 0.95 | - | 13.7 | 0.0 | 119 | 677 | 81 | 72.2 |
| 37 | 5.588 | 0.157 | 0.097 | 2.50 | 82.9 | 0.92 | - | 13.6 | -0.1 | 119 | 663 | 81 | 71.7 |
| 38 | 5.744 | 0.156 | 0.096 | 2.50 | 83.2 | 0.92 | - | 13.5 | -0.1 | 120 | 654 | 81 | 71.6 |
| 39 | 5.902 | 0.158 | 0.098 | 2.51 | 83.4 | 0.94 | - | 13.4 | 0.0 | 119 | 650 | 81 | 71.7 |
| 40 | 6.056 | 0.154 | 0.096 | 2.50 | 83.7 | 0.92 | 102 | 13.4 | -0.1 | 118 | 629 | 81 | 71.5 |
| 41 | 6.217 | 0.161 | 0.097 | 2.51 | 83.9 | 0.93 | - | 13.3 | -0.1 | 118 | 622 | 81 | 71.2 |
| 42 | 6.372 | 0.155 | 0.095 | 2.53 | 84.2 | 0.95 | - | 13.2 | -0.1 | 117 | 619 | 81 | 71.2 |
| 43 | 6.529 | 0.157 | 0.098 | 2.52 | 84.3 | 0.96 | - | 13.1 | -0.1 | 118 | 636 | 81 | 71.5 |
| 44 | 6.686 | 0.157 | 0.094 | 2.52 | 84.6 | 0.95 | - | 13.0 | -0.1 | 118 | 638 | 81 | 71.7 |
| 45 | 6.843 | 0.157 | 0.096 | 2.52 | 84.8 | 0.95 | - | 12.9 | -0.1 | 118 | 622 | 81 | 71.3 |
| 46 | 7.002 | 0.159 | 0.095 | 2.52 | 85 | 0.95 | - | 12.9 | -0.1 | 118 | 627 | 81 | 71.5 |
| 47 | 7.156 | 0.154 | 0.093 | 2.52 | 85.2 | 0.93 | - | 12.8 | -0.1 | 117 | 628 | 81 | 71.5 |
| 48 | 7.318 | 0.162 | 0.096 | 2.53 | 85.4 | 0.94 | - | 12.8 | -0.1 | 117 | 645 | 81 | 71.4 |
| 49 | 7.473 | 0.155 | 0.098 | 2.53 | 85.6 | 0.97 | - | 12.7 | -0.1 | 117 | 644 | 81 | 71.4 |
| 50 | 7.631 | 0.158 | 0.097 | 2.54 | 85.8 | 0.95 | 101 | 12.6 | -0.1 | 116 | 611 | 81 | 72.1 |
| 51 | 7.791 | 0.160 | 0.097 | 2.53 | 86 | 0.93 | - | 12.6 | -0.1 | 116 | 604 | 81 | 72.2 |
| 52 | 7.947 | 0.156 | 0.095 | 2.54 | 86.3 | 0.95 | - | 12.5 | -0.1 | 116 | 598 | 81 | 71.9 |
| 53 | 8.107 | 0.160 | 0.094 | 2.55 | 86.4 | 0.94 | - | 12.4 | -0.1 | 116 | 605 | 81 | 72.3 |
| 54 | 8.262 | 0.155 | 0.093 | 2.53 | 86.6 | 0.95 | - | 12.4 | -0.1 | 116 | 625 | 81 | 71.9 |
| 55 | 8.423 | 0.161 | 0.095 | 2.54 | 86.8 | 0.93 | - | 12.3 | 0.0 | 115 | 552 | 81 | 71.8 |
| 56 | 8.579 | 0.156 | 0.095 | 2.53 | 87 | 0.97 | - | 12.2 | -0.1 | 115 | 655 | 81 | 72 |
| 57 | 8.737 | 0.158 | 0.093 | 2.51 | 87.1 | 0.98 | - | 12.1 | -0.1 | 116 | 657 | 81 | 71.8 |
| 58 | 8.898 | 0.161 | 0.094 | 2.52 | 87.3 | 0.97 | - | 12.0 | -0.1 | 117 | 656 | 81 | 72.2 |
| 59 | 9.052 | 0.154 | 0.097 | 2.54 | 87.5 | 0.96 | - | 12.0 | -0.1 | 116 | 623 | 81 | 72.1 |
| 60 | 9.213 | 0.161 | 0.095 | 2.52 | 87.7 | 0.97 | 102 | 11.9 | -0.1 | 117 | 624 | 81 | 72 |
| 61 | 9.369 | 0.156 | 0.091 | 2.53 | 87.8 | 0.97 | - | 11.8 | -0.1 | 116 | 626 | 81 | 72.3 |
| 62 | 9.528 | 0.159 | 0.094 | 2.54 | 88 | 0.97 | - | 11.7 | -0.1 | 116 | 611 | 81 | 71.9 |
| 63 | 9.687 | 0.159 | 0.098 | 2.52 | 88.1 | 0.97 | - | 11.7 | 0.0 | 114 | 605 | 81 | 72.6 |
| 64 | 9.844 | 0.157 | 0.093 | 2.53 | 88.3 | 0.96 | - | 11.6 | -0.1 | 113 | 597 | 81 | 72.2 |
| 65 | 10.004 | 0.160 | 0.096 | 2.54 | 88.5 | 0.98 | - | 11.5 | -0.1 | 114 | 600 | 81 | 72 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 66 | 10.160 | 0.156 | 0.096 | 2.54 | 88.6 | 0.98 | - | 11.5 | -0.1 | 113 | 594 | 81 | 72.2 |
| 67 | 10.321 | 0.161 | 0.096 | 2.54 | 88.8 | 0.98 | - | 11.4 | -0.1 | 113 | 597 | 81 | 72.4 |
| 68 | 10.477 | 0.156 | 0.096 | 2.54 | 88.9 | 0.97 | - | 11.3 | -0.1 | 113 | 588 | 81 | 72.2 |
| 69 | 10.636 | 0.159 | 0.095 | 2.55 | 89 | 0.96 | - | 11.3 | -0.1 | 113 | 600 | 81 | 72.2 |
| 70 | 10.797 | 0.161 | 0.095 | 2.54 | 89.2 | 0.94 | 102 | 11.2 | -0.1 | 114 | 578 | 81 | 72.1 |
| 71 | 10.952 | 0.155 | 0.094 | 2.54 | 89.3 | 0.98 | - | 11.1 | -0.1 | 113 | 553 | 81 | 72.2 |
| 72 | 11.115 | 0.163 | 0.097 | 2.54 | 89.4 | 0.99 | - | 11.1 | -0.1 | 111 | 554 | 81 | 72.3 |
| 73 | 11.271 | 0.156 | 0.095 | 2.54 | 89.6 | 0.98 | - | 11.0 | 0.0 | 111 | 551 | 81 | 72.3 |
| 74 | 11.430 | 0.159 | 0.098 | 2.54 | 89.7 | 1 | - | 11.0 | -0.1 | 109 | 555 | 81 | 72.2 |
| 75 | 11.591 | 0.161 | 0.096 | 2.55 | 89.8 | 0.98 | - | 10.9 | -0.1 | 110 | 565 | 81 | 72.1 |
| 76 | 11.747 | 0.156 | 0.097 | 2.55 | 89.9 | 0.98 | - | 10.8 | -0.1 | 111 | 561 | 81 | 72.2 |
| 77 | 11.909 | 0.162 | 0.094 | 2.55 | 90.1 | 0.97 | - | 10.8 | -0.1 | 111 | 540 | 81 | 72.2 |
| 78 | 12.066 | 0.157 | 0.095 | 2.55 | 90.2 | 0.97 | - | 10.7 | 0.0 | 110 | 551 | 81 | 72.3 |
| 79 | 12.226 | 0.160 | 0.096 | 2.55 | 90.3 | 0.97 | - | 10.7 | -0.1 | 111 | 578 | 81 | 72 |
| 80 | 12.386 | 0.160 | 0.094 | 2.54 | 90.4 | 0.99 | 102 | 10.6 | -0.1 | 111 | 595 | 81 | 72.1 |
| 81 | 12.544 | 0.158 | 0.093 | 2.55 | 90.5 | 0.98 | - | 10.5 | -0.1 | 112 | 599 | 81 | 72.2 |
| 82 | 12.704 | 0.160 | 0.097 | 2.55 | 90.6 | 0.99 | - | 10.4 | -0.1 | 111 | 587 | 81 | 72.4 |
| 83 | 12.862 | 0.158 | 0.097 | 2.55 | 90.7 | 0.97 | - | 10.4 | 0.0 | 111 | 553 | 81 | 72.5 |
| 84 | 13.022 | 0.160 | 0.095 | 2.55 | 90.8 | 0.96 | - | 10.4 | 0.0 | 108 | 483 | 81 | 72.8 |
| 85 | 13.180 | 0.158 | 0.095 | 2.55 | 90.9 | 0.99 | - | 10.3 | -0.1 | 108 | 502 | 81 | 72.5 |
| 86 | 13.340 | 0.160 | 0.097 | 2.55 | 91 | 0.99 | - | 10.2 | -0.1 | 109 | 573 | 81 | 72.5 |
| 87 | 13.500 | 0.160 | 0.096 | 2.55 | 91.1 | 0.98 | - | 10.2 | -0.1 | 110 | 582 | 81 | 72.9 |
| 88 | 13.657 | 0.157 | 0.097 | 2.54 | 91.2 | 0.99 | - | 10.1 | -0.1 | 110 | 585 | 81 | 73.2 |
| 89 | 13.819 | 0.162 | 0.097 | 2.54 | 91.3 | 1 | - | 10.0 | -0.1 | 111 | 609 | 81 | 72.7 |
| 90 | 14.067 | 0.248 | 0.096 | 2.55 | 91.4 | 0.99 | 107 | 9.9 | -0.1 | 112 | 609 | 81 | 73 |
| 91 | 14.228 | 0.161 | 0.095 | 2.55 | 91.5 | 1 | - | 9.8 | -0.1 | 113 | 595 | 81 | 73 |
| 92 | 14.388 | 0.160 | 0.096 | 2.54 | 91.6 | 1 | - | 9.7 | -0.1 | 112 | 596 | 81 | 72.7 |
| 93 | 14.544 | 0.156 | 0.096 | 2.54 | 91.6 | 1.01 | - | 9.7 | -0.1 | 112 | 603 | 81 | 73.3 |
| 94 | 14.707 | 0.163 | 0.096 | 2.54 | 91.7 | 0.99 | - | 9.6 | -0.1 | 111 | 582 | 81 | 72.9 |
| 95 | 14.863 | 0.156 | 0.098 | 2.54 | 91.8 | 0.99 | - | 9.6 | 0.0 | 111 | 584 | 81 | 72.9 |
| 96 | 15.024 | 0.161 | 0.097 | 2.54 | 91.9 | 1 | - | 9.5 | -0.1 | 111 | 592 | 81 | 73 |
| 97 | 15.185 | 0.161 | 0.096 | 2.56 | 92 | 1 | - | 9.4 | -0.1 | 111 | 574 | 81 | 72.8 |
| 98 | 15.341 | 0.156 | 0.096 | 2.55 | 92.1 | 1 | - | 9.4 | -0.1 | 111 | 562 | 81 | 73.2 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 99 | 15.504 | 0.163 | 0.097 | 2.55 | 92.1 | 0.98 | - | 9.3 | -0.1 | 111 | 550 | 81 | 72.8 |
| 100 | 15.660 | 0.156 | 0.097 | 2.55 | 92.2 | 0.99 | 101 | 9.2 | 0.0 | 110 | 552 | 81 | 73 |
| 101 | 15.820 | 0.160 | 0.097 | 2.56 | 92.3 | 1 | - | 9.2 | -0.1 | 110 | 551 | 81 | 72.9 |
| 102 | 15.982 | 0.162 | 0.095 | 2.55 | 92.3 | 0.99 | - | 9.1 | -0.1 | 110 | 534 | 81 | 72.6 |
| 103 | 16.138 | 0.156 | 0.098 | 2.56 | 92.4 | 1 | - | 9.1 | -0.1 | 109 | 528 | 81 | 73.1 |
| 104 | 16.301 | 0.163 | 0.098 | 2.54 | 92.4 | 0.99 | - | 9.0 | 0.0 | 107 | 513 | 81 | 73.4 |
| 105 | 16.458 | 0.157 | 0.099 | 2.55 | 92.5 | 1 | - | 9.0 | -0.1 | 107 | 506 | 81 | 73 |
| 106 | 16.617 | 0.159 | 0.096 | 2.55 | 92.6 | 1 | - | 8.9 | -0.1 | 108 | 512 | 81 | 72.9 |
| 107 | 16.779 | 0.162 | 0.097 | 2.55 | 92.6 | 0.99 | - | 8.8 | 0.0 | 108 | 529 | 81 | 72.7 |
| 108 | 16.935 | 0.156 | 0.096 | 2.56 | 92.7 | 0.99 | - | 8.8 | -0.1 | 108 | 528 | 81 | 72.9 |
| 109 | 17.099 | 0.164 | 0.090 | 2.55 | 92.7 | 1.01 | - | 8.7 | -0.1 | 108 | 530 | 81 | 73.1 |
| 110 | 17.256 | 0.157 | 0.095 | 2.55 | 92.8 | 1 | 101 | 8.7 | 0.0 | 107 | 527 | 81 | 73.3 |
| 111 | 17.416 | 0.160 | 0.096 | 2.56 | 92.9 | 1 | - | 8.7 | -0.1 | 107 | 513 | 81 | 73.4 |
| 112 | 17.577 | 0.161 | 0.093 | 2.55 | 92.9 | 1.01 | - | 8.6 | -0.1 | 107 | 501 | 81 | 72.9 |
| 113 | 17.734 | 0.157 | 0.095 | 2.55 | 93 | 0.98 | - | 8.5 | -0.1 | 106 | 505 | 81 | 73.2 |
| 114 | 17.896 | 0.162 | 0.098 | 2.55 | 93 | 1.03 | - | 8.5 | 0.0 | 106 | 498 | 81 | 73.1 |
| 115 | 18.054 | 0.158 | 0.092 | 2.56 | 93.1 | 0.97 | - | 8.4 | -0.1 | 106 | 502 | 81 | 73 |
| 116 | 18.215 | 0.161 | 0.096 | 2.57 | 93.2 | 1.01 | - | 8.3 | 0.0 | 107 | 512 | 81 | 72.7 |
| 117 | 18.376 | 0.161 | 0.095 | 2.56 | 93.2 | 1 | - | 8.3 | 0.0 | 107 | 511 | 81 | 73.2 |
| 118 | 18.533 | 0.157 | 0.096 | 2.56 | 93.3 | 1 | - | 8.3 | -0.1 | 106 | 508 | 81 | 73.2 |
| 119 | 18.695 | 0.162 | 0.095 | 2.57 | 93.3 | 1 | - | 8.2 | 0.0 | 105 | 496 | 80 | 73 |
| 120 | 18.853 | 0.158 | 0.098 | 2.56 | 93.3 | 0.99 | 100 | 8.2 | -0.1 | 105 | 482 | 80 | 72.8 |
| 121 | 19.014 | 0.161 | 0.095 | 2.56 | 93.4 | 1 | - | 8.2 | 0.0 | 105 | 467 | 80 | 73 |
| 122 | 19.175 | 0.161 | 0.096 | 2.55 | 93.5 | 1.03 | - | 8.1 | 0.0 | 104 | 472 | 80 | 73.4 |
| 123 | 19.332 | 0.157 | 0.097 | 2.56 | 93.5 | 1.04 | - | 8.1 | -0.1 | 105 | 493 | 80 | 73.2 |
| 124 | 19.495 | 0.163 | 0.096 | 2.56 | 93.5 | 1.02 | - | 8.0 | -0.1 | 104 | 496 | 80 | 73.2 |
| 125 | 19.653 | 0.158 | 0.096 | 2.56 | 93.5 | 1 | - | 8.0 | -0.1 | 104 | 498 | 80 | 73.3 |
| 126 | 19.814 | 0.161 | 0.097 | 2.58 | 93.6 | 1 | - | 7.9 | 0.0 | 105 | 495 | 80 | 73.4 |
| 127 | 19.975 | 0.161 | 0.095 | 2.56 | 93.6 | 1 | - | 7.9 | -0.1 | 105 | 471 | 81 | 73.5 |
| 128 | 20.132 | 0.157 | 0.098 | 2.56 | 93.7 | 1.01 | - | 7.8 | -0.1 | 103 | 462 | 80 | 73.9 |
| 129 | 20.295 | 0.163 | 0.098 | 2.56 | 93.7 | 1.01 | - | 7.8 | 0.0 | 103 | 471 | 80 | 73.8 |
| 130 | 20.453 | 0.158 | 0.097 | 2.57 | 93.7 | 1.01 | 100 | 7.7 | 0.0 | 103 | 454 | 80 | 74.1 |
| 131 | 20.613 | 0.160 | 0.096 | 2.57 | 93.8 | 1.01 | - | 7.7 | 0.0 | 102 | 432 | 80 | 73.8 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 132 | 20.775 | 0.162 | 0.096 | 2.56 | 93.8 | 1.02 | - | 7.7 | 0.0 | 102 | 419 | 80 | 73.5 |
| 133 | 20.932 | 0.157 | 0.093 | 2.57 | 93.9 | 1.01 | - | 7.6 | 0.0 | 101 | 405 | 80 | 73.7 |
| 134 | 21.096 | 0.164 | 0.096 | 2.56 | 93.9 | 1.01 | - | 7.6 | 0.0 | 100 | 412 | 80 | 73.4 |
| 135 | 21.253 | 0.157 | 0.097 | 2.55 | 94 | 1.01 | - | 7.6 | 0.0 | 100 | 410 | 80 | 73.2 |
| 136 | 21.414 | 0.161 | 0.096 | 2.56 | 93.9 | 1.02 | - | 7.6 | 0.0 | 100 | 414 | 80 | 73.5 |
| 137 | 21.575 | 0.161 | 0.098 | 2.57 | 94 | 0.99 | - | 7.6 | 0.0 | 99 | 415 | 80 | 73.5 |
| 138 | 21.732 | 0.157 | 0.094 | 2.57 | 94 | 1.01 | - | 7.5 | 0.0 | 100 | 409 | 80 | 73.6 |
| 139 | 21.896 | 0.164 | 0.096 | 2.56 | 94.1 | 1.02 | - | 7.5 | 0.0 | 99 | 413 | 80 | 73.7 |
| 140 | 22.054 | 0.158 | 0.098 | 2.57 | 94.2 | 1.01 | 99 | 7.5 | 0.0 | 99 | 415 | 80 | 73.7 |
| 141 | 22.214 | 0.160 | 0.095 | 2.56 | 94.2 | 1.02 | - | 7.4 | 0.0 | 100 | 433 | 80 | 73.3 |
| 142 | 22.376 | 0.162 | 0.096 | 2.56 | 94.2 | 1.02 | - | 7.4 | -0.1 | 100 | 442 | 80 | 73.2 |
| 143 | 22.533 | 0.157 | 0.096 | 2.57 | 94.3 | 1.01 | - | 7.3 | 0.0 | 100 | 442 | 80 | 73.7 |
| 144 | 22.697 | 0.164 | 0.099 | 2.56 | 94.3 | 1.01 | - | 7.3 | 0.0 | 100 | 438 | 80 | 73.6 |
| 145 | 22.854 | 0.157 | 0.098 | 2.57 | 94.3 | 1.01 | - | 7.3 | 0.0 | 100 | 439 | 80 | 73.4 |
| 146 | 23.016 | 0.162 | 0.099 | 2.57 | 94.4 | 1 | - | 7.2 | 0.0 | 100 | 442 | 80 | 73.6 |
| 147 | 23.179 | 0.163 | 0.096 | 2.57 | 94.4 | 1.04 | - | 7.2 | -0.1 | 101 | 450 | 80 | 73.4 |
| 148 | 23.335 | 0.156 | 0.095 | 2.57 | 94.5 | 1 | - | 7.2 | 0.0 | 101 | 466 | 80 | 73.4 |
| 149 | 23.499 | 0.164 | 0.093 | 2.56 | 94.5 | 1.01 | - | 7.1 | -0.1 | 101 | 471 | 80 | 73.3 |
| 150 | 23.656 | 0.157 | 0.095 | 2.57 | 94.6 | 1.03 | 100 | 7.1 | 0.0 | 101 | 460 | 80 | 73.7 |
| 151 | 23.818 | 0.162 | 0.096 | 2.56 | 94.6 | 1.01 | - | 7.0 | 0.0 | 102 | 475 | 80 | 73.6 |
| 152 | 23.980 | 0.162 | 0.098 | 2.57 | 94.6 | 1.02 | - | 7.0 | 0.0 | 102 | 463 | 80 | 73.5 |
| 153 | 24.136 | 0.156 | 0.095 | 2.56 | 94.6 | 1.01 | - | 7.0 | 0.0 | 101 | 459 | 80 | 73.8 |
| 154 | 24.301 | 0.165 | 0.096 | 2.56 | 94.7 | 1.03 | - | 6.9 | -0.1 | 101 | 452 | 80 | 73.8 |
| 155 | 24.458 | 0.157 | 0.097 | 2.58 | 94.7 | 1.02 | - | 6.9 | -0.1 | 101 | 432 | 80 | 73.5 |
| 156 | 24.620 | 0.162 | 0.096 | 2.56 | 94.7 | 1.01 | - | 6.9 | 0.0 | 100 | 416 | 80 | 73.4 |
| 157 | 24.781 | 0.161 | 0.095 | 2.57 | 94.7 | 1.01 | - | 6.8 | -0.1 | 101 | 429 | 80 | 73.6 |
| 158 | 24.939 | 0.158 | 0.095 | 2.57 | 94.8 | 1.02 | - | 6.7 | -0.1 | 102 | 492 | 80 | 73.5 |
| 159 | 25.103 | 0.164 | 0.094 | 2.57 | 94.8 | 1.02 | - | 6.7 | -0.1 | 102 | 489 | 80 | 73.4 |
| 160 | 25.260 | 0.157 | 0.092 | 2.57 | 94.9 | 1.03 | 102 | 6.6 | -0.1 | 101 | 481 | 80 | 73.8 |
| 161 | 25.422 | 0.162 | 0.095 | 2.56 | 94.8 | 1.06 | - | 6.6 | 0.0 | 102 | 479 | 80 | 73.7 |
| 162 | 25.584 | 0.162 | 0.097 | 2.58 | 94.9 | 1.01 | - | 6.6 | 0.0 | 102 | 468 | 80 | 73.8 |
| 163 | 25.742 | 0.158 | 0.098 | 2.56 | 94.9 | 0.99 | - | 6.5 | 0.0 | 101 | 449 | 80 | 73.8 |
| 164 | 25.904 | 0.162 | 0.098 | 2.57 | 94.9 | 1.03 | - | 6.5 | 0.0 | 101 | 440 | 80 | 74 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 165 | 26.063 | 0.159 | 0.098 | 2.56 | 94.9 | 0.99 | - | 6.5 | 0.0 | 102 | 477 | 80 | 73.5 |
| 166 | 26.224 | 0.161 | 0.097 | 2.57 | 95 | 1.03 | - | 6.4 | 0.0 | 102 | 480 | 80 | 73.3 |
| 167 | 26.386 | 0.162 | 0.097 | 2.59 | 95.1 | 1.03 | - | 6.4 | 0.0 | 102 | 458 | 80 | 73.4 |
| 168 | 26.544 | 0.158 | 0.098 | 2.57 | 95 | 1.02 | - | 6.4 | 0.0 | 101 | 448 | 80 | 73.7 |
| 169 | 26.706 | 0.162 | 0.097 | 2.58 | 95.1 | 1.03 | - | 6.3 | -0.1 | 101 | 470 | 80 | 73.8 |
| 170 | 26.867 | 0.161 | 0.096 | 2.57 | 95.1 | 1 | 101 | 6.3 | 0.0 | 102 | 484 | 80 | 73.6 |
| 171 | 27.026 | 0.159 | 0.095 | 2.58 | 95.1 | 1.01 | - | 6.2 | 0.0 | 102 | 486 | 80 | 73.9 |
| 172 | 27.188 | 0.162 | 0.096 | 2.56 | 95.2 | 1.02 | - | 6.1 | -0.1 | 103 | 494 | 80 | 73.5 |
| 173 | 27.347 | 0.159 | 0.097 | 2.57 | 95.2 | 1.04 | - | 6.1 | 0.0 | 103 | 500 | 80 | 73.3 |
| 174 | 27.508 | 0.161 | 0.093 | 2.57 | 95.3 | 1.02 | - | 6.0 | -0.1 | 104 | 505 | 80 | 73.7 |
| 175 | 27.670 | 0.162 | 0.099 | 2.57 | 95.3 | 1.03 | - | 6.0 | 0.0 | 104 | 486 | 80 | 73.8 |
| 176 | 27.827 | 0.157 | 0.098 | 2.57 | 95.3 | 1.02 | - | 6.0 | 0.0 | 103 | 454 | 80 | 74.1 |
| 177 | 27.992 | 0.165 | 0.096 | 2.56 | 95.3 | 1.02 | - | 5.9 | 0.0 | 103 | 449 | 80 | 74.1 |
| 178 | 28.150 | 0.158 | 0.099 | 2.56 | 95.4 | 1.01 | - | 5.9 | 0.0 | 102 | 433 | 80 | 74.3 |
| 179 | 28.310 | 0.160 | 0.098 | 2.56 | 95.4 | 1.03 | - | 5.9 | 0.0 | 101 | 424 | 80 | 74.2 |
| 180 | 28.473 | 0.163 | 0.098 | 2.56 | 95.4 | 1.01 | 100 | 5.8 | 0.0 | 101 | 438 | 80 | 74.5 |
| 181 | 28.630 | 0.157 | 0.095 | 2.57 | 95.4 | 1.02 | - | 5.8 | 0.0 | 102 | 455 | 80 | 74.3 |
| 182 | 28.795 | 0.165 | 0.095 | 2.56 | 95.5 | 1.01 | - | 5.8 | 0.0 | 101 | 451 | 80 | 74 |
| 183 | 28.951 | 0.156 | 0.095 | 2.58 | 95.5 | 1.02 | - | 5.7 | 0.0 | 101 | 437 | 80 | 74 |
| 184 | 29.114 | 0.163 | 0.096 | 2.56 | 95.5 | 1.03 | - | 5.7 | 0.0 | 101 | 441 | 80 | 73.8 |
| 185 | 29.276 | 0.162 | 0.096 | 2.57 | 95.5 | 1.01 | - | 5.7 | 0.0 | 100 | 425 | 80 | 73.9 |
| 186 | 29.433 | 0.157 | 0.097 | 2.56 | 95.6 | 1.04 | - | 5.6 | 0.0 | 100 | 411 | 80 | 73.9 |
| 187 | 29.597 | 0.164 | 0.094 | 2.56 | 95.6 | 1.04 | - | 5.6 | -0.1 | 99 | 415 | 80 | 74.3 |
| 188 | 29.755 | 0.158 | 0.096 | 2.58 | 95.6 | 1.02 | - | 5.6 | 0.0 | 99 | 402 | 80 | 74.3 |
| 189 | 29.917 | 0.162 | 0.098 | 2.57 | 95.6 | 1.02 | - | 5.5 | 0.0 | 98 | 402 | 80 | 74 |
| 190 | 30.078 | 0.161 | 0.097 | 2.56 | 95.6 | 1.03 | 99 | 5.5 | 0.0 | 99 | 422 | 80 | 74 |
| 191 | 30.236 | 0.158 | 0.097 | 2.56 | 95.6 | 1.02 | - | 5.4 | -0.1 | 99 | 427 | 80 | 74.2 |
| 192 | 30.400 | 0.164 | 0.094 | 2.57 | 95.6 | 1.02 | - | 5.4 | 0.0 | 98 | 425 | 80 | 74.4 |
| 193 | 30.558 | 0.158 | 0.098 | 2.56 | 95.7 | 1.02 | - | 5.4 | 0.0 | 98 | 420 | 80 | 74.5 |
| 194 | 30.719 | 0.161 | 0.096 | 2.57 | 95.7 | 1 | - | 5.3 | 0.0 | 98 | 422 | 80 | 74.3 |
| 195 | 30.881 | 0.162 | 0.095 | 2.58 | 95.7 | 1.04 | - | 5.3 | 0.0 | 97 | 400 | 80 | 74.4 |
| 196 | 31.040 | 0.159 | 0.098 | 2.56 | 95.7 | 1.03 | - | 5.2 | -0.1 | 98 | 446 | 80 | 74.2 |
| 197 | 31.201 | 0.161 | 0.096 | 2.56 | 95.7 | 1.03 | - | 5.2 | -0.1 | 99 | 471 | 80 | 74 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 198 | 31.362 | 0.161 | 0.097 | 2.55 | 95.8 | 0.99 | - | 5.1 | 0.0 | 100 | 479 | 80 | 74.2 |
| 199 | 31.522 | 0.160 | 0.097 | 2.57 | 95.8 | 1.02 | - | 5.1 | -0.1 | 100 | 468 | 80 | 74.1 |
| 200 | 31.683 | 0.161 | 0.098 | 2.56 | 95.8 | 1.02 | 99 | 5.1 | 0.0 | 100 | 446 | 80 | 74.1 |
| 201 | 31.842 | 0.159 | 0.095 | 2.55 | 95.9 | 1.05 | - | 5.0 | 0.0 | 99 | 429 | 80 | 74.2 |
| 202 | 32.004 | 0.162 | 0.097 | 2.57 | 95.9 | 1.01 | - | 5.0 | 0.0 | 99 | 420 | 80 | 74.3 |
| 203 | 32.165 | 0.161 | 0.098 | 2.56 | 95.9 | 1.02 | - | 4.9 | 0.0 | 99 | 409 | 80 | 74.1 |
| 204 | 32.323 | 0.158 | 0.097 | 2.56 | 95.9 | 1.03 | - | 4.9 | 0.0 | 98 | 404 | 80 | 74.4 |
| 205 | 32.486 | 0.163 | 0.094 | 2.56 | 96 | 1.02 | - | 4.9 | 0.0 | 98 | 399 | 80 | 74.2 |
| 206 | 32.645 | 0.159 | 0.094 | 2.56 | 96 | 1.02 | - | 4.9 | 0.0 | 98 | 403 | 80 | 74.2 |
| 207 | 32.806 | 0.161 | 0.096 | 2.56 | 95.9 | 1.03 | - | 4.8 | -0.1 | 99 | 429 | 80 | 74.4 |
| 208 | 32.968 | 0.162 | 0.098 | 2.56 | 96 | 1.04 | - | 4.8 | 0.0 | 98 | 424 | 80 | 74.4 |
| 209 | 33.125 | 0.157 | 0.098 | 2.57 | 96 | 1.01 | - | 4.7 | 0.0 | 97 | 403 | 80 | 74.4 |
| 210 | 33.289 | 0.164 | 0.097 | 2.56 | 96 | 1.02 | 99 | 4.7 | 0.0 | 97 | 395 | 80 | 74.4 |
| 211 | 33.447 | 0.158 | 0.097 | 2.57 | 96 | 1.01 | - | 4.7 | 0.0 | 97 | 401 | 80 | 74.3 |
| 212 | 33.608 | 0.161 | 0.099 | 2.56 | 96 | 1.03 | - | 4.6 | -0.1 | 98 | 412 | 80 | 74.4 |
| 213 | 33.771 | 0.163 | 0.100 | 2.57 | 96 | 1.04 | - | 4.6 | 0.0 | 98 | 401 | 80 | 74.4 |
| 214 | 33.927 | 0.156 | 0.097 | 2.56 | 96 | 1.02 | - | 4.6 | -0.1 | 98 | 401 | 80 | 74.3 |
| 215 | 34.092 | 0.165 | 0.091 | 2.56 | 96 | 1.03 | - | 4.5 | 0.0 | 98 | 401 | 80 | 74.5 |
| 216 | 34.249 | 0.157 | 0.095 | 2.57 | 96 | 1.02 | - | 4.5 | -0.1 | 98 | 407 | 80 | 74.5 |
| 217 | 34.411 | 0.162 | 0.098 | 2.55 | 96 | 1.02 | - | 4.4 | 0.0 | 99 | 413 | 80 | 74.3 |
| 218 | 34.573 | 0.162 | 0.094 | 2.57 | 96 | 1.03 | - | 4.4 | 0.0 | 99 | 406 | 80 | 74.4 |
| 219 | 34.730 | 0.157 | 0.096 | 2.55 | 96.1 | 1.04 | - | 4.4 | -0.1 | 98 | 395 | 80 | 74.5 |
| 220 | 34.894 | 0.164 | 0.094 | 2.55 | 96 | 1.01 | 100 | 4.3 | 0.0 | 97 | 388 | 80 | 74.6 |
| 221 | 35.052 | 0.158 | 0.094 | 2.57 | 96.1 | 1.03 | - | 4.3 | 0.0 | 96 | 384 | 80 | 74.5 |
| 222 | 35.213 | 0.161 | 0.099 | 2.56 | 96.1 | 1.03 | - | 4.3 | 0.0 | 97 | 399 | 80 | 74.4 |
| 223 | 35.374 | 0.161 | 0.095 | 2.56 | 96.1 | 1.01 | - | 4.2 | 0.0 | 97 | 403 | 80 | 74.3 |
| 224 | 35.533 | 0.159 | 0.099 | 2.55 | 96.1 | 1.04 | - | 4.2 | 0.0 | 97 | 403 | 80 | 74.4 |
| 225 | 35.696 | 0.163 | 0.096 | 2.55 | 96.1 | 1.04 | - | 4.2 | 0.0 | 97 | 408 | 80 | 74.6 |
| 226 | 35.854 | 0.158 | 0.098 | 2.56 | 96.2 | 1.04 | - | 4.2 | 0.0 | 96 | 411 | 80 | 74.6 |
| 227 | 36.015 | 0.161 | 0.098 | 2.55 | 96.2 | 1.03 | - | 4.1 | 0.0 | 96 | 401 | 80 | 74.5 |
| 228 | 36.177 | 0.162 | 0.097 | 2.57 | 96.2 | 1.04 | - | 4.1 | 0.0 | 96 | 395 | 80 | 74.4 |
| 229 | 36.336 | 0.159 | 0.097 | 2.56 | 96.2 | 1.02 | - | 4.1 | 0.0 | 96 | 397 | 80 | 74.3 |
| 230 | 36.497 | 0.161 | 0.094 | 2.56 | 96.2 | 1.03 | 101 | 4.0 | 0.0 | 97 | 419 | 80 | 74.2 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 231 | 36.658 | 0.161 | 0.098 | 2.55 | 96.2 | 1.03 | - | 4.0 | 0.0 | 96 | 404 | 80 | 74.3 |
| 232 | 36.818 | 0.160 | 0.099 | 2.56 | 96.3 | 1.02 | - | 4.0 | 0.0 | 96 | 382 | 80 | 74.2 |
| 233 | 36.980 | 0.162 | 0.095 | 2.56 | 96.3 | 1.03 | - | 3.9 | -0.1 | 96 | 395 | 80 | 74 |
| 234 | 37.139 | 0.159 | 0.095 | 2.55 | 96.4 | 1.03 | - | 3.9 | 0.0 | 97 | 403 | 80 | 74 |
| 235 | 37.300 | 0.161 | 0.096 | 2.58 | 96.4 | 1.03 | - | 3.9 | 0.0 | 97 | 411 | 80 | 74.2 |
| 236 | 37.462 | 0.162 | 0.096 | 2.56 | 96.4 | 1.04 | - | 3.8 | 0.0 | 97 | 411 | 80 | 74.1 |
| 237 | 37.619 | 0.157 | 0.098 | 2.55 | 96.4 | 1.03 | - | 3.8 | 0.0 | 97 | 415 | 80 | 74.3 |
| 238 | 37.783 | 0.164 | 0.094 | 2.56 | 96.5 | 1.03 | - | 3.7 | -0.1 | 97 | 406 | 80 | 74.1 |
| 239 | 37.942 | 0.159 | 0.097 | 2.55 | 96.4 | 1.02 | - | 3.7 | 0.0 | 97 | 411 | 80 | 74.2 |
| 240 | 38.102 | 0.160 | 0.099 | 2.56 | 96.4 | 1.04 | 99 | 3.7 | 0.0 | 97 | 404 | 80 | 74.3 |
| 241 | 38.265 | 0.163 | 0.096 | 2.55 | 96.5 | 1.04 | - | 3.6 | -0.1 | 97 | 410 | 80 | 74.5 |
| 242 | 38.422 | 0.157 | 0.098 | 2.57 | 96.5 | 1.04 | - | 3.6 | 0.0 | 97 | 409 | 80 | 74.4 |
| 243 | 38.586 | 0.164 | 0.098 | 2.56 | 96.5 | 1.01 | - | 3.6 | 0.0 | 97 | 409 | 80 | 74.7 |
| 244 | 38.743 | 0.157 | 0.097 | 2.56 | 96.5 | 1.01 | - | 3.6 | 0.0 | 97 | 402 | 80 | 74.8 |
| 245 | 38.905 | 0.162 | 0.096 | 2.55 | 96.5 | 1.03 | - | 3.5 | -0.1 | 98 | 405 | 80 | 74.6 |
| 246 | 39.068 | 0.163 | 0.097 | 2.56 | 96.5 | 1.03 | - | 3.5 | 0.0 | 98 | 406 | 80 | 74.7 |
| 247 | 39.224 | 0.156 | 0.098 | 2.56 | 96.5 | 1.04 | - | 3.5 | 0.0 | 97 | 391 | 80 | 74.8 |
| 248 | 39.389 | 0.165 | 0.099 | 2.55 | 96.6 | 1.03 | - | 3.4 | 0.0 | 97 | 384 | 80 | 74.8 |
| 249 | 39.546 | 0.157 | 0.098 | 2.56 | 96.6 | 1.05 | - | 3.4 | 0.0 | 97 | 405 | 80 | 74.7 |
| 250 | 39.708 | 0.162 | 0.096 | 2.55 | 96.6 | 1.05 | 99 | 3.3 | 0.0 | 98 | 419 | 80 | 74.4 |
| 251 | 39.870 | 0.162 | 0.090 | 2.56 | 96.6 | 1.03 | - | 3.3 | -0.1 | 97 | 428 | 80 | 74.7 |
| 252 | 40.027 | 0.157 | 0.098 | 2.55 | 96.6 | 1.05 | - | 3.3 | 0.0 | 98 | 423 | 80 | 74.7 |
| 253 | 40.192 | 0.165 | 0.095 | 2.57 | 96.6 | 1.04 | - | 3.2 | 0.0 | 97 | 400 | 80 | 74.8 |
| 254 | 40.349 | 0.157 | 0.099 | 2.56 | 96.6 | 1.03 | - | 3.2 | 0.0 | 96 | 391 | 80 | 74.8 |
| 255 | 40.510 | 0.161 | 0.095 | 2.55 | 96.7 | 1.03 | - | 3.2 | 0.0 | 96 | 400 | 80 | 74.8 |
| 256 | 40.672 | 0.162 | 0.094 | 2.57 | 96.7 | 1.04 | - | 3.2 | 0.0 | 97 | 407 | 80 | 74.8 |
| 257 | 40.830 | 0.158 | 0.097 | 2.55 | 96.7 | 1.03 | - | 3.1 | 0.0 | 97 | 401 | 80 | 74.7 |
| 258 | 40.993 | 0.163 | 0.097 | 2.56 | 96.7 | 1.03 | - | 3.1 | 0.0 | 97 | 382 | 80 | 75 |
| 259 | 41.152 | 0.159 | 0.097 | 2.55 | 96.7 | 1.03 | - | 3.1 | 0.0 | 96 | 386 | 80 | 74.9 |
| 260 | 41.313 | 0.161 | 0.098 | 2.55 | 96.7 | 1.04 | 99 | 3.0 | -0.1 | 97 | 408 | 80 | 75 |
| 261 | 41.474 | 0.161 | 0.099 | 2.57 | 96.8 | 1.05 | - | 3.0 | 0.0 | 97 | 409 | 80 | 75.1 |
| 262 | 41.633 | 0.159 | 0.096 | 2.56 | 96.8 | 1.05 | - | 2.9 | 0.0 | 97 | 402 | 80 | 75.1 |
| 263 | 41.794 | 0.161 | 0.099 | 2.56 | 96.8 | 1.04 | - | 2.9 | 0.0 | 97 | 421 | 80 | 74.9 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 264 | 41.955 | 0.161 | 0.098 | 2.55 | 96.8 | 1.06 | - | 2.9 | 0.0 | 97 | 418 | 80 | 75 |
| 265 | 42.115 | 0.160 | 0.096 | 2.56 | 96.9 | 1.06 | - | 2.8 | 0.0 | 97 | 405 | 80 | 74.9 |
| 266 | 42.277 | 0.162 | 0.097 | 2.55 | 96.8 | 1.04 | - | 2.8 | 0.0 | 97 | 405 | 80 | 74.8 |
| 267 | 42.436 | 0.159 | 0.097 | 2.55 | 96.9 | 1.06 | - | 2.8 | 0.0 | 97 | 397 | 80 | 74.8 |
| 268 | 42.597 | 0.161 | 0.098 | 2.56 | 96.9 | 1.04 | - | 2.8 | 0.0 | 97 | 383 | 80 | 74.6 |
| 269 | 42.759 | 0.162 | 0.097 | 2.55 | 96.9 | 1.03 | - | 2.7 | 0.0 | 96 | 370 | 80 | 75 |
| 270 | 42.916 | 0.157 | 0.098 | 2.55 | 96.9 | 1.05 | 98 | 2.7 | 0.0 | 96 | 362 | 80 | 75 |
| 271 | 43.081 | 0.165 | 0.097 | 2.56 | 96.9 | 1.05 | - | 2.7 | 0.0 | 95 | 346 | 80 | 75.1 |
| 272 | 43.239 | 0.158 | 0.096 | 2.56 | 96.9 | 1.06 | - | 2.7 | 0.0 | 95 | 341 | 80 | 75 |
| 273 | 43.400 | 0.161 | 0.096 | 2.56 | 96.9 | 1.03 | - | 2.6 | 0.0 | 94 | 348 | 80 | 75.1 |
| 274 | 43.563 | 0.163 | 0.094 | 2.56 | 96.9 | 1.03 | - | 2.6 | 0.0 | 95 | 362 | 80 | 74.6 |
| 275 | 43.720 | 0.157 | 0.094 | 2.56 | 97 | 1.04 | - | 2.6 | 0.0 | 96 | 388 | 80 | 74.8 |
| 276 | 43.885 | 0.165 | 0.098 | 2.55 | 96.9 | 1.04 | - | 2.5 | 0.0 | 96 | 384 | 80 | 75 |
| 277 | 44.041 | 0.156 | 0.096 | 2.56 | 96.9 | 1.03 | - | 2.5 | -0.1 | 96 | 384 | 80 | 75 |
| 278 | 44.204 | 0.163 | 0.095 | 2.55 | 97 | 1.05 | - | 2.4 | 0.0 | 94 | 374 | 80 | 75 |
| 279 | 44.366 | 0.162 | 0.093 | 2.56 | 97 | 1.04 | - | 2.4 | 0.0 | 94 | 366 | 80 | 75 |
| 280 | 44.523 | 0.157 | 0.091 | 2.56 | 97 | 1.04 | 100 | 2.4 | 0.0 | 94 | 364 | 80 | 75.1 |
| 281 | 44.688 | 0.165 | 0.094 | 2.55 | 97 | 1.03 | - | 2.3 | 0.0 | 95 | 385 | 80 | 75.1 |
| 282 | 44.846 | 0.158 | 0.098 | 2.56 | 96.9 | 1.04 | - | 2.3 | 0.0 | 95 | 399 | 80 | 75.2 |
| 283 | 45.007 | 0.161 | 0.097 | 2.56 | 97 | 1.03 | - | 2.3 | 0.0 | 96 | 389 | 80 | 75.2 |
| 284 | 45.169 | 0.162 | 0.098 | 2.56 | 97 | 1.04 | - | 2.3 | 0.0 | 95 | 403 | 80 | 75.1 |
| 285 | 45.327 | 0.158 | 0.098 | 2.55 | 97 | 1.05 | - | 2.3 | 0.0 | 96 | 403 | 80 | 75.1 |
| 286 | 45.490 | 0.163 | 0.099 | 2.56 | 97 | 1.05 | - | 2.2 | 0.0 | 95 | 394 | 80 | 74.9 |
| 287 | 45.649 | 0.159 | 0.099 | 2.55 | 97 | 1.05 | - | 2.2 | 0.0 | 94 | 381 | 80 | 75 |
| 288 | 45.811 | 0.162 | 0.096 | 2.55 | 97 | 1.05 | - | 2.1 | 0.0 | 95 | 370 | 80 | 75 |
| 289 | 45.972 | 0.161 | 0.093 | 2.56 | 97.1 | 1.03 | - | 2.1 | 0.0 | 95 | 353 | 80 | 74.8 |
| 290 | 46.131 | 0.159 | 0.095 | 2.55 | 97.1 | 1.03 | 101 | 2.1 | 0.0 | 94 | 328 | 80 | 74.7 |
| 291 | 46.292 | 0.161 | 0.095 | 2.56 | 97.1 | 1.03 | - | 2.1 | 0.0 | 94 | 335 | 80 | 74.8 |
| 292 | 46.454 | 0.162 | 0.097 | 2.55 | 97.1 | 1.03 | - | 2.0 | 0.0 | 94 | 347 | 80 | 74.9 |
| 293 | 46.612 | 0.158 | 0.098 | 2.56 | 97.1 | 1.04 | - | 2.0 | -0.1 | 95 | 392 | 80 | 74.9 |
| 294 | 46.775 | 0.163 | 0.098 | 2.55 | 97.1 | 1.06 | - | 1.9 | -0.1 | 96 | 415 | 80 | 75 |
| 295 | 46.934 | 0.159 | 0.096 | 2.55 | 97.1 | 1.03 | - | 1.9 | 0.0 | 97 | 433 | 80 | 75 |
| 296 | 47.095 | 0.161 | 0.096 | 2.56 | 97.2 | 1.06 | - | 1.9 | 0.0 | 98 | 415 | 80 | 75.2 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 297 | 47.257 | 0.162 | 0.097 | 2.55 | 97.2 | 1.05 | - | 1.8 | 0.0 | 97 | 388 | 81 | 75.2 |
| 298 | 47.414 | 0.157 | 0.094 | 2.56 | 97.2 | 1.04 | - | 1.8 | 0.0 | 96 | 378 | 80 | 75.1 |
| 299 | 47.579 | 0.165 | 0.099 | 2.54 | 97.2 | 1.05 | - | 1.8 | 0.0 | 96 | 381 | 80 | 75.3 |
| 300 | 47.737 | 0.158 | 0.096 | 2.57 | 97.2 | 1.07 | 100 | 1.8 | 0.0 | 95 | 358 | 80 | 75.3 |
| 301 | 47.898 | 0.161 | 0.096 | 2.56 | 97.2 | 1.05 | - | 1.7 | 0.0 | 95 | 366 | 80 | 75.1 |
| 302 | 48.061 | 0.163 | 0.098 | 2.55 | 97.2 | 1.05 | - | 1.7 | 0.0 | 95 | 376 | 80 | 75.2 |
| 303 | 48.218 | 0.157 | 0.095 | 2.56 | 97.2 | 1.06 | - | 1.7 | -0.1 | 95 | 380 | 80 | 75.2 |
| 304 | 48.382 | 0.164 | 0.092 | 2.55 | 97.3 | 1.05 | - | 1.6 | 0.0 | 96 | 390 | 80 | 75.3 |
| 305 | 48.540 | 0.158 | 0.091 | 2.56 | 97.3 | 1.06 | - | 1.6 | 0.0 | 95 | 381 | 80 | 75.2 |
| 306 | 48.702 | 0.162 | 0.097 | 2.56 | 97.3 | 1.04 | - | 1.6 | 0.0 | 94 | 366 | 80 | 75.4 |
| 307 | 48.864 | 0.162 | 0.098 | 2.56 | 97.3 | 1.05 | - | 1.6 | 0.0 | 95 | 362 | 80 | 75.2 |
| 308 | 49.021 | 0.157 | 0.096 | 2.55 | 97.4 | 1.04 | - | 1.5 | -0.1 | 95 | 359 | 80 | 75.3 |
| 309 | 49.186 | 0.165 | 0.097 | 2.56 | 97.3 | 1.05 | - | 1.5 | 0.0 | 95 | 352 | 80 | 75.2 |
| 310 | 49.343 | 0.157 | 0.095 | 2.56 | 97.4 | 1.04 | 100 | 1.4 | 0.0 | 95 | 367 | 80 | 75.5 |
| 311 | 49.505 | 0.162 | 0.099 | 2.55 | 97.4 | 1.07 | - | 1.4 | 0.0 | 95 | 387 | 80 | 75.5 |
| 312 | 49.667 | 0.162 | 0.096 | 2.56 | 97.4 | 1.04 | - | 1.4 | 0.0 | 96 | 405 | 81 | 75.4 |
| 313 | 49.825 | 0.158 | 0.098 | 2.56 | 97.5 | 1.04 | - | 1.3 | 0.0 | 96 | 406 | 81 | 75.4 |
| 314 | 49.988 | 0.163 | 0.100 | 2.55 | 97.5 | 1.05 | - | 1.3 | 0.0 | 96 | 406 | 81 | 75.6 |
| 315 | 50.147 | 0.159 | 0.098 | 2.54 | 97.5 | 1.05 | - | 1.3 | 0.0 | 96 | 408 | 81 | 75.6 |
| 316 | 50.308 | 0.161 | 0.099 | 2.56 | 97.5 | 1.05 | - | 1.2 | -0.1 | 96 | 400 | 81 | 75.7 |
| 317 | 50.470 | 0.162 | 0.098 | 2.55 | 97.6 | 1.04 | - | 1.2 | 0.0 | 96 | 388 | 81 | 75.8 |
| 318 | 50.628 | 0.158 | 0.098 | 2.55 | 97.6 | 1.03 | - | 1.2 | 0.0 | 95 | 375 | 81 | 75.6 |
| 319 | 50.790 | 0.162 | 0.095 | 2.57 | 97.6 | 1.05 | - | 1.2 | 0.0 | 95 | 366 | 81 | 75.5 |
| 320 | 50.952 | 0.162 | 0.095 | 2.55 | 97.6 | 1.07 | 100 | 1.1 | -0.1 | 94 | 354 | 80 | 75.6 |
| 321 | 51.110 | 0.158 | 0.098 | 2.55 | 97.6 | 1.05 | - | 1.1 | 0.0 | 94 | 347 | 80 | 75.3 |
| 322 | 51.273 | 0.163 | 0.095 | 2.55 | 97.6 | 1.05 | - | 1.1 | 0.0 | 94 | 347 | 80 | 75.5 |
| 323 | 51.432 | 0.159 | 0.097 | 2.55 | 97.7 | 1.06 | - | 1.1 | 0.0 | 94 | 350 | 81 | 75.7 |
| 324 | 51.593 | 0.161 | 0.098 | 2.56 | 97.7 | 1.05 | - | 1.0 | 0.0 | 94 | 361 | 81 | 75.5 |
| 325 | 51.755 | 0.162 | 0.098 | 2.54 | 97.7 | 1.05 | - | 1.0 | 0.0 | 94 | 367 | 80 | 75.6 |
| 326 | 51.913 | 0.158 | 0.096 | 2.56 | 97.7 | 1.05 | - | 1.0 | 0.0 | 94 | 366 | 80 | 75.5 |
| 327 | 52.077 | 0.164 | 0.089 | 2.55 | 97.7 | 1.05 | - | 0.9 | 0.0 | 94 | 369 | 80 | 75.2 |
| 328 | 52.234 | 0.157 | 0.099 | 2.56 | 97.7 | 1.06 | - | 0.9 | 0.0 | 93 | 371 | 80 | 75.5 |
| 329 | 52.396 | 0.162 | 0.097 | 2.55 | 97.7 | 1.04 | - | 0.9 | -0.1 | 94 | 403 | 80 | 75.5 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 330 | 52.559 | 0.163 | 0.098 | 2.55 | 97.7 | 1.07 | 99 | 0.8 | 0.0 | 95 | 411 | 80 | 75.7 |
| 331 | 52.715 | 0.156 | 0.096 | 2.55 | 97.8 | 1.06 | - | 0.8 | -0.1 | 95 | 397 | 80 | 75.7 |
| 332 | 52.880 | 0.165 | 0.093 | 2.54 | 97.8 | 1.03 | - | 0.8 | 0.0 | 95 | 381 | 80 | 75.8 |
| 333 | 53.038 | 0.158 | 0.098 | 2.56 | 97.8 | 1.05 | - | 0.7 | 0.0 | 95 | 407 | 81 | 75.6 |
| 334 | 53.199 | 0.161 | 0.096 | 2.55 | 97.8 | 1.05 | - | 0.7 | 0.0 | 96 | 409 | 81 | 75.7 |
| 335 | 53.361 | 0.162 | 0.099 | 2.55 | 97.8 | 1.07 | - | 0.7 | -0.1 | 97 | 397 | 81 | 75.7 |
| 336 | 53.519 | 0.158 | 0.095 | 2.54 | 97.8 | 1.04 | - | 0.6 | 0.0 | 95 | 381 | 81 | 75.8 |
| 337 | 53.683 | 0.164 | 0.097 | 2.55 | 97.8 | 1.05 | - | 0.6 | 0.0 | 95 | 375 | 81 | 75.5 |
| 338 | 53.841 | 0.158 | 0.095 | 2.55 | 97.8 | 1.06 | - | 0.6 | -0.1 | 94 | 362 | 81 | 75.8 |
| 339 | 54.002 | 0.161 | 0.094 | 2.54 | 97.8 | 1.06 | - | 0.5 | 0.0 | 95 | 361 | 81 | 75.6 |
| 340 | 54.164 | 0.162 | 0.099 | 2.55 | 97.8 | 1.06 | 98 | 0.5 | 0.0 | 95 | 361 | 81 | 75.6 |
| 341 | 54.323 | 0.159 | 0.098 | 2.55 | 97.8 | 1.05 | - | 0.5 | 0.0 | 95 | 368 | 81 | 75.8 |
| 342 | 54.485 | 0.162 | 0.098 | 2.55 | 97.8 | 1.06 | - | 0.5 | 0.0 | 96 | 400 | 81 | 75.8 |
| 343 | 54.645 | 0.160 | 0.098 | 2.55 | 97.8 | 1.05 | - | 0.4 | -0.1 | 95 | 381 | 81 | 75.7 |
| 344 | 54.805 | 0.160 | 0.098 | 2.54 | 97.8 | 1.06 | - | 0.4 | 0.0 | 95 | 359 | 81 | 75.8 |
| 345 | 54.967 | 0.162 | 0.098 | 2.55 | 97.8 | 1.07 | - | 0.4 | 0.0 | 94 | 340 | 81 | 75.8 |
| 346 | 55.126 | 0.159 | 0.093 | 2.54 | 97.8 | 1.04 | - | 0.3 | 0.0 | 93 | 328 | 81 | 75.7 |
| 347 | 55.288 | 0.162 | 0.096 | 2.56 | 97.8 | 1.04 | - | 0.3 | 0.0 | 93 | 325 | 81 | 75.6 |
| 348 | 55.449 | 0.161 | 0.093 | 2.54 | 97.8 | 1.08 | - | 0.3 | 0.0 | 94 | 336 | 81 | 75.6 |
| 349 | 55.607 | 0.158 | 0.098 | 2.55 | 97.9 | 1.06 | - | 0.3 | 0.0 | 93 | 334 | 81 | 75.5 |
| 350 | 55.771 | 0.164 | 0.099 | 2.55 | 97.8 | 1.05 | 98 | 0.3 | 0.0 | 94 | 334 | 81 | 75.6 |
| 351 | 55.929 | 0.158 | 0.096 | 2.55 | 97.9 | 1.06 | - | 0.2 | 0.0 | 94 | 347 | 81 | 75.9 |
| 352 | 56.090 | 0.161 | 0.097 | 2.55 | 97.8 | 1.05 | - | 0.2 | 0.0 | 94 | 361 | 81 | 75.7 |
| 353 | 56.253 | 0.163 | 0.098 | 2.55 | 97.9 | 1.03 | - | 0.2 | 0.0 | 95 | 357 | 81 | 76 |
| 354 | 56.410 | 0.157 | 0.098 | 2.55 | 97.9 | 1.06 | - | 0.1 | -0.1 | 94 | 355 | 81 | 76 |
| 355 | 56.575 | 0.165 | 0.094 | 2.54 | 97.9 | 1.04 | - | 0.1 | 0.0 | 93 | 353 | 81 | 76 |
| 356 | 56.732 | 0.157 | 0.092 | 2.56 | 97.9 | 1.05 | - | 0.1 | 0.0 | 93 | 357 | 81 | 76 |
| 357 | 56.894 | 0.162 | 0.096 | 2.55 | 98 | 1.06 | - | 0.1 | 0.0 | 93 | 347 | 81 | 75.9 |
| 358 | 57.057 | 0.163 | 0.100 | 2.55 | 98 | 1.04 | - | 0.0 | 0.0 | 92 | 342 | 80 | 75.8 |
| 359 | 57.213 | 0.156 | 0.098 | 2.54 | 98 | 1.06 | - | 0.0 | 0.0 | 93 | 351 | 80 | 75.8 |
| 360 | 57.378 | 0.165 | 0.098 | 2.55 | 98 | 1.04 | 98 | 0.0 | 0.0 | 92 | 347 | 80 | 75.8 |
| Avg/Tot | 57.378 | 0.159 | 0.096 | 2.53 | 93 | 1.00 | 100 | | | 103 | 471 | 80 | 74 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 0 | 0.000 | | 0.01 | 76.6 | 0.69 | | 74 | -0.099 | 9.33 | 0.09 |
| 1 | 0.116 | 0.116 | 2.44 | 76.4 | 1.75 | - | 77 | -0.100 | 11.91 | 0.05 |
| 2 | 0.267 | 0.151 | 2.45 | 76.4 | 1.91 | - | 78 | -0.104 | 14.11 | 0.03 |
| 3 | 0.422 | 0.155 | 2.45 | 76.5 | 1.55 | - | 79 | -0.102 | 13.59 | 0.04 |
| 4 | 0.572 | 0.150 | 2.45 | 76.5 | 2.07 | - | 79 | -0.103 | 13.38 | 0.04 |
| 5 | 0.728 | 0.156 | 2.46 | 76.5 | 1.94 | - | 80 | -0.104 | 12.50 | 0.04 |
| 6 | 0.879 | 0.151 | 2.46 | 76.6 | 2 | - | 80 | -0.100 | 11.74 | 0.08 |
| 7 | 1.035 | 0.156 | 2.46 | 76.7 | 1.78 | - | 81 | -0.103 | 16.10 | 0.03 |
| 8 | 1.185 | 0.150 | 2.45 | 76.9 | 1.64 | - | 81 | -0.103 | 17.61 | 0.02 |
| 9 | 1.339 | 0.154 | 2.46 | 76.9 | 1.81 | - | 81 | -0.100 | 15.47 | 0.04 |
| 10 | 1.491 | 0.152 | 2.45 | 77.1 | 1.61 | 100 | 81 | -0.104 | 13.74 | 0.04 |
| 11 | 1.645 | 0.154 | 2.45 | 77.3 | 1.83 | - | 82 | -0.103 | 16.12 | 0.02 |
| 12 | 1.799 | 0.154 | 2.45 | 77.5 | 1.92 | - | 82 | -0.099 | 12.58 | 0.04 |
| 13 | 1.952 | 0.153 | 2.46 | 77.7 | 1.6 | - | 82 | -0.101 | 14.60 | 0.04 |
| 14 | 2.106 | 0.154 | 2.45 | 77.9 | 1.77 | - | 82 | -0.101 | 12.67 | 0.05 |
| 15 | 2.257 | 0.151 | 2.45 | 78.3 | 1.6 | - | 82 | -0.099 | 12.31 | 0.04 |
| 16 | 2.413 | 0.156 | 2.46 | 78.4 | 2.12 | - | 82 | -0.103 | 12.54 | 0.04 |
| 17 | 2.564 | 0.151 | 2.46 | 78.7 | 1.57 | - | 82 | -0.105 | 13.76 | 0.02 |
| 18 | 2.721 | 0.157 | 2.46 | 79 | 1.62 | - | 83 | -0.105 | 12.58 | 0.03 |
| 19 | 2.871 | 0.150 | 2.46 | 79.2 | 1.79 | - | 83 | -0.104 | 13.60 | 0.02 |
| 20 | 3.026 | 0.155 | 2.46 | 79.4 | 1.57 | 102 | 83 | -0.105 | 15.25 | 0.04 |
| 21 | 3.180 | 0.154 | 2.46 | 79.8 | 1.95 | - | 83 | -0.099 | 10.80 | 0.05 |
| 22 | 3.335 | 0.155 | 2.46 | 80.1 | 1.6 | - | 83 | -0.100 | 12.03 | 0.04 |
| 23 | 3.490 | 0.155 | 2.47 | 80.4 | 1.94 | - | 83 | -0.099 | 11.21 | 0.05 |
| 24 | 3.642 | 0.152 | 2.46 | 80.6 | 1.96 | - | 83 | -0.101 | 11.45 | 0.03 |
| 25 | 3.798 | 0.156 | 2.46 | 81 | 1.81 | - | 83 | -0.106 | 12.22 | 0.03 |
| 26 | 3.951 | 0.153 | 2.47 | 81.3 | 1.84 | - | 83 | -0.103 | 14.14 | 0.03 |
| 27 | 4.108 | 0.157 | 2.47 | 81.6 | 1.81 | - | 83 | -0.105 | 13.17 | 0.03 |
| 28 | 4.259 | 0.151 | 2.47 | 81.9 | 2.14 | - | 84 | -0.102 | 11.71 | 0.03 |
| 29 | 4.415 | 0.156 | 2.46 | 82.2 | 1.79 | - | 84 | -0.102 | 11.84 | 0.04 |
| 30 | 4.570 | 0.155 | 2.48 | 82.5 | 1.95 | 103 | 84 | -0.098 | 11.00 | 0.04 |
| 31 | 4.725 | 0.155 | 2.47 | 82.8 | 1.7 | - | 84 | -0.105 | 16.56 | 0.06 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 32 | 4.881 | 0.156 | 2.47 | 83.1 | 1.58 | - | 84 | -0.107 | 16.32 | 0.04 |
| 33 | 5.033 | 0.152 | 2.46 | 83.5 | 2.11 | - | 84 | -0.110 | 15.62 | 0.03 |
| 34 | 5.191 | 0.158 | 2.47 | 83.7 | 1.64 | - | 84 | -0.107 | 14.81 | 0.04 |
| 35 | 5.344 | 0.153 | 2.48 | 84.1 | 2.12 | - | 84 | -0.106 | 13.36 | 0.03 |
| 36 | 5.500 | 0.156 | 2.47 | 84.3 | 2.11 | - | 84 | -0.105 | 14.50 | 0.03 |
| 37 | 5.654 | 0.154 | 2.47 | 84.7 | 1.57 | - | 84 | -0.106 | 13.32 | 0.04 |
| 38 | 5.811 | 0.157 | 2.47 | 84.9 | 1.62 | - | 84 | -0.105 | 12.70 | 0.04 |
| 39 | 5.968 | 0.157 | 2.48 | 85.2 | 2.09 | - | 84 | -0.101 | 11.60 | 0.04 |
| 40 | 6.121 | 0.153 | 2.48 | 85.5 | 2.09 | 103 | 84 | -0.103 | 9.34 | 0.07 |
| 41 | 6.279 | 0.158 | 2.48 | 85.8 | 1.66 | - | 84 | -0.099 | 11.30 | 0.05 |
| 42 | 6.432 | 0.153 | 2.47 | 86.2 | 1.66 | - | 84 | -0.102 | 11.21 | 0.05 |
| 43 | 6.590 | 0.158 | 2.48 | 86.5 | 2.1 | - | 84 | -0.104 | 11.53 | 0.04 |
| 44 | 6.743 | 0.153 | 2.47 | 86.7 | 1.58 | - | 84 | -0.104 | 10.61 | 0.05 |
| 45 | 6.901 | 0.158 | 2.48 | 87 | 1.88 | - | 84 | -0.101 | 11.96 | 0.04 |
| 46 | 7.058 | 0.157 | 2.49 | 87.3 | 2.01 | - | 84 | -0.102 | 10.99 | 0.04 |
| 47 | 7.212 | 0.154 | 2.48 | 87.6 | 1.6 | - | 84 | -0.103 | 11.36 | 0.04 |
| 48 | 7.370 | 0.158 | 2.49 | 87.9 | 2 | - | 84 | -0.105 | 12.37 | 0.03 |
| 49 | 7.524 | 0.154 | 2.48 | 88.1 | 1.62 | - | 84 | -0.101 | 12.42 | 0.03 |
| 50 | 7.681 | 0.157 | 2.48 | 88.4 | 1.78 | 102 | 84 | -0.099 | 10.19 | 0.08 |
| 51 | 7.836 | 0.155 | 2.48 | 88.7 | 1.6 | - | 84 | -0.098 | 9.55 | 0.07 |
| 52 | 7.994 | 0.158 | 2.49 | 88.9 | 1.84 | - | 84 | -0.097 | 10.43 | 0.04 |
| 53 | 8.151 | 0.157 | 2.48 | 89.1 | 1.61 | - | 84 | -0.097 | 10.74 | 0.05 |
| 54 | 8.305 | 0.154 | 2.48 | 89.4 | 1.89 | - | 84 | -0.102 | 12.71 | 0.06 |
| 55 | 8.465 | 0.160 | 2.49 | 89.6 | 1.68 | - | 84 | -0.086 | 9.04 | 0.12 |
| 56 | 8.619 | 0.154 | 2.48 | 89.9 | 1.62 | - | 84 | -0.109 | 19.08 | 0.84 |
| 57 | 8.776 | 0.157 | 2.47 | 90.1 | 1.63 | - | 84 | -0.109 | 14.93 | 0.03 |
| 58 | 8.933 | 0.157 | 2.47 | 90.3 | 1.65 | - | 84 | -0.101 | 16.41 | 0.05 |
| 59 | 9.089 | 0.156 | 2.47 | 90.6 | 1.99 | - | 84 | -0.101 | 11.21 | 0.05 |
| 60 | 9.247 | 0.158 | 2.48 | 90.8 | 1.67 | 102 | 84 | -0.099 | 12.22 | 0.03 |
| 61 | 9.401 | 0.154 | 2.48 | 91.1 | 1.6 | - | 84 | -0.102 | 10.76 | 0.04 |
| 62 | 9.561 | 0.160 | 2.48 | 91.2 | 1.7 | - | 84 | -0.099 | 13.22 | 0.03 |
| 63 | 9.714 | 0.153 | 2.47 | 91.4 | 1.85 | - | 84 | -0.101 | 11.47 | 0.05 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 64 | 9.872 | 0.158 | 2.48 | 91.7 | 2.12 | - | 83 | -0.102 | 12.83 | 0.03 |
| 65 | 10.030 | 0.158 | 2.48 | 91.9 | 1.81 | - | 84 | -0.101 | 11.73 | 0.03 |
| 66 | 10.185 | 0.155 | 2.47 | 92.1 | 1.71 | - | 83 | -0.100 | 12.84 | 0.02 |
| 67 | 10.344 | 0.159 | 2.48 | 92.3 | 2.09 | - | 84 | -0.101 | 13.16 | 0.03 |
| 68 | 10.499 | 0.155 | 2.48 | 92.5 | 1.98 | - | 83 | -0.097 | 12.87 | 0.02 |
| 69 | 10.657 | 0.158 | 2.48 | 92.7 | 1.92 | - | 83 | -0.102 | 12.65 | 0.03 |
| 70 | 10.813 | 0.156 | 2.48 | 92.9 | 1.77 | 102 | 83 | -0.098 | 10.66 | 0.05 |
| 71 | 10.971 | 0.158 | 2.48 | 93.1 | 2.04 | - | 83 | -0.095 | 8.88 | 0.08 |
| 72 | 11.129 | 0.158 | 2.48 | 93.2 | 2.15 | - | 83 | -0.100 | 9.33 | 0.07 |
| 73 | 11.284 | 0.155 | 2.48 | 93.4 | 2.06 | - | 83 | -0.097 | 10.43 | 0.07 |
| 74 | 11.444 | 0.160 | 2.48 | 93.6 | 1.59 | - | 83 | -0.099 | 13.27 | 0.02 |
| 75 | 11.599 | 0.155 | 2.48 | 93.8 | 1.58 | - | 83 | -0.100 | 11.04 | 0.03 |
| 76 | 11.757 | 0.158 | 2.48 | 94 | 2.03 | - | 83 | -0.096 | 10.13 | 0.04 |
| 77 | 11.916 | 0.159 | 2.48 | 94.1 | 1.76 | - | 83 | -0.096 | 9.08 | 0.09 |
| 78 | 12.070 | 0.154 | 2.48 | 94.3 | 1.66 | - | 83 | -0.098 | 8.90 | 0.06 |
| 79 | 12.231 | 0.161 | 2.49 | 94.5 | 2.05 | - | 83 | -0.099 | 11.13 | 0.04 |
| 80 | 12.386 | 0.155 | 2.48 | 94.7 | 1.84 | 102 | 83 | -0.101 | 12.61 | 0.02 |
| 81 | 12.544 | 0.158 | 2.48 | 94.8 | 1.92 | - | 83 | -0.098 | 11.72 | 0.03 |
| 82 | 12.702 | 0.158 | 2.48 | 95 | 1.66 | - | 83 | -0.099 | 13.14 | 0.03 |
| 83 | 12.858 | 0.156 | 2.48 | 95.1 | 1.64 | - | 83 | -0.089 | 10.02 | 0.04 |
| 84 | 13.017 | 0.159 | 2.47 | 95.3 | 1.66 | - | 83 | -0.086 | 6.02 | 0.16 |
| 85 | 13.173 | 0.156 | 2.47 | 95.4 | 1.82 | - | 83 | -0.099 | 6.99 | 0.13 |
| 86 | 13.332 | 0.159 | 2.47 | 95.6 | 1.84 | - | 83 | -0.101 | 18.00 | 0.71 |
| 87 | 13.488 | 0.156 | 2.48 | 95.7 | 1.66 | - | 83 | -0.098 | 13.80 | 0.04 |
| 88 | 13.646 | 0.158 | 2.47 | 95.9 | 1.97 | - | 83 | -0.098 | 13.47 | 0.03 |
| 89 | 13.805 | 0.159 | 2.47 | 96 | 2.07 | - | 83 | -0.104 | 14.01 | 0.03 |
| 90 | 13.957 | 0.152 | 2.47 | 96.1 | 1.64 | 102 | 83 | -0.100 | 16.19 | 0.07 |
| 91 | 14.117 | 0.160 | 2.48 | 96.2 | 1.99 | - | 83 | -0.099 | 14.94 | 0.10 |
| 92 | 14.271 | 0.154 | 2.48 | 96.4 | 2.06 | - | 83 | -0.102 | 12.84 | 0.02 |
| 93 | 14.430 | 0.159 | 2.47 | 96.4 | 1.74 | - | 83 | -0.102 | 13.27 | 0.04 |
| 94 | 14.588 | 0.158 | 2.48 | 96.6 | 1.62 | - | 83 | -0.099 | 11.40 | 0.04 |
| 95 | 14.743 | 0.155 | 2.47 | 96.7 | 1.85 | - | 83 | -0.102 | 11.31 | 0.05 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 96 | 14.903 | 0.160 | 2.48 | 96.9 | 1.73 | - | 83 | -0.101 | 13.18 | 0.03 |
| 97 | 15.058 | 0.155 | 2.48 | 97 | 2.13 | - | 83 | -0.098 | 11.91 | 0.04 |
| 98 | 15.217 | 0.159 | 2.47 | 97.1 | 2.05 | - | 83 | -0.096 | 12.89 | 0.03 |
| 99 | 15.374 | 0.157 | 2.47 | 97.2 | 1.66 | - | 83 | -0.095 | 11.23 | 0.03 |
| 100 | 15.531 | 0.157 | 2.47 | 97.3 | 2.11 | 101 | 83 | -0.097 | 11.66 | 0.06 |
| 101 | 15.689 | 0.158 | 2.47 | 97.4 | 1.64 | - | 83 | -0.094 | 10.03 | 0.06 |
| 102 | 15.846 | 0.157 | 2.47 | 97.5 | 2.09 | - | 83 | -0.093 | 9.24 | 0.08 |
| 103 | 16.005 | 0.159 | 2.47 | 97.7 | 2 | - | 83 | -0.094 | 9.51 | 0.08 |
| 104 | 16.160 | 0.155 | 2.47 | 97.8 | 1.76 | - | 83 | -0.092 | 9.99 | 0.10 |
| 105 | 16.319 | 0.159 | 2.47 | 97.8 | 2.09 | - | 83 | -0.093 | 9.29 | 0.09 |
| 106 | 16.477 | 0.158 | 2.47 | 97.9 | 1.84 | - | 83 | -0.096 | 10.45 | 0.05 |
| 107 | 16.633 | 0.156 | 2.47 | 98 | 1.73 | - | 83 | -0.095 | 11.58 | 0.03 |
| 108 | 16.794 | 0.161 | 2.48 | 98.1 | 2.09 | - | 83 | -0.093 | 10.53 | 0.05 |
| 109 | 16.949 | 0.155 | 2.47 | 98.2 | 1.75 | - | 83 | -0.095 | 10.10 | 0.04 |
| 110 | 17.108 | 0.159 | 2.47 | 98.2 | 1.72 | 101 | 82 | -0.094 | 9.55 | 0.06 |
| 111 | 17.267 | 0.159 | 2.48 | 98.4 | 1.75 | - | 82 | -0.089 | 8.81 | 0.07 |
| 112 | 17.422 | 0.155 | 2.47 | 98.4 | 1.71 | - | 82 | -0.092 | 9.24 | 0.06 |
| 113 | 17.583 | 0.161 | 2.48 | 98.6 | 2.12 | - | 82 | -0.093 | 10.85 | 0.06 |
| 114 | 17.738 | 0.155 | 2.47 | 98.5 | 1.65 | - | 82 | -0.093 | 10.58 | 0.05 |
| 115 | 17.897 | 0.159 | 2.48 | 98.7 | 2.06 | - | 82 | -0.091 | 10.28 | 0.08 |
| 116 | 18.055 | 0.158 | 2.47 | 98.7 | 1.75 | - | 82 | -0.090 | 10.27 | 0.05 |
| 117 | 18.212 | 0.157 | 2.48 | 98.8 | 2.14 | - | 82 | -0.095 | 9.80 | 0.08 |
| 118 | 18.372 | 0.160 | 2.47 | 98.9 | 2.02 | - | 82 | -0.092 | 9.22 | 0.07 |
| 119 | 18.528 | 0.156 | 2.48 | 98.9 | 1.61 | - | 82 | -0.090 | 8.26 | 0.10 |
| 120 | 18.687 | 0.159 | 2.48 | 99 | 2.01 | 100 | 82 | -0.089 | 7.70 | 0.11 |
| 121 | 18.845 | 0.158 | 2.48 | 99.1 | 2.02 | - | 82 | -0.091 | 7.36 | 0.11 |
| 122 | 19.002 | 0.157 | 2.48 | 99.1 | 1.64 | - | 82 | -0.089 | 7.36 | 0.13 |
| 123 | 19.161 | 0.159 | 2.47 | 99.2 | 1.78 | - | 82 | -0.093 | 9.20 | 0.07 |
| 124 | 19.317 | 0.156 | 2.47 | 99.2 | 1.93 | - | 82 | -0.093 | 8.99 | 0.06 |
| 125 | 19.477 | 0.160 | 2.48 | 99.3 | 1.81 | - | 82 | -0.093 | 9.11 | 0.06 |
| 126 | 19.634 | 0.157 | 2.47 | 99.4 | 2.13 | - | 82 | -0.088 | 9.25 | 0.06 |
| 127 | 19.793 | 0.159 | 2.47 | 99.4 | 1.67 | - | 82 | -0.086 | 7.93 | 0.12 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 128 | 19.951 | 0.158 | 2.47 | 99.4 | 1.85 | - | 82 | -0.089 | 9.16 | 0.06 |
| 129 | 20.107 | 0.156 | 2.47 | 99.5 | 2.06 | - | 82 | -0.089 | 9.20 | 0.06 |
| 130 | 20.267 | 0.160 | 2.47 | 99.6 | 1.69 | 100 | 82 | -0.084 | 7.13 | 0.14 |
| 131 | 20.423 | 0.156 | 2.47 | 99.6 | 1.86 | - | 82 | -0.081 | 7.03 | 0.13 |
| 132 | 20.583 | 0.160 | 2.47 | 99.6 | 2.04 | - | 82 | -0.081 | 6.56 | 0.14 |
| 133 | 20.741 | 0.158 | 2.48 | 99.8 | 1.68 | - | 82 | -0.077 | 6.01 | 0.15 |
| 134 | 20.898 | 0.157 | 2.47 | 99.8 | 1.92 | - | 82 | -0.081 | 6.29 | 0.11 |
| 135 | 21.059 | 0.161 | 2.48 | 99.9 | 1.89 | - | 82 | -0.082 | 7.53 | 0.09 |
| 136 | 21.214 | 0.155 | 2.48 | 99.9 | 1.69 | - | 82 | -0.081 | 6.49 | 0.14 |
| 137 | 21.374 | 0.160 | 2.47 | 99.8 | 1.84 | - | 82 | -0.083 | 7.81 | 0.09 |
| 138 | 21.532 | 0.158 | 2.47 | 100 | 1.68 | - | 82 | -0.079 | 6.74 | 0.16 |
| 139 | 21.688 | 0.156 | 2.47 | 100 | 2.05 | - | 81 | -0.081 | 6.26 | 0.16 |
| 140 | 21.850 | 0.162 | 2.47 | 100 | 1.75 | 99 | 81 | -0.081 | 6.65 | 0.15 |
| 141 | 22.005 | 0.155 | 2.47 | 100 | 1.71 | - | 81 | -0.086 | 7.52 | 0.10 |
| 142 | 22.165 | 0.160 | 2.47 | 100.1 | 2.12 | - | 81 | -0.084 | 8.08 | 0.09 |
| 143 | 22.323 | 0.158 | 2.48 | 100.2 | 1.87 | - | 81 | -0.086 | 7.18 | 0.15 |
| 144 | 22.479 | 0.156 | 2.47 | 100.2 | 2.14 | - | 81 | -0.084 | 7.16 | 0.12 |
| 145 | 22.640 | 0.161 | 2.47 | 100.3 | 2.03 | - | 81 | -0.086 | 6.78 | 0.15 |
| 146 | 22.795 | 0.155 | 2.48 | 100.3 | 1.94 | - | 81 | -0.088 | 6.75 | 0.13 |
| 147 | 22.955 | 0.160 | 2.47 | 100.4 | 1.61 | - | 81 | -0.088 | 7.11 | 0.11 |
| 148 | 23.115 | 0.160 | 2.48 | 100.3 | 1.8 | - | 81 | -0.092 | 7.42 | 0.13 |
| 149 | 23.270 | 0.155 | 2.47 | 100.3 | 1.78 | - | 81 | -0.086 | 8.66 | 0.10 |
| 150 | 23.432 | 0.162 | 2.48 | 100.4 | 1.61 | 100 | 81 | -0.087 | 7.36 | 0.12 |
| 151 | 23.587 | 0.155 | 2.47 | 100.5 | 1.79 | - | 81 | -0.090 | 7.84 | 0.11 |
| 152 | 23.746 | 0.159 | 2.48 | 100.5 | 1.67 | - | 82 | -0.084 | 8.13 | 0.11 |
| 153 | 23.906 | 0.160 | 2.48 | 100.5 | 1.74 | - | 81 | -0.087 | 7.68 | 0.09 |
| 154 | 24.062 | 0.156 | 2.48 | 100.6 | 2.15 | - | 81 | -0.082 | 7.86 | 0.07 |
| 155 | 24.223 | 0.161 | 2.47 | 100.6 | 1.66 | - | 81 | -0.081 | 6.44 | 0.15 |
| 156 | 24.379 | 0.156 | 2.48 | 100.6 | 1.64 | - | 81 | -0.082 | 6.18 | 0.13 |
| 157 | 24.538 | 0.159 | 2.47 | 100.6 | 2.13 | - | 81 | -0.087 | 6.15 | 0.14 |
| 158 | 24.697 | 0.159 | 2.47 | 100.7 | 1.64 | - | 81 | -0.092 | 11.04 | 0.05 |
| 159 | 24.854 | 0.157 | 2.48 | 100.7 | 1.95 | - | 82 | -0.091 | 9.27 | 0.08 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 160 | 25.014 | 0.160 | 2.47 | 100.8 | 1.63 | 101 | 81 | -0.089 | 9.34 | 0.07 |
| 161 | 25.171 | 0.157 | 2.48 | 100.9 | 2.09 | - | 81 | -0.089 | 9.35 | 0.08 |
| 162 | 25.329 | 0.158 | 2.47 | 100.9 | 2.13 | - | 82 | -0.085 | 7.96 | 0.12 |
| 163 | 25.488 | 0.159 | 2.48 | 100.8 | 1.61 | - | 82 | -0.083 | 8.00 | 0.10 |
| 164 | 25.645 | 0.157 | 2.47 | 101 | 1.64 | - | 81 | -0.086 | 7.46 | 0.12 |
| 165 | 25.806 | 0.161 | 2.48 | 100.9 | 1.66 | - | 81 | -0.092 | 8.57 | 0.08 |
| 166 | 25.962 | 0.156 | 2.48 | 100.9 | 1.66 | - | 82 | -0.090 | 7.90 | 0.12 |
| 167 | 26.121 | 0.159 | 2.48 | 100.9 | 1.83 | - | 82 | -0.084 | 6.74 | 0.15 |
| 168 | 26.280 | 0.159 | 2.47 | 101 | 1.82 | - | 82 | -0.084 | 6.30 | 0.13 |
| 169 | 26.437 | 0.157 | 2.47 | 101 | 1.72 | - | 81 | -0.088 | 8.70 | 0.11 |
| 170 | 26.596 | 0.159 | 2.48 | 101.1 | 2.06 | 101 | 81 | -0.089 | 9.22 | 0.09 |
| 171 | 26.753 | 0.157 | 2.47 | 101 | 2.1 | - | 81 | -0.094 | 8.47 | 0.09 |
| 172 | 26.913 | 0.160 | 2.47 | 101 | 2.13 | - | 82 | -0.090 | 10.98 | 0.04 |
| 173 | 27.070 | 0.157 | 2.47 | 101 | 2.11 | - | 82 | -0.088 | 10.41 | 0.05 |
| 174 | 27.229 | 0.159 | 2.47 | 101.1 | 2.09 | - | 82 | -0.093 | 9.89 | 0.05 |
| 175 | 27.387 | 0.158 | 2.47 | 101.1 | 2.05 | - | 82 | -0.087 | 8.22 | 0.09 |
| 176 | 27.544 | 0.157 | 2.47 | 101.2 | 2.02 | - | 82 | -0.083 | 6.43 | 0.12 |
| 177 | 27.704 | 0.160 | 2.48 | 101.2 | 1.64 | - | 82 | -0.085 | 6.60 | 0.12 |
| 178 | 27.862 | 0.158 | 2.47 | 101.2 | 1.96 | - | 82 | -0.084 | 6.43 | 0.11 |
| 179 | 28.021 | 0.159 | 2.47 | 101.2 | 2.14 | - | 82 | -0.083 | 6.67 | 0.11 |
| 180 | 28.179 | 0.158 | 2.47 | 101.2 | 2.1 | 99 | 82 | -0.084 | 6.93 | 0.10 |
| 181 | 28.336 | 0.157 | 2.47 | 101.3 | 1.79 | - | 82 | -0.088 | 8.37 | 0.08 |
| 182 | 28.496 | 0.160 | 2.47 | 101.2 | 1.79 | - | 82 | -0.084 | 8.40 | 0.08 |
| 183 | 28.652 | 0.156 | 2.47 | 101.2 | 2.13 | - | 82 | -0.082 | 7.81 | 0.12 |
| 184 | 28.812 | 0.160 | 2.47 | 101.3 | 1.63 | - | 82 | -0.084 | 8.02 | 0.08 |
| 185 | 28.971 | 0.159 | 2.47 | 101.3 | 2.05 | - | 82 | -0.080 | 7.22 | 0.07 |
| 186 | 29.128 | 0.157 | 2.47 | 101.3 | 1.9 | - | 82 | -0.080 | 7.39 | 0.06 |
| 187 | 29.288 | 0.160 | 2.48 | 101.4 | 1.81 | - | 82 | -0.082 | 7.76 | 0.07 |
| 188 | 29.444 | 0.156 | 2.46 | 101.3 | 2.13 | - | 82 | -0.079 | 7.09 | 0.09 |
| 189 | 29.604 | 0.160 | 2.47 | 101.3 | 1.65 | - | 82 | -0.080 | 9.17 | 0.07 |
| 190 | 29.762 | 0.158 | 2.47 | 101.4 | 2.1 | 99 | 82 | -0.085 | 9.48 | 0.08 |
| 191 | 29.919 | 0.157 | 2.47 | 101.4 | 1.67 | - | 82 | -0.083 | 8.99 | 0.07 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 192 | 30.080 | 0.161 | 2.47 | 101.5 | 1.83 | - | 82 | -0.083 | 7.89 | 0.09 |
| 193 | 30.235 | 0.155 | 2.47 | 101.4 | 2.14 | - | 82 | -0.083 | 8.56 | 0.07 |
| 194 | 30.395 | 0.160 | 2.47 | 101.4 | 1.69 | - | 81 | -0.082 | 9.18 | 0.11 |
| 195 | 30.554 | 0.159 | 2.47 | 101.4 | 1.68 | - | 81 | -0.078 | 7.98 | 0.10 |
| 196 | 30.710 | 0.156 | 2.47 | 101.4 | 1.66 | - | 81 | -0.090 | 9.51 | 0.05 |
| 197 | 30.872 | 0.162 | 2.47 | 101.5 | 1.79 | - | 81 | -0.089 | 13.18 | 0.05 |
| 198 | 31.027 | 0.155 | 2.47 | 101.5 | 1.79 | - | 81 | -0.088 | 12.43 | 0.03 |
| 199 | 31.187 | 0.160 | 2.46 | 101.4 | 2.1 | - | 81 | -0.085 | 9.19 | 0.07 |
| 200 | 31.345 | 0.158 | 2.47 | 101.5 | 1.7 | 99 | 82 | -0.083 | 8.53 | 0.06 |
| 201 | 31.501 | 0.156 | 2.46 | 101.5 | 1.87 | - | 82 | -0.085 | 8.03 | 0.10 |
| 202 | 31.662 | 0.161 | 2.46 | 101.6 | 1.81 | - | 81 | -0.079 | 8.27 | 0.05 |
| 203 | 31.817 | 0.155 | 2.46 | 101.6 | 1.7 | - | 81 | -0.080 | 7.60 | 0.07 |
| 204 | 31.977 | 0.160 | 2.46 | 101.6 | 1.68 | - | 81 | -0.081 | 6.57 | 0.08 |
| 205 | 32.137 | 0.160 | 2.46 | 101.7 | 2.05 | - | 81 | -0.076 | 6.81 | 0.06 |
| 206 | 32.292 | 0.155 | 2.46 | 101.6 | 1.85 | - | 81 | -0.087 | 6.79 | 0.10 |
| 207 | 32.453 | 0.161 | 2.46 | 101.6 | 2.01 | - | 81 | -0.082 | 9.76 | 0.09 |
| 208 | 32.608 | 0.155 | 2.46 | 101.7 | 1.72 | - | 81 | -0.082 | 7.69 | 0.09 |
| 209 | 32.768 | 0.160 | 2.46 | 101.7 | 1.65 | - | 81 | -0.079 | 6.38 | 0.11 |
| 210 | 32.927 | 0.159 | 2.46 | 101.7 | 2.15 | 99 | 81 | -0.079 | 6.82 | 0.09 |
| 211 | 33.084 | 0.157 | 2.46 | 101.8 | 1.65 | - | 81 | -0.083 | 6.50 | 0.09 |
| 212 | 33.244 | 0.160 | 2.46 | 101.7 | 2.01 | - | 81 | -0.081 | 7.35 | 0.10 |
| 213 | 33.400 | 0.156 | 2.47 | 101.8 | 1.75 | - | 81 | -0.076 | 7.92 | 0.11 |
| 214 | 33.559 | 0.159 | 2.46 | 101.7 | 1.81 | - | 81 | -0.078 | 8.26 | 0.09 |
| 215 | 33.718 | 0.159 | 2.45 | 101.8 | 1.76 | - | 81 | -0.081 | 7.68 | 0.10 |
| 216 | 33.875 | 0.157 | 2.46 | 101.8 | 1.63 | - | 81 | -0.079 | 7.39 | 0.10 |
| 217 | 34.035 | 0.160 | 2.46 | 101.8 | 2.01 | - | 82 | -0.080 | 9.31 | 0.06 |
| 218 | 34.192 | 0.157 | 2.46 | 101.8 | 1.68 | - | 82 | -0.080 | 8.53 | 0.07 |
| 219 | 34.350 | 0.158 | 2.46 | 101.8 | 2.02 | - | 82 | -0.075 | 7.84 | 0.11 |
| 220 | 34.509 | 0.159 | 2.46 | 101.8 | 1.84 | 100 | 82 | -0.076 | 7.37 | 0.11 |
| 221 | 34.666 | 0.157 | 2.46 | 101.9 | 1.82 | - | 81 | -0.076 | 6.07 | 0.11 |
| 222 | 34.825 | 0.159 | 2.46 | 101.9 | 2.13 | - | 81 | -0.078 | 6.99 | 0.07 |
| 223 | 34.982 | 0.157 | 2.46 | 101.9 | 2.01 | - | 81 | -0.077 | 6.99 | 0.11 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 224 | 35.142 | 0.160 | 2.46 | 101.9 | 1.83 | - | 81 | -0.082 | 6.00 | 0.11 |
| 225 | 35.299 | 0.157 | 2.46 | 101.8 | 1.74 | - | 81 | -0.079 | 7.89 | 0.11 |
| 226 | 35.457 | 0.158 | 2.46 | 101.9 | 1.67 | - | 81 | -0.080 | 7.38 | 0.11 |
| 227 | 35.616 | 0.159 | 2.45 | 101.9 | 1.7 | - | 81 | -0.078 | 7.71 | 0.09 |
| 228 | 35.773 | 0.157 | 2.45 | 102 | 1.71 | - | 81 | -0.078 | 8.03 | 0.08 |
| 229 | 35.932 | 0.159 | 2.46 | 101.9 | 2.07 | - | 81 | -0.081 | 6.69 | 0.10 |
| 230 | 36.090 | 0.158 | 2.46 | 102 | 2.14 | 100 | 81 | -0.081 | 8.19 | 0.07 |
| 231 | 36.249 | 0.159 | 2.46 | 102 | 1.66 | - | 81 | -0.081 | 6.78 | 0.13 |
| 232 | 36.407 | 0.158 | 2.46 | 102 | 1.83 | - | 81 | -0.073 | 6.27 | 0.10 |
| 233 | 36.564 | 0.157 | 2.45 | 102 | 1.71 | - | 81 | -0.082 | 6.76 | 0.09 |
| 234 | 36.724 | 0.160 | 2.46 | 102 | 1.65 | - | 81 | -0.084 | 8.10 | 0.10 |
| 235 | 36.880 | 0.156 | 2.45 | 102 | 2.12 | - | 81 | -0.084 | 7.61 | 0.11 |
| 236 | 37.040 | 0.160 | 2.45 | 102 | 1.76 | - | 81 | -0.081 | 7.40 | 0.08 |
| 237 | 37.198 | 0.158 | 2.47 | 102 | 1.96 | - | 81 | -0.082 | 8.39 | 0.08 |
| 238 | 37.355 | 0.157 | 2.46 | 102 | 1.89 | - | 81 | -0.078 | 7.74 | 0.10 |
| 239 | 37.516 | 0.161 | 2.45 | 102 | 1.68 | - | 81 | -0.080 | 7.01 | 0.08 |
| 240 | 37.671 | 0.155 | 2.45 | 102 | 1.89 | 99 | 81 | -0.077 | 7.24 | 0.07 |
| 241 | 37.831 | 0.160 | 2.46 | 102.1 | 2.04 | - | 81 | -0.081 | 8.29 | 0.07 |
| 242 | 37.989 | 0.158 | 2.46 | 102 | 2.12 | - | 81 | -0.079 | 7.80 | 0.10 |
| 243 | 38.145 | 0.156 | 2.46 | 102.1 | 1.75 | - | 81 | -0.077 | 7.56 | 0.09 |
| 244 | 38.307 | 0.162 | 2.46 | 102 | 2.13 | - | 81 | -0.082 | 7.36 | 0.07 |
| 245 | 38.462 | 0.155 | 2.46 | 102 | 1.66 | - | 81 | -0.083 | 7.68 | 0.10 |
| 246 | 38.622 | 0.160 | 2.46 | 102.1 | 2.13 | - | 82 | -0.077 | 7.85 | 0.07 |
| 247 | 38.780 | 0.158 | 2.46 | 102.1 | 1.78 | - | 82 | -0.077 | 6.69 | 0.12 |
| 248 | 38.936 | 0.156 | 2.45 | 102.1 | 1.97 | - | 82 | -0.076 | 6.54 | 0.14 |
| 249 | 39.097 | 0.161 | 2.45 | 102.1 | 2.12 | - | 81 | -0.083 | 7.31 | 0.08 |
| 250 | 39.252 | 0.155 | 2.45 | 102.1 | 1.73 | 99 | 82 | -0.082 | 7.36 | 0.08 |
| 251 | 39.412 | 0.160 | 2.45 | 102.1 | 1.65 | - | 82 | -0.081 | 9.45 | 0.08 |
| 252 | 39.571 | 0.159 | 2.46 | 102.2 | 2.02 | - | 82 | -0.081 | 7.75 | 0.09 |
| 253 | 39.727 | 0.156 | 2.45 | 102.2 | 1.68 | - | 81 | -0.077 | 6.66 | 0.14 |
| 254 | 39.888 | 0.161 | 2.45 | 102.1 | 2.12 | - | 81 | -0.080 | 7.93 | 0.07 |
| 255 | 40.043 | 0.155 | 2.46 | 102.2 | 1.82 | - | 81 | -0.082 | 6.79 | 0.14 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 256 | 40.202 | 0.159 | 2.44 | 102.1 | 1.84 | - | 81 | -0.081 | 8.02 | 0.10 |
| 257 | 40.361 | 0.159 | 2.45 | 102.2 | 1.71 | - | 81 | -0.075 | 7.15 | 0.12 |
| 258 | 40.517 | 0.156 | 2.45 | 102.2 | 1.7 | - | 81 | -0.075 | 6.93 | 0.13 |
| 259 | 40.677 | 0.160 | 2.45 | 102.2 | 1.74 | - | 81 | -0.083 | 7.11 | 0.15 |
| 260 | 40.834 | 0.157 | 2.45 | 102.2 | 1.99 | 99 | 81 | -0.081 | 9.24 | 0.09 |
| 261 | 40.992 | 0.158 | 2.46 | 102.2 | 1.92 | - | 81 | -0.081 | 8.44 | 0.11 |
| 262 | 41.150 | 0.158 | 2.46 | 102.2 | 1.93 | - | 81 | -0.077 | 7.68 | 0.10 |
| 263 | 41.307 | 0.157 | 2.46 | 102.2 | 1.9 | - | 81 | -0.081 | 8.52 | 0.06 |
| 264 | 41.466 | 0.159 | 2.45 | 102.3 | 1.73 | - | 82 | -0.082 | 8.11 | 0.06 |
| 265 | 41.623 | 0.157 | 2.44 | 102.3 | 2.04 | - | 82 | -0.078 | 7.32 | 0.12 |
| 266 | 41.783 | 0.160 | 2.46 | 102.2 | 1.84 | - | 81 | -0.080 | 7.16 | 0.09 |
| 267 | 41.940 | 0.157 | 2.45 | 102.3 | 1.86 | - | 82 | -0.078 | 6.54 | 0.08 |
| 268 | 42.099 | 0.159 | 2.45 | 102.2 | 1.7 | - | 82 | -0.073 | 6.76 | 0.06 |
| 269 | 42.257 | 0.158 | 2.45 | 102.3 | 1.8 | - | 81 | -0.074 | 6.91 | 0.09 |
| 270 | 42.414 | 0.157 | 2.45 | 102.3 | 1.86 | 98 | 81 | -0.074 | 6.20 | 0.07 |
| 271 | 42.573 | 0.159 | 2.46 | 102.2 | 1.77 | - | 81 | -0.071 | 5.27 | 0.07 |
| 272 | 42.729 | 0.156 | 2.45 | 102.3 | 2.17 | - | 81 | -0.070 | 5.27 | 0.07 |
| 273 | 42.889 | 0.160 | 2.45 | 102.3 | 2.01 | - | 81 | -0.073 | 7.09 | 0.09 |
| 274 | 43.048 | 0.159 | 2.45 | 102.3 | 2.02 | - | 81 | -0.073 | 7.29 | 0.13 |
| 275 | 43.204 | 0.156 | 2.45 | 102.3 | 1.89 | - | 81 | -0.077 | 7.82 | 0.10 |
| 276 | 43.365 | 0.161 | 2.46 | 102.3 | 1.9 | - | 81 | -0.077 | 7.36 | 0.10 |
| 277 | 43.520 | 0.155 | 2.45 | 102.4 | 1.68 | - | 81 | -0.077 | 7.64 | 0.08 |
| 278 | 43.680 | 0.160 | 2.46 | 102.4 | 2.05 | - | 81 | -0.074 | 6.83 | 0.17 |
| 279 | 43.838 | 0.158 | 2.45 | 102.4 | 1.67 | - | 81 | -0.072 | 6.46 | 0.14 |
| 280 | 43.994 | 0.156 | 2.46 | 102.4 | 1.98 | 100 | 81 | -0.072 | 6.59 | 0.09 |
| 281 | 44.156 | 0.162 | 2.45 | 102.4 | 1.99 | - | 81 | -0.079 | 7.06 | 0.10 |
| 282 | 44.311 | 0.155 | 2.45 | 102.4 | 1.83 | - | 81 | -0.081 | 8.51 | 0.13 |
| 283 | 44.470 | 0.159 | 2.45 | 102.4 | 1.62 | - | 81 | -0.076 | 7.10 | 0.10 |
| 284 | 44.629 | 0.159 | 2.46 | 102.4 | 1.78 | - | 81 | -0.081 | 9.33 | 0.05 |
| 285 | 44.785 | 0.156 | 2.44 | 102.4 | 1.76 | - | 81 | -0.078 | 8.11 | 0.08 |
| 286 | 44.946 | 0.161 | 2.44 | 102.5 | 2.12 | - | 81 | -0.080 | 7.27 | 0.09 |
| 287 | 45.101 | 0.155 | 2.45 | 102.5 | 2.16 | - | 81 | -0.077 | 6.88 | 0.11 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 288 | 45.261 | 0.160 | 2.45 | 102.5 | 1.83 | - | 81 | -0.073 | 6.54 | 0.11 |
| 289 | 45.420 | 0.159 | 2.45 | 102.5 | 1.72 | - | 81 | -0.071 | 5.76 | 0.10 |
| 290 | 45.576 | 0.156 | 2.45 | 102.6 | 1.65 | 101 | 81 | -0.068 | 4.55 | 0.24 |
| 291 | 45.736 | 0.160 | 2.45 | 102.5 | 2.05 | - | 81 | -0.072 | 6.88 | 0.12 |
| 292 | 45.892 | 0.156 | 2.45 | 102.5 | 1.99 | - | 81 | -0.075 | 6.02 | 0.17 |
| 293 | 46.050 | 0.158 | 2.44 | 102.5 | 1.66 | - | 81 | -0.081 | 8.38 | 0.08 |
| 294 | 46.209 | 0.159 | 2.45 | 102.5 | 1.73 | - | 81 | -0.082 | 9.22 | 0.12 |
| 295 | 46.366 | 0.157 | 2.44 | 102.6 | 2.01 | - | 82 | -0.087 | 8.56 | 0.08 |
| 296 | 46.526 | 0.160 | 2.44 | 102.5 | 2.11 | - | 82 | -0.077 | 8.38 | 0.07 |
| 297 | 46.682 | 0.156 | 2.45 | 102.5 | 1.64 | - | 82 | -0.073 | 6.04 | 0.11 |
| 298 | 46.841 | 0.159 | 2.45 | 102.6 | 2.07 | - | 82 | -0.075 | 6.64 | 0.12 |
| 299 | 46.999 | 0.158 | 2.45 | 102.7 | 1.81 | - | 82 | -0.079 | 6.43 | 0.13 |
| 300 | 47.156 | 0.157 | 2.45 | 102.7 | 1.62 | 99 | 82 | -0.073 | 6.54 | 0.13 |
| 301 | 47.315 | 0.159 | 2.45 | 102.6 | 1.92 | - | 82 | -0.080 | 7.81 | 0.11 |
| 302 | 47.472 | 0.157 | 2.44 | 102.6 | 1.95 | - | 82 | -0.077 | 7.48 | 0.13 |
| 303 | 47.632 | 0.160 | 2.45 | 102.7 | 1.8 | - | 81 | -0.078 | 7.21 | 0.12 |
| 304 | 47.789 | 0.157 | 2.44 | 102.7 | 1.62 | - | 82 | -0.079 | 6.86 | 0.10 |
| 305 | 47.948 | 0.159 | 2.45 | 102.7 | 2.18 | - | 82 | -0.077 | 7.17 | 0.09 |
| 306 | 48.106 | 0.158 | 2.45 | 102.7 | 1.63 | - | 81 | -0.074 | 7.29 | 0.15 |
| 307 | 48.263 | 0.157 | 2.44 | 102.8 | 2.16 | - | 81 | -0.073 | 7.36 | 0.13 |
| 308 | 48.422 | 0.159 | 2.45 | 102.8 | 2.16 | - | 81 | -0.072 | 7.34 | 0.09 |
| 309 | 48.578 | 0.156 | 2.44 | 102.7 | 1.64 | - | 81 | -0.071 | 7.06 | 0.11 |
| 310 | 48.738 | 0.160 | 2.44 | 102.8 | 2.15 | 99 | 82 | -0.077 | 7.74 | 0.09 |
| 311 | 48.896 | 0.158 | 2.45 | 102.8 | 2.18 | - | 81 | -0.081 | 7.09 | 0.10 |
| 312 | 49.053 | 0.157 | 2.44 | 102.7 | 1.71 | - | 82 | -0.083 | 7.73 | 0.09 |
| 313 | 49.214 | 0.161 | 2.45 | 102.7 | 1.71 | - | 82 | -0.081 | 7.53 | 0.09 |
| 314 | 49.368 | 0.154 | 2.45 | 102.8 | 1.69 | - | 82 | -0.078 | 8.73 | 0.07 |
| 315 | 49.528 | 0.160 | 2.44 | 102.8 | 1.98 | - | 82 | -0.079 | 8.74 | 0.10 |
| 316 | 49.686 | 0.158 | 2.45 | 102.8 | 1.99 | - | 82 | -0.078 | 6.92 | 0.13 |
| 317 | 49.842 | 0.156 | 2.44 | 102.8 | 1.98 | - | 82 | -0.077 | 7.11 | 0.09 |
| 318 | 50.003 | 0.161 | 2.43 | 103 | 1.8 | - | 82 | -0.077 | 6.70 | 0.09 |
| 319 | 50.158 | 0.155 | 2.45 | 102.9 | 1.82 | - | 82 | -0.073 | 6.71 | 0.13 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 FabricationsJob #: 24-265Model: Mini MeTracking #: 212Run #: 2Technician: AKDate: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 320 | 50.318 | 0.160 | 2.44 | 102.9 | 1.65 | 99 | 82 | -0.072 | 6.27 | 0.13 |
| 321 | 50.477 | 0.159 | 2.44 | 103 | 2.05 | - | 82 | -0.073 | 5.84 | 0.11 |
| 322 | 50.632 | 0.155 | 2.45 | 103 | 2.07 | - | 82 | -0.070 | 5.85 | 0.13 |
| 323 | 50.793 | 0.161 | 2.44 | 103 | 2.15 | - | 82 | -0.075 | 5.92 | 0.14 |
| 324 | 50.948 | 0.155 | 2.44 | 103 | 1.77 | - | 82 | -0.077 | 6.14 | 0.08 |
| 325 | 51.107 | 0.159 | 2.44 | 103 | 2.18 | - | 82 | -0.074 | 6.01 | 0.09 |
| 326 | 51.266 | 0.159 | 2.43 | 102.9 | 1.91 | - | 81 | -0.076 | 7.57 | 0.09 |
| 327 | 51.422 | 0.156 | 2.44 | 103 | 2.13 | - | 81 | -0.077 | 6.66 | 0.15 |
| 328 | 51.583 | 0.161 | 2.44 | 102.9 | 1.71 | - | 81 | -0.079 | 6.95 | 0.19 |
| 329 | 51.739 | 0.156 | 2.44 | 103 | 1.98 | - | 81 | -0.082 | 9.14 | 0.07 |
| 330 | 51.897 | 0.158 | 2.44 | 102.9 | 2.03 | 99 | 82 | -0.078 | 8.54 | 0.10 |
| 331 | 52.055 | 0.158 | 2.44 | 103 | 2.05 | - | 82 | -0.076 | 7.16 | 0.10 |
| 332 | 52.213 | 0.158 | 2.44 | 103 | 2.08 | - | 82 | -0.076 | 6.08 | 0.12 |
| 333 | 52.371 | 0.158 | 2.44 | 103 | 1.71 | - | 82 | -0.083 | 8.46 | 0.07 |
| 334 | 52.528 | 0.157 | 2.44 | 103 | 1.93 | - | 82 | -0.080 | 7.46 | 0.16 |
| 335 | 52.687 | 0.159 | 2.44 | 102.9 | 2 | - | 82 | -0.078 | 6.83 | 0.16 |
| 336 | 52.844 | 0.157 | 2.44 | 103 | 2.11 | - | 82 | -0.075 | 7.06 | 0.10 |
| 337 | 53.003 | 0.159 | 2.44 | 103 | 1.7 | - | 82 | -0.073 | 6.92 | 0.12 |
| 338 | 53.161 | 0.158 | 2.44 | 103.1 | 1.81 | - | 82 | -0.073 | 6.79 | 0.13 |
| 339 | 53.317 | 0.156 | 2.44 | 103.1 | 1.7 | - | 82 | -0.072 | 6.16 | 0.10 |
| 340 | 53.478 | 0.161 | 2.44 | 103.1 | 1.99 | 98 | 82 | -0.071 | 6.25 | 0.10 |
| 341 | 53.633 | 0.155 | 2.43 | 103.1 | 1.96 | - | 82 | -0.078 | 7.81 | 0.11 |
| 342 | 53.792 | 0.159 | 2.44 | 103 | 2.16 | - | 82 | -0.079 | 8.76 | 0.07 |
| 343 | 53.950 | 0.158 | 2.44 | 103.1 | 1.85 | - | 82 | -0.075 | 7.26 | 0.12 |
| 344 | 54.106 | 0.156 | 2.44 | 103 | 2.09 | - | 82 | -0.072 | 6.01 | 0.10 |
| 345 | 54.267 | 0.161 | 2.44 | 103.1 | 1.66 | - | 82 | -0.068 | 5.44 | 0.09 |
| 346 | 54.423 | 0.156 | 2.44 | 103.1 | 1.68 | - | 82 | -0.068 | 5.28 | 0.10 |
| 347 | 54.582 | 0.159 | 2.44 | 103.2 | 1.86 | - | 82 | -0.071 | 5.29 | 0.08 |
| 348 | 54.741 | 0.159 | 2.44 | 103.1 | 2.12 | - | 82 | -0.072 | 6.72 | 0.15 |
| 349 | 54.896 | 0.155 | 2.44 | 103.1 | 2.04 | - | 82 | -0.071 | 5.97 | 0.18 |
| 350 | 55.057 | 0.161 | 2.44 | 103.1 | 1.91 | 97 | 82 | -0.072 | 5.83 | 0.15 |
| 351 | 55.212 | 0.155 | 2.44 | 103 | 1.98 | - | 82 | -0.075 | 6.43 | 0.10 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: 509 Fabrications
 Model: Mini Me
 Run #: 2

Job #: 24-265
 Tracking #: 212
 Technician: AK
 Date: 8/14/2024

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 352 | 55.371 | 0.159 | 2.44 | 103.1 | 1.65 | - | 82 | -0.072 | 7.10 | 0.10 |
| 353 | 55.530 | 0.159 | 2.44 | 103.2 | 1.94 | - | 82 | -0.070 | 6.52 | 0.12 |
| 354 | 55.687 | 0.157 | 2.44 | 103.2 | 1.95 | - | 82 | -0.076 | 6.62 | 0.14 |
| 355 | 55.847 | 0.160 | 2.43 | 103.2 | 1.96 | - | 82 | -0.075 | 7.47 | 0.08 |
| 356 | 56.003 | 0.156 | 2.44 | 103.3 | 1.68 | - | 82 | -0.074 | 7.08 | 0.09 |
| 357 | 56.161 | 0.158 | 2.44 | 103.3 | 1.82 | - | 82 | -0.070 | 6.02 | 0.11 |
| 358 | 56.320 | 0.159 | 2.44 | 103.3 | 2.08 | - | 82 | -0.072 | 7.21 | 0.09 |
| 359 | 56.477 | 0.157 | 2.44 | 103.3 | 2.15 | - | 82 | -0.070 | 7.42 | 0.12 |
| 360 | 56.636 | 0.159 | 2.44 | 103.3 | 1.76 | 97 | 82 | -0.072 | 6.75 | 0.14 |
| Avg/Tot | 56.636 | 0.157 | 2.46 | 98 | 1.86 | 100 | | | 9.00 | 0.09 |

LAB SAMPLE DATA - ASTM E2515

Client: 509 Fabrications
 Model: Mini Me
 Run #: 2

Job #: 24-265
 Tracking #: 212
 Technician: AK
 Date: 8/14/2024

| | | Sample ID | Tare, mg | Final, mg | Catch, mg |
|----------------|---------------------|-----------|----------|-----------|-----------|
| Filters | A | G01129 | 244.4 | 245.9 | 1.5 |
| | B | G01130 | 244.8 | 246.4 | 1.6 |
| | C - 1st Hour | G01131 | 244.6 | 245.4 | 0.8 |
| | Amb | G01132 | 243.7 | 243.8 | 0.1 |
| Probes | A | 19A | 117027.0 | 117027.0 | 0.0 |
| | B | 19B | 117014.1 | 117014.1 | 0.0 |
| | C - 1st Hour | 19C | 114231.9 | 114232.0 | 0.1 |
| | | | | | |
| O-rings | A | 19A | 3586.0 | 3586.3 | 0.3 |
| | B | 19B | 3633.1 | 3633.2 | 0.1 |
| | C - 1st Hour | 19C | 3615.3 | 3615.3 | 0.0 |
| | | | | | |

Placed in Dessicator on: 8/14/2024

Balance Audit (mg): 200.0 200.0

| | | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time | Weight (mg) | Date/Time |
|----------------|---------------------|-------------|-----------|-------------|------------|-------------|-----------|-------------|-----------|
| Filters | A | 245.9 | 8/19 9:00 | 245.9 | 8/21 14:45 | | | | |
| | B | 246.3 | 8/19 9:00 | 246.4 | 8/21 14:45 | | | | |
| | C - 1st Hour | 245.4 | 8/19 9:00 | 245.4 | 8/21 14:45 | | | | |
| | Amb | 244.0 | 8/19 9:00 | 243.8 | 8/21 14:45 | | | | |
| Probes | A | 117027.0 | 8/19 9:00 | 117027.0 | 8/21 14:45 | | | | |
| | B | 117014.2 | 8/19 9:00 | 117014.1 | 8/21 14:45 | | | | |
| | C - 1st Hour | 114232.0 | 8/19 9:00 | 114232.0 | 8/21 14:45 | | | | |
| | | | | | | | | | |
| O-Rings | A | 3586.5 | 8/19 9:00 | 3586.3 | 8/21 14:45 | | | | |
| | B | 3633.2 | 8/19 9:00 | 3633.2 | 8/21 14:45 | | | | |
| | C - 1st Hour | 3615.4 | 8/19 9:00 | 3615.3 | 8/21 14:45 | | | | |
| | | | | | | | | | |

| | |
|-------------------------------|------------|
| Train A Aggregate, mg: | 1.8 |
| Train B Aggregate, mg: | 1.7 |
| Train C Aggregate, mg: | 0.9 |
| Ambient Aggregate, mg: | 0.1 |

ASTM E2779 Wood Heater Run Sheets

Client: 509 Fabrications Job Number: 24-265 Tracking #: 212
 Model: Mini Me Run Number: 2 Test Date: 8/14/24

Pellet Heater Control Settings

High Burn Rate Settings: Fully Open
 Medium Burn Rate Settings: Open 1/16"
 Low Burn Rate Settings: Fully closed

Preburn Notes

Preburn Start Time: 08:28

| Time | Notes |
|------|--------|
| | -None- |

Test Notes

Test Burn Start Time: 09:29

| Time | Notes |
|------|--------|
| | -None- |

Test Burn End Time: 15:29


Flue Gas Concentration Measurement

Calibration Gas Values: Span Gas CO₂ (%): 16.98 CO (%): 4.300
 Mid Gas CO₂ (%): 10.00 CO (%): 2.500

Calibration Results:

| | Pre Test | | | Post Test | | |
|-----------------|----------|-------|-------|-----------|-------|-------|
| | Zero | Mid | Span | Zero | Mid | Span |
| Time | 08:56 | 08:57 | 08:58 | 15:39 | 15:40 | 15:41 |
| CO ₂ | 0.00 | 17.06 | 10.13 | -0.01 | 17.02 | 10.08 |
| CO | -0.001 | 4.315 | 2.522 | -0.004 | 4.309 | 2.502 |

Flue Gas Probe Leak Check: Initial: 0 Final: 0

Technician Signature: 

Date: 8/28/2024
Page 1 of 1

ASTM E2515 - Glass Fiber Filters

| Date: | 7/30/24 | 7/31/24 | | | | | |
|--------|----------|----------|----------|----------|---------|---------|-----|
| | Time: | 3:00 p | 4:30 | | | | |
| | Weight 1 | Weight 2 | Weigth 3 | Weight 4 | Initial | Project | Run |
| G01125 | 245.4 | 245.5 | - | - | | 24-265 | #1 |
| G01126 | 245.6 | 245.5 | - | - | | ↓ | ↓ |
| G01127 | 244.2 | 244.1 | - | - | | ↓ | ↓ |
| G01128 | 245.6 | 245.6 | - | - | | ↓ | ↓ |
| G01129 | 244.4 | 244.4 | - | - | | ↓ | #2 |
| G01130 | 244.9 | 244.8 | - | - | | ↓ | ↓ |
| G01131 | 244.8 | 244.6 | - | - | | ↓ | ↓ |
| G01132 | 243.7 | 243.7 | - | - | | ↓ | ↓ |
| G01133 | 245.4 | 245.3 | - | - | | 24-321 | #1 |
| G01134 | 245.1 | 245.2 | - | - | | ↓ | ↓ |
| G01135 | 244.3 | 244.2 | - | - | | ↓ | ↓ |
| G01136 | 244.2 | 244.0 | - | - | | ↓ | ↓ |
| G01137 | 244.0 | 243.8 | - | - | | ↓ | #2 |
| G01138 | 244.9 | 244.7 | - | - | | ↓ | ↓ |
| G01139 | 244.7 | 244.7 | - | - | | ↓ | ↓ |
| G01140 | 244.1 | 243.6 | | | | ↓ | ↓ |

| Date: | | | | | | | |
|--------|----------|----------|----------|----------|---------|---------|-----|
| | Time: | | | | | | |
| | Weight 1 | Weight 2 | Weigth 3 | Weight 4 | Initial | Project | Run |
| G01141 | | | | | | | |
| G01142 | | | | | | | |
| G01143 | | | | | | | |
| G01144 | | | | | | | |
| G01145 | | | | | | | |
| G01146 | | | | | | | |
| G01147 | | | | | | | |
| G01148 | | | | | | | |
| G01149 | | | | | | | |
| G01150 | | | | | | | |
| G01151 | | | | | | | |
| G01152 | | | | | | | |
| G01153 | | | | | | | |
| G01154 | | | | | | | |
| G01155 | | | | | | | |
| G01156 | | | | | | | |

ASTM E2515 - Probe Samples 11-20

| Date: | 6/25/24 | 6/26/24 | | | | | |
|-------|----------|----------|----------|----------|---------|---------|-----|
| Time: | 0900 | 0900 | | | | | |
| | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
| 11A | 116868.4 | 116868.6 | - | - | A | 24-309 | #4 |
| 11B | 117342.3 | 117342.4 | - | - | A | | |
| 11C | 116188.1 | 116188.2 | - | - | A | | |
| 12A | 116708.9 | 116708.9 | - | - | A | 24-309 | #3 |
| 12B | 117775.1 | 117775.2 | - | - | A | | |
| 12C | 117174.0 | 117174.1 | - | - | A | | |
| 13A | 117316.6 | 117316.8 | - | - | A | 24-309 | #5 |
| 13B | 116943.0 | 116943.1 | - | - | A | | |
| 13C | 115651.6 | 115651.4 | - | - | A | | |
| 14A | 116634.9 | 116635.1 | - | - | A | 24-330 | #1 |
| 14B | 116620.9 | 116621.1 | - | - | A | | |
| 14C | 116531.6 | 116531.6 | - | - | A | | |
| 15A | 117241.5 | 117241.5 | - | - | A | 24-330 | #2 |
| 15B | 116754.3 | 116754.2 | - | - | A | | |
| 15C | 116848.3 | 116848.3 | - | - | A | | |

| Date: | 7/30/24 | 8/1/24 | 8/2/24 | 8/3/24 | | | |
|-------|----------|----------|----------|-----------|---------|---------|-----|
| Time: | 3:30 pm | 13:30 | 15:00 | 13:30 | | | |
| | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
| 16A | 116380.1 | 116379.9 | - | - | A | 24-330 | #3 |
| 16B | 115862.7 | 115862.5 | - | - | A | | |
| 16C | 114148.1 | 114148.2 | - | - | A | | |
| 17A | 116811.0 | 116811.2 | - | - | A | 24-330 | #4 |
| 17B | 117140.9 | 117141.1 | - | - | A | | |
| 17C | 113141.3 | 113141.9 | 113141.4 | 113141.86 | A | | |
| 18A | 117501.2 | 117501.0 | - | - | A | 24-265 | #1 |
| 18B | 117333.1 | 117333.0 | - | - | A | | |
| 18C | 114335.7 | 114335.8 | - | - | A | | |
| 19A | 117027.2 | 117027.0 | - | - | A | 24-265 | #2 |
| 19B | 117014.3 | 117014.1 | - | - | A | | |
| 19C | 114231.7 | 114231.9 | - | - | A | | |
| 20A | 115628.3 | 115627.9 | 115627.8 | - | A | 24-321 | #1 |
| 20B | 115967.6 | 115967.5 | - | - | A | | |
| 20C | 113776.2 | 113776.1 | - | - | A | | |

ASTM E2515 - O-Ring Samples 11-20

| Date: | 6/25/24 | 6/26/24 | | | | | |
|-------|----------|----------|----------|----------|---------|---------|-----|
| | Time: | 09:00 | 10:00 | | | | |
| | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
| 11A | 3423.6 | 3423.5 | - | - | A | 24-309 | #3 |
| 11B | 4233.9 | 4233.9 | - | - | A | | |
| 11C | 3588.2 | 3588.3 | - | - | A | | |
| 12A | 3586.0 | 3585.9 | - | - | A | 24-309 | #4 |
| 12B | 3550.7 | 3550.8 | - | - | A | | |
| 12C | 3615.9 | 3615.9 | - | - | A | | |
| 13A | 3596.4 | 3596.5 | - | - | A | 24-309 | #5 |
| 13B | 3642.3 | 3642.3 | - | - | A | | |
| 13C | 4409.7 | 4409.7 | - | - | A | | |
| 14A | 3342.7 | 3342.7 | - | - | A | 24-330 | #1 |
| 14B | 3367.4 | 3367.4 | - | - | A | | |
| 14C | 3444.7 | 3444.7 | - | - | A | | |
| 15A | 3570.0 | 3570.0 | - | - | A | 24-330 | #12 |
| 15B | 3571.0 | 3571.1 | - | - | A | | |
| 15C | 3397.5 | 3397.5 | - | - | N | | |

| Date: | 7/30/24 | 8/1/24 | | | | | |
|-------|----------|----------|----------|----------|---------|---------|-----|
| | Time: | 3:00 pm | 13:00 | | | | |
| | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
| 16A | 3573.0 | 3573.1 | - | - | A | 24-330 | #3 |
| 16B | 3638.0 | 3638.1 | - | - | A | | |
| 16C | 3601.9 | 3601.9 | - | - | A | | |
| 17A | 3613.0 | 3612.9 | - | - | A | 24-330 | #4 |
| 17B | 3569.1 | 3569.0 | - | - | A | | |
| 17C | 3597.3 | 3597.2 | - | - | A | | |
| 18A | 3602.8 | 3602.7 | - | - | A | 24-265 | #1 |
| 18B | 3546.1 | 3546.1 | - | - | A | | |
| 18C | 3528.6 | 3528.5 | - | - | A | | |
| 19A | 3586.2 | 3586.1 | - | - | A | 24-265 | #2 |
| 19B | 3633.1 | 3633.1 | - | - | A | | |
| 19C | 3615.1 | 3615.3 | - | - | A | | |
| 20A | 3559.0 | 3558.9 | - | - | A | 24-321 | #1 |
| 20B | 3614.7 | 3614.7 | - | - | A | | |
| 20C | 3610.9 | 3611.0 | - | - | A | | |



Twin Ports Testing, Inc.
 1301 North 3rd Street
 Superior, WI 54880
 p: 715-392-7114
 p: 800-373-2562
 f: 715-392-7163
 www.twinportstesting.com

Report No: USR:W224-0189-01
Issue No: 1

Analytical Test Report

Client: PFS-TECO
 11785 SE Hwy 212, Ste 305
 Clackamas, OR 97015
Attention: Sebastian Button
PO No:

Signed: *Katy Jahr*
 Katy Jahr
 Chemistry Lab Supervisor
 Date of Issue: 5/13/2024
THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

Sample Details
Sample Log No: W224-0189-01 **Sample Date:**
Sample Designation: Lignetics Pellets (Mill # 16036) **Sample Time:**
Sample Recognized As: Wood Pellets **Arrival Date:** 4/26/2024

Test Results

| | METHOD | UNITS | MOISTURE FREE | AS RECEIVED |
|-----------------------------------|------------|----------|---------------|-------------|
| Moisture Total | ASTM E871 | wt. % | | 2.10 |
| Ash | ASTM D1102 | wt. % | 0.17 | 0.17 |
| Volatile Matter | ASTM D3175 | wt. % | 80.51 | 78.82 |
| Fixed Carbon by Difference | ASTM D3172 | wt. % | 19.31 | 18.91 |
| Sulfur | ASTM D4239 | wt. % | 0.070 | 0.069 |
| SO ₂ | Calculated | lb/mmbtu | | 0.163 |
| Net Cal. Value at Const. Pressure | ISO 1928 | GJ/tonne | 18.71 | 18.27 |
| Gross Cal. Value at Const. Vol. | ASTM E711 | Btu/lb | 8627 | 8445 |
| Carbon | ASTM D5373 | wt. % | 49.48 | 48.44 |
| Hydrogen* | ASTM D5373 | wt. % | 6.22 | 6.09 |
| Nitrogen | ASTM D5373 | wt. % | < 0.20 | < 0.20 |
| Oxygen* | ASTM D3176 | wt. % | > 43.86 | > 42.94 |

*Note: As received values do not include hydrogen and oxygen in the total moisture.

| | | | | |
|--------------------------------|--------------|---------------------|--|----|
| Chlorine | ASTM D6721 | mg/kg | | |
| Fluorine | ASTM D3761 | mg/kg | | |
| Mercury | ASTM D6722 | mg/kg | | |
| Bulk Density | ASTM E873 | lbs/ft ³ | | |
| Fines (Less than 1/8") | TPT CH-P-06 | wt. % | | |
| Durability Index | Kansas State | PDI | | |
| Sample Above 1.50" | TPT CH-P-06 | wt. % | | |
| Maximum Length (Single Pellet) | TPT CH-P-06 | inch | | |
| Diameter, Range | TPT CH-P-05 | inch | | to |
| Diameter, Average | TPT CH-P-05 | inch | | |
| Stated Bag Weight | TPT CH-P-01 | lbs | | |
| Actual Bag Weight | TPT CH-P-01 | lbs | | |

Comments:



Accreditation #60243

Results issued on this report only reflect the analysis of the sample submitted. Our reports and letters are for the exclusive and confidential use of our clients and may not be reproduced, except in their entirety, without the written approval of Twin Ports Testing. Twin Ports Testing Laboratory is accredited to the ISO/IEC 17025:2017 standard by PJLA.

John D. Hudson

| Elapsed Time (hrs) | Fine (°F) | Catalyst Exit (°F) | Notes: Indicate initial air setting and any changes in in setting during conditioning, as well as weight and average moisture content of all fuel additions. |
|--------------------|-----------|--------------------|--|
| 0 | 55 | N/A | |
| 1 | 888 | N/A | 6/5/2024 40 lbs pellets |
| 2 | 786 | N/A | |
| 3 | 757 | N/A | |
| 4 | 713 | N/A | |
| 5 | 538 | N/A | |
| 6 | 531 | N/A | |
| 7 | 614 | N/A | |
| 8 | 550 | N/A | |
| 9 | 518 | N/A | |
| 10 | 547 | N/A | |
| 11 | 601 | N/A | |
| 12 | 633 | N/A | |
| 13 | 787 | N/A | Cleaned Fire Pot Morning Start 6/6/2024 40 lbs pellets Medium Setting |
| 14 | 766 | N/A | |
| 15 | 688 | N/A | |
| 16 | 590 | N/A | |
| 17 | 557 | N/A | |
| 18 | 528 | N/A | |
| 19 | 570 | N/A | |
| 20 | 533 | N/A | |
| 21 | 504 | N/A | |
| 22 | 541 | N/A | |
| 23 | 494 | N/A | |
| 24 | 502 | N/A | |
| 25 | 444 | N/A | |
| 26 | 853 | N/A | Cleaned Fire Pot Morning Start 6/7/2024 40 lbs pellets Medium Setting |
| 27 | 771 | N/A | |
| 28 | 658 | N/A | |
| 29 | 580 | N/A | |
| 30 | 576 | N/A | |
| 31 | 515 | N/A | |
| 32 | 565 | N/A | |
| 33 | 540 | N/A | |
| 34 | 748 | N/A | Cleaned Fire Pot Morning Start 6/10/2024 30 lbs pellets Medium Setting |
| 35 | 735 | N/A | |
| 36 | 714 | N/A | |
| 37 | 663 | N/A | |
| 38 | 583 | N/A | |
| 39 | 553 | N/A | |
| 40 | 740 | N/A | |
| 41 | 555 | N/A | |
| 42 | 691 | N/A | |
| 43 | 627 | N/A | |
| 44 | 551 | N/A | |
| 45 | 560 | N/A | |
| 46 | 683 | N/A | Cleaned Fire Pot Morning Start 6/11/2024 Medium Setting |
| 47 | 824 | N/A | |
| 48 | 848 | N/A | |
| 49 | 829 | N/A | |
| 50 | 789 | N/A | |

Pre-Conditioning Data

Client: 509 Fabrications, Inc
 Model: Mini Me Pellet
 Date(s): 6/5/2024-6/11/2024
 Job #:
 Tracking #:
 Technician:

Equations and Sample Calculations – ASTM E2779 & E2515

Client 509 Fabrications
 Model: Mini Me
 Tracking #: 212
 Run: 2

Equations used to calculate the parameters listed below are described in this appendix. Sample calculations are provided for each equation. The raw data and printout results from a sample run are also provided for comparison to the sample calculations.

- M_{Bdb} – Weight of test fuel burned during test run, dry basis, kg
- M_{BSidb} – Weight of test fuel burned during test run segment i , dry basis, kg
- BR – Average dry burn rate over full integrated test run, kg/hr
- BR_{Si} – Average dry burn rate over test run segment i , kg/hr
- V_s – Average gas velocity in the dilution tunnel, ft/sec
- Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr
- $V_{m(std)}$ – Volume of Gas Sampled Corrected to Dry Standard Conditions, dscf
- m_n – Total Particulate Matter Collected, mg
- C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to STP, g/dscf
- E_T – Total Particulate Emissions, g
- PR - Proportional Rate Variation
- PM_R – Average particulate emissions for full integrated test run, g/hr
- PM_F – Average particulate emission factor for full integrated test run, g/dry kg of fuel burned

M_{Bdb} – Weight of test fuel burned during test run, dry basis, kg
ASTM E2779 equation (1)

$$M_{Bdb} = (M_{Swb} - M_{Ewb})(100/(100 + FM))$$

Where,

- FM = average fuel moisture of test fuel, % dry basis
- M_{Swb} = weight of test fuel in hopper at start of test run, wet basis, kg
- M_{Ewb} = weight of test fuel in hopper at end of test run, wet basis, kg

Sample Calculation:

- FM = 2.15 %
- M_{Swb} = 16.5 lbs
- M_{Ewb} = 0.0 lbs
- 0.4536 = Conversion factor from lbs to kg

$$M_{Bdb} = [(16.5 \times 0.4536) - (0.0 \times 0.4536)] (100/(100 + 2.145))$$

$$M_{Bdb} = 7.34 \text{ kg}$$

M_{BSidb} – Weight of test fuel burned during test run segment i , dry basis, kg
ASTM E2779 equation (2)

$$M_{BSidb} = (M_{S_{Siwb}} - M_{E_{Siwb}})(100/(100 + FM))$$

Where,

$M_{S_{Siwb}}$ = weight of test fuel in hopper at start of test run segment i , wet basis, kg

$M_{E_{Siwb}}$ = weight of test fuel in hopper at end of test run segment i , wet basis, kg

Sample Calculation (from medium burn rate segment):

$$FM = 2.15 \%$$

$$M_{S_{Siwb}} = 11.9 \text{ lbs}$$

$$M_{E_{Siwb}} = 5.8 \text{ lbs}$$

0.4536 = Conversion factor from lbs to kg

$$M_{BSidb} = [(11.9 \times 0.4536) - (5.8 \times 0.4536)] (100/(100 + 2.15))$$

$$M_{BSidb} = \mathbf{2.69 \text{ kg}}$$

BR – Average dry burn rate over full integrated test run, kg/hr

ASTM E2779 equation (3)

$$BR = \frac{60 M_{Bdb}}{\theta}$$

Where,

$$\theta = \text{Total length of full integrated test run, min}$$

Sample Calculation:

$$M_{Bdb} = 7.34 \quad \text{kg}$$

$$\theta = 360 \quad \text{min}$$

$$BR = \frac{60 \times 7.34}{360}$$

$$BR = 1.22 \quad \text{kg/hr}$$

BR_{Si} – Average dry burn rate over test run segment *i*, kg/hr
ASTM E2779 equation (4)

$$BR_{Si} = \frac{60 M_{BSidb}}{\theta_{Si}}$$

Where,

$$\theta_{Si} = \text{Total length of test run segment } i, \text{ min}$$

Sample Calculation (from medium burn rate segment):

$$M_{BSidb} = 2.69 \text{ kg}$$

$$\theta = 120 \text{ min}$$

$$BR = \frac{60 \times 2.69}{120}$$

$$BR = 1.34 \text{ kg/hr}$$

V_s – Average gas velocity in the dilution tunnel, ft/sec

ASTM E2515 equations (9)

$$V_s = F_p \times K_p \times C_p \times (\sqrt{\Delta P})_{avg} \times \sqrt{\frac{T_s}{P_s \times M_s}}$$

Where:

- F_p = Adjustment factor for center of tunnel pitot tube placement, $F_p = \frac{V_{strav}}{V_{scent}}$, ASTM E2515 Equation (1)
- V_{scent} = Dilution tunnel velocity calculated after the multi-point pitot traverse at the center, ft/sec
- V_{strav} = Dilution tunnel velocity calculated after the multi-point pitot traverse, ft/sec
- k_p = Pitot tube constant, 85.49
- C_p = Pitot tube coefficient: 0.99, unitless
- ΔP^* = Velocity pressure in the dilution tunnel, in H_2O
- T_s = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
- P_s = Absolute average gas static pressure in dilution tunnel, = $P_{bar} + P_g$, in Hg
- P_{bar} = Barometric pressure at test site, in. Hg
- P_g = Static pressure of tunnel, in. H_2O ; (in Hg = in H_2O /13.6)
- M_s = **The dilution tunnel wet molecular weight; $M_s = 28.78$ assuming a dry weight of 29 lb/lb-mole

Sample calculation:

$$F_p = \frac{17.94}{20.86} = 0.860$$

$$V_s = 0.860 \times 85.49 \times 0.99 \times 0.310 \times \left(\frac{102.8 + 460}{29.95 + \frac{-0.16}{13.6}} \right)^{1/2} \times 28.78$$

$$V_s = \mathbf{18.24 \text{ ft/s}}$$

*The ASTM test standard mistakenly has the square root of the average delta p instead of the average of the square root of delta p. The current EPA Method 2 is also incorrect. This was verified by Mike Toney at EPA.

**The ASTM test standard mistakenly identifies M_s as the dry molecular weight. It should be the wet molecular weight as indicated in EPA Method 2.

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

ASTM E2515 equation (3)

$$Q_{sd} = 3600 \times (1 - B_{ws}) \times v_s \times A \times \frac{T_{std}}{T_s} \times \frac{P_s}{P_{std}}$$

Where:

- 3600 = Conversion from seconds to hours (ASTM method uses 60 to convert in minutes)
- B_{ws} = Water vapor in gas stream, proportion by volume; assume 2%
- A = Cross sectional area of dilution tunnel, ft²
- T_{std} = Standard absolute temperature, 528 °R
- P_s = Absolute average gas static pressure in dilution tunnel, = P_{bar} + P_g, in Hg
- T_s = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
- P_{std} = Standard absolute pressure, 29.92 in Hg

Sample calculation:

$$Q_{sd} = 3600 \times (1 - 0.02) \times 18.24 \times 0.1963 \times \frac{528}{102.8 + 460} \times \frac{29.95 + \frac{-0.16}{13.6}}{29.92}$$

$$Q_{sd} = \mathbf{11860.5} \text{ dscf/hr}$$

$V_{m(std)}$ – Volume of Gas Sampled Corrected to Dry Standard Conditions, dscf
 ASTM E2515 equation (6)

$$V_{m(std)} = K_1 \times V_m \times Y \times \frac{P_{bar} + \left(\frac{\Delta H}{13.6} \right)}{T_m}$$

Where:

| | | |
|------------|---|--|
| K_1 | = | 17.64 °R/in. Hg |
| V_m | = | Volume of gas sample measured at the dry gas meter, dcf |
| Y | = | Dry gas meter calibration factor, dimensionless |
| P_{bar} | = | Barometric pressure at the testing site, in. Hg |
| ΔH | = | Average pressure differential across the orifice meter, in. H ₂ O |
| T_m | = | Absolute average dry gas meter temperature, °R |

Sample Calculation:

Using equation for Train A:

$$V_{m(std)} = 17.64 \times 57.378 \times 0.996 \times \frac{\left(29.95 + \frac{2.53}{13.6} \right)}{\left(92.8 + 460 \right)}$$

$$V_{m(std)} = \mathbf{54.944} \text{ dscf}$$

Using equation for Train B:

$$V_{m(std)} = 17.64 \times 56.636 \times 1.012 \times \frac{\left(29.95 + \frac{2.46}{13.6} \right)}{\left(97.6 + 460 \right)}$$

$$V_{m(std)} = \mathbf{54.624} \text{ dscf}$$

Using equation for ambient train:

$$V_{m(std)} = 17.64 \times 84.75 \times 1.004 \times \frac{\left(\underline{29.95} + \frac{0.00}{13.6} \right)}{\left(73.7 + 460 \right)}$$

$$V_{m(std)} = \mathbf{84.214} \text{ dscf}$$

m_n – Total Particulate Matter Collected, mg

ASTM E2515 Equation (12)

$$m_n = m_p + m_f + m_g$$

Where:

m_p = mass of particulate matter from probe, mg

m_f = mass of particulate matter from filters, mg

m_g = mass of particulate matter from filter seals, mg

Sample Calculation:

Using equation for Train A:

$$m_n = 0.0 + 1.5 + 0.3$$

$$m_n = \mathbf{1.8} \text{ mg}$$

Using equation for Train B:

$$m_n = 0.0 + 1.6 + 0.1$$

$$m_n = \mathbf{1.7} \text{ mg}$$

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to standard conditions, g/dscf
 ASTM E2515 equation (13)

$$C_s = K_2 \times \frac{m_n}{V_{m(std)}}$$

Where:

- K₂ = Constant, 0.001 g/mg
 m_n = Total mass of particulate matter collected in the sampling train, mg
 V_{m(std)} = Volume of gas sampled corrected to dry standard conditions, dscf

Sample calculation:

For Train A:

$$C_s = 0.001 \times \frac{1.8}{54.944}$$

$$C_s = \mathbf{0.00003} \text{ g/dscf}$$

For Train B:

$$C_s = 0.001 \times \frac{1.7}{54.624}$$

$$C_s = \mathbf{0.00003} \text{ g/dscf}$$

For Ambient Train

$$C_r = 0.001 \times \frac{0.1}{84.214}$$

$$C_r = \mathbf{0.000001} \text{ g/dscf}$$

E_T – Total Particulate Emissions, g

ASTM E2515 equation (15)

$$E_T = (C_s - C_r) \times Q_{std} \times \theta$$

Where:

- C_s = Concentration of particulate matter in tunnel gas, g/dscf
- C_r = Concentration particulate matter room air, g/dscf
- Q_{std} = Average dilution tunnel gas flow rate, dscf/hr
- θ = Total time of test run, minutes

Sample calculation:

For Train A

$$E_T = (0.000033 - 0.000001) \times 11860.5 \times 360 /60$$

$$E_T = \mathbf{2.25} \text{ g}$$

For Train B

$$E_T = (0.000031 - 0.000001) \times 11860.5 \times 360 /60$$

$$E_T = \mathbf{2.13} \text{ g}$$

Average

$$E = \mathbf{2.19} \text{ g}$$

Total emission values shall not differ by more than 7.5% from the total average emissions

- 7.5% of the average = 0.16
- Train A difference (%) = **2.7%**
- Train B difference (%)= **2.7%**

PR - Proportional Rate Variation

ASTM E2515 equation (16)

$$PR = \left[\frac{\theta \times V_{mi} \times V_s \times T_m \times T_{si}}{\theta_i \times V_m \times V_{si} \times T_{mi} \times T_s} \right] \times 100$$

Where:

- θ = Total sampling time, min
- θ_i = Length of recording interval, min
- V_{mi} = Volume of gas sample measured by the dry gas meter during the "ith" time interval, dcf
- V_m = Volume of gas sample as measured by dry gas meter, dcf
- V_{si} = Average gas velocity in the dilution tunnel during the "ith" time interval, ft/sec
- V_s = Average gas velocity in the dilution tunnel, ft/sec
- T_{mi} = Absolute average dry gas meter temperature during the "ith" time interval, °R
- T_m = Absolute average dry gas meter temperature, °R
- T_{si} = Absolute average gas temperature in the dilution tunnel during the "ith" time interval, °R
- T_s = Absolute average gas temperature in the dilution tunnel, °R

Sample calculation (for the first 10 minute interval of Train A):

$$PR = \left(\frac{360 \times 1.425 \times 18.24 \times (92.8 + 460) \times (#### + 460)}{10 \times 57.378 \times 18.43 \times (102.8 + 460) \times (76.2 + 460)} \right) \times 100$$

$$PR = \quad \mathbf{93} \quad \%$$

PM_R – Average particulate emissions for full integrated test run, g/hr
ASTM E2779 equation (5)

$$PM_R = 60 (E_T/\theta)$$

Where,

E_T = Total particulate emissions, grams

θ = Total length of full integrated test run, min

Sample Calculation:

$$E_T \text{ (Dual train average)} = 2.19 \text{ g}$$

$$\theta = 360 \text{ min}$$

$$PM_R = 60 \times (2.19 / 360)$$

$$PM_R = 0.36 \text{ g/hr}$$

PM_F – Average particulate emission factor for full integrated test run, g/dry kg of fuel burned
ASTM E2779 equation (6)

$$PM_F = E_T / M_{Bdb}$$

Where,

E_T = Total particulate emissions, grams

M_{Bdb} = Weight of test fuel burned during test run, dry basis, kg

Sample Calculation:

$$E_T \text{ (Dual train average)} = 2.19 \text{ g}$$

$$M_{Bdb} = 7.34 \text{ kg}$$

$$PM_F = 2.19 / 7.34)$$

$$PM_F = \mathbf{0.30} \text{ g/kg}$$

Stack Loss Efficiency and CO emissions calculations are done in accordance with CSA B415.1, using the password protected excel spreadsheet provided with the test standard. No alterations or alternative calculations are used for determining efficiency or CO emissions. The following pages are a sample of the calculations page from the B415.1 Spreadsheet (V2_4 - Dated April 15, 2010).

Manufacturer: 509 Fabrications

Model: Mini Me
 Date: 08/14/24
 Run: 2
 Control #: 24-265

Test Duration: 360 min

| | HHV | LHV |
|-----------|--------|--------|
| Eff | 75.60% | 81.02% |
| Comb Eff | 99.50% | 99.50% |
| HT Eff | 75.98% | 81.42% |
| Output | 18,563 | |
| Burn Rate | 1.22 | kg/h |
| Grams CO | 78 | g |
| Input | 24,555 | kJ/h |
| MC wet | 2.10 | |
| Averages | 0.09 | 9.00 |

Note: In the "Input data", "Calc. % O₂", "Fuel Properties", and "Mass Balance" columns, [e], [d], [g], [a], [b], [c], [h], [u], [w], [j], and [k] refer to their respective variables in Clauses 13.7.3 to 13.7.5.

Ultimate CO₂

CO_{2,ult} 20.28
 F₀
 1.028

| | | Air Fuel Ratio (A/F) | | |
|-----------------------------|--------------|--|--------|--------|
| Overall Heating Efficiency: | 75.60% | Dry Molecular Weight (M _d) | 29.90 | |
| Combustion Efficiency: | 99.50% | Dry Moles Exhaust Gas (N _d): | 467.58 | %HC |
| Heat Transfer Efficiency: | 75.98% | Air Fuel Ratio (A/F) | 13.47 | 0.8 |
| Heat Output: | 17,609 Btu/h | 18,563 | | kJ/h |
| Heat Input: | 23,293 Btu/h | 24,555 | | kJ/h |
| Burn Duration: | 6.00 | | | h |
| Burn Rate: | 2.70 | lb/h | 1.224 | kg/h |
| Stack Temp: | 470.5 Deg. F | 243.6 | | Deg. C |

| INPUT DATA | | | | Oxygen Calculation | | | | Input Data | | Combust | Heat | Net | Air | Wet Wt | % Wet | Dry Wt. | % Dry | Total | Carbon |
|--------------|-----------------------|----------|-----------------------|--------------------|----------------------|----------------------------|---------------|----------------|--------|------------|-------|------------|--------|------------|----------------------|------------|-------|----------|--------|
| Elapsed Time | Weight Remaining (kg) | % CO [e] | % CO ₂ [d] | Excess Air EA | Total O ₂ | Calc. % O ₂ [g] | Fuel Gas (°C) | Room Temp (°C) | % | Transfer % | Eff % | Fuel Ratio | Now Wt | Consumed x | Now W _{dry} | Consumed y | Input | /12= [a] | |
| 0 | 7.50 | 0.09 | 9.33 | 115.2% | 20.63 | 11.26 | 302.5 | 21.7 | 99.5% | 72.3% | 72.0% | 12.7 | 7.50 | 0.00 | 7.35 | 0.00 | 0 | 4.12 | |
| 1 | 7.48 | 0.05 | 11.91 | 69.5% | 20.55 | 8.61 | 316.4 | 21.7 | 99.8% | 75.4% | 75.3% | 10.0 | 7.48 | 0.36 | 7.32 | 0.36 | 1024 | 4.12 | |
| 2 | 7.43 | 0.03 | 14.11 | 43.5% | 20.48 | 6.36 | 339.1 | 21.5 | 100.0% | 76.5% | 76.5% | 8.5 | 7.43 | 1.03 | 7.27 | 1.03 | 713 | 4.12 | |
| 3 | 7.40 | 0.04 | 13.59 | 48.8% | 20.50 | 6.89 | 343.3 | 21.4 | 99.9% | 75.8% | 75.7% | 8.8 | 7.40 | 1.33 | 7.25 | 1.33 | 624 | 4.12 | |
| 4 | 7.36 | 0.04 | 13.38 | 51.2% | 20.50 | 7.11 | 350.7 | 21.6 | 99.9% | 75.1% | 75.1% | 8.9 | 7.36 | 1.87 | 7.21 | 1.87 | 802 | 4.12 | |
| 5 | 7.32 | 0.04 | 12.50 | 61.8% | 20.53 | 8.02 | 342.4 | 21.5 | 99.9% | 74.6% | 74.5% | 9.6 | 7.32 | 2.42 | 7.17 | 2.42 | 757 | 4.12 | |
| 6 | 7.29 | 0.08 | 11.74 | 71.7% | 20.56 | 8.78 | 333.8 | 21.4 | 99.7% | 74.1% | 73.8% | 10.1 | 7.29 | 2.90 | 7.13 | 2.90 | 757 | 4.12 | |
| 7 | 7.25 | 0.03 | 16.10 | 25.8% | 20.42 | 4.31 | 346.4 | 21.4 | 99.9% | 77.9% | 77.8% | 7.4 | 7.25 | 3.45 | 7.09 | 3.45 | 668 | 4.12 | |
| 8 | 7.22 | 0.02 | 17.61 | 15.0% | 20.37 | 2.75 | 347.0 | 21.5 | 99.9% | 78.9% | 78.9% | 6.8 | 7.22 | 3.81 | 7.07 | 3.81 | 579 | 4.12 | |
| 9 | 7.19 | 0.04 | 15.47 | 30.7% | 20.44 | 4.94 | 336.4 | 21.5 | 99.9% | 77.9% | 77.8% | 7.7 | 7.19 | 4.23 | 7.04 | 4.23 | 802 | 4.12 | |
| 10 | 7.14 | 0.04 | 13.74 | 47.2% | 20.49 | 6.73 | 342.1 | 21.6 | 99.9% | 76.0% | 75.9% | 8.7 | 7.14 | 4.90 | 6.99 | 4.90 | 802 | 4.12 | |
| 11 | 7.11 | 0.02 | 16.12 | 25.7% | 20.42 | 4.29 | 333.4 | 21.7 | 100.0% | 78.5% | 78.5% | 7.4 | 7.11 | 5.32 | 6.96 | 5.32 | 534 | 4.12 | |
| 12 | 7.08 | 0.04 | 12.58 | 60.7% | 20.53 | 7.93 | 328.8 | 21.6 | 99.9% | 75.5% | 75.4% | 9.5 | 7.08 | 5.62 | 6.93 | 5.62 | 624 | 4.12 | |
| 13 | 7.04 | 0.04 | 14.60 | 38.5% | 20.46 | 5.84 | 328.1 | 21.8 | 99.9% | 77.6% | 77.5% | 8.2 | 7.04 | 6.17 | 6.89 | 6.17 | 757 | 4.12 | |
| 14 | 7.01 | 0.05 | 12.67 | 59.5% | 20.53 | 7.83 | 329.7 | 21.8 | 99.9% | 75.5% | 75.4% | 9.4 | 7.01 | 6.65 | 6.86 | 6.65 | 668 | 4.12 | |
| 15 | 6.97 | 0.04 | 12.31 | 64.3% | 20.54 | 8.21 | 332.1 | 21.8 | 99.9% | 75.0% | 74.9% | 9.7 | 6.97 | 7.07 | 6.83 | 7.07 | 624 | 4.12 | |
| 16 | 6.94 | 0.04 | 12.54 | 61.2% | 20.53 | 7.97 | 330.6 | 21.7 | 99.9% | 75.3% | 75.3% | 9.5 | 6.94 | 7.50 | 6.80 | 7.50 | 579 | 4.12 | |
| 17 | 6.91 | 0.02 | 13.76 | 47.2% | 20.49 | 6.72 | 339.1 | 21.7 | 100.0% | 76.2% | 76.2% | 8.7 | 6.91 | 7.86 | 6.77 | 7.86 | 624 | 4.12 | |
| 18 | 6.88 | 0.03 | 12.58 | 60.8% | 20.53 | 7.93 | 348.1 | 21.9 | 100.0% | 74.4% | 74.4% | 9.5 | 6.88 | 8.34 | 6.73 | 8.34 | 713 | 4.12 | |
| 19 | 6.84 | 0.02 | 13.60 | 48.9% | 20.50 | 6.89 | 351.7 | 22.0 | 100.0% | 75.3% | 75.3% | 8.8 | 6.84 | 8.83 | 6.70 | 8.83 | 846 | 4.12 | |
| 20 | 6.79 | 0.04 | 15.25 | 32.7% | 20.44 | 5.17 | 359.3 | 21.8 | 99.9% | 76.6% | 76.5% | 7.8 | 6.79 | 9.49 | 6.65 | 9.49 | 757 | 4.12 | |
| 21 | 6.76 | 0.05 | 10.80 | 87.0% | 20.59 | 9.76 | 326.6 | 21.6 | 99.9% | 73.2% | 73.1% | 11.0 | 6.76 | 9.85 | 6.62 | 9.85 | 624 | 4.12 | |
| 22 | 6.73 | 0.04 | 12.03 | 68.0% | 20.55 | 8.50 | 324.3 | 21.8 | 99.9% | 75.1% | 75.0% | 9.9 | 6.73 | 10.34 | 6.59 | 10.34 | 713 | 4.12 | |
| 23 | 6.69 | 0.05 | 11.21 | 80.1% | 20.57 | 9.34 | 321.4 | 21.7 | 99.9% | 74.2% | 74.1% | 10.6 | 6.69 | 10.82 | 6.55 | 10.82 | 668 | 4.12 | |
| 24 | 6.66 | 0.03 | 11.45 | 76.6% | 20.57 | 9.10 | 326.1 | 21.8 | 100.0% | 74.2% | 74.2% | 10.4 | 6.66 | 11.25 | 6.52 | 11.25 | 624 | 4.12 | |
| 25 | 6.63 | 0.03 | 12.22 | 65.6% | 20.54 | 8.31 | 339.9 | 21.9 | 100.0% | 74.4% | 74.4% | 9.8 | 6.63 | 11.67 | 6.49 | 11.67 | 668 | 4.12 | |
| 26 | 6.59 | 0.03 | 14.14 | 43.1% | 20.48 | 6.32 | 349.7 | 21.8 | 100.0% | 76.0% | 76.0% | 8.5 | 6.59 | 12.15 | 6.45 | 12.15 | 891 | 4.12 | |
| 27 | 6.54 | 0.03 | 13.17 | 53.7% | 20.51 | 7.33 | 344.7 | 22.0 | 100.0% | 75.3% | 75.3% | 9.1 | 6.54 | 12.88 | 6.40 | 12.88 | 713 | 4.12 | |
| 28 | 6.52 | 0.03 | 11.71 | 72.8% | 20.56 | 8.84 | 341.1 | 21.9 | 100.0% | 73.6% | 73.6% | 10.2 | 6.52 | 13.12 | 6.38 | 13.12 | 713 | 4.12 | |
| 29 | 6.47 | 0.04 | 11.84 | 70.7% | 20.55 | 8.69 | 335.7 | 21.9 | 99.9% | 74.1% | 74.1% | 10.1 | 6.47 | 13.85 | 6.33 | 13.85 | 757 | 4.12 | |
| 30 | 6.44 | 0.04 | 11.00 | 83.7% | 20.58 | 9.56 | 328.1 | 21.9 | 99.9% | 73.4% | 73.4% | 10.8 | 6.44 | 14.15 | 6.31 | 14.15 | 668 | 4.12 | |
| 31 | 6.40 | 0.06 | 16.56 | 22.0% | 20.40 | 3.81 | 347.9 | 22.0 | 99.8% | 78.2% | 78.0% | 7.2 | 6.40 | 14.75 | 6.26 | 14.75 | 1024 | 4.12 | |
| 32 | 6.34 | 0.04 | 16.32 | 24.0% | 20.41 | 4.07 | 359.8 | 22.0 | 99.9% | 77.4% | 77.3% | 7.3 | 6.34 | 15.54 | 6.21 | 15.54 | 802 | 4.12 | |

Moisture Content M_{cwb} : 2.1

Combustion Efficiency: 99.50%
 Total Input (kJ): 147,328 139,733 (Btu)
 Total Output (kJ): 111,378 105,637 (Btu)
 Efficiency: 75.60%
 Total CO (g): 77.94

Moisture of Wood (wet basis): 2.1
 Initial Dry Weight $W_{t_{db}}$ (kg): 7.35
 Moisture Content Dry 2.15

Dry kg : 7.35
 CA: 49
 HY: 6
 OX: 44.13

Load Weight (kg): 7.50
 Fuel Heating HHV LHV
 Value in kJ/kg - CV: 20,053 18,712 Btu/lb HHV LHV
 8627.0 8050.0

| 6.22 | 2.76 | 20052.95 | 2.10 | 79.31 | 21.04 | 2.20 | 6.86 | -0.01 | 0.22 | 40.88 | 59.97 | 0.45 | -0.03 | 387.80 | 31.21 | 1.19 | 516.91 | 9162.10 | 6728.76 | 6502.33 | 6438.85 |
|---------------------|--------------------|--------------------|------------------------------|---|-------|------|-------|-------|-----------------------------|--------------------------|----------------|------|-------|----------------|------------------|---------------------|--------------------|--|----------------|----------|----------------|
| Fuel Properties | | | Mw Moisture Fuel Burnt | Mass Balance (moles/100 mole dry flue gas) | | | | | kg Wood per 100 mole dtp | Moles per kg of Dry Wood | | | | | | Moisture Present | Stack Temp K | Heat Content Change - Ambient to Stack T | | | |
| Hydrogen /1= [b] | Oxygen /16= [c] | Calorific Value | | [h] | [u] | [w] | [j] | [k] | | CO ₂ | O ₂ | CO | HC | N ₂ | H ₂ O | | | Flue Gas Constituent | | | |
| | | | | | | | | | | | | | | | | | | CO ₂ | O ₂ | CO | N ₂ |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.32 | 21.04 | 2.28 | 7.11 | 0.00 | 0.23 | 40.92 | 49.37 | 0.40 | -0.02 | 347.89 | 31.19 | 1.19 | 575.65 | 11840.43 | 8621.33 | 8312.47 | 8235.28 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.42 | 21.07 | 2.90 | 9.03 | -0.01 | 0.29 | 41.14 | 29.76 | 0.18 | -0.02 | 274.38 | 31.19 | 1.19 | 589.59 | 12487.95 | 9067.91 | 8736.73 | 8656.94 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.51 | 21.09 | 3.43 | 10.67 | -0.01 | 0.34 | 41.24 | 18.58 | 0.08 | -0.02 | 232.38 | 31.19 | 1.19 | 612.26 | 13558.89 | 9802.46 | 9433.48 | 9349.65 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.48 | 21.08 | 3.30 | 10.29 | -0.01 | 0.33 | 41.21 | 20.88 | 0.11 | -0.02 | 240.98 | 31.19 | 1.19 | 616.48 | 13763.07 | 9942.16 | 9565.89 | 9481.32 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.48 | 21.08 | 3.25 | 10.12 | -0.01 | 0.32 | 41.21 | 21.90 | 0.11 | -0.02 | 244.85 | 31.19 | 1.19 | 623.82 | 14103.12 | 10172.95 | 9784.14 | 9698.45 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.45 | 21.07 | 3.04 | 9.46 | -0.01 | 0.30 | 41.19 | 26.42 | 0.14 | -0.02 | 261.85 | 31.20 | 1.19 | 615.54 | 13714.07 | 9908.36 | 9533.78 | 9449.40 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.41 | 21.06 | 2.86 | 8.91 | 0.00 | 0.29 | 41.04 | 30.71 | 0.27 | -0.01 | 277.70 | 31.17 | 1.19 | 606.98 | 13313.91 | 9635.43 | 9275.31 | 9192.34 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.57 | 21.11 | 3.91 | 12.16 | 0.00 | 0.39 | 41.24 | 11.03 | 0.07 | -0.01 | 203.86 | 31.17 | 1.19 | 619.59 | 13910.73 | 10042.79 | 9661.16 | 9576.08 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.62 | 21.12 | 4.28 | 13.30 | 0.00 | 0.43 | 41.25 | 6.43 | 0.05 | 0.00 | 186.52 | 31.16 | 1.19 | 620.15 | 13932.90 | 10057.49 | 9674.98 | 9589.84 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.54 | 21.10 | 3.76 | 11.70 | 0.00 | 0.38 | 41.19 | 13.16 | 0.12 | 0.00 | 211.79 | 31.16 | 1.19 | 609.54 | 13430.24 | 9714.59 | 9350.23 | 9266.86 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.49 | 21.08 | 3.34 | 10.40 | -0.01 | 0.33 | 41.21 | 20.19 | 0.11 | -0.02 | 238.40 | 31.18 | 1.19 | 615.26 | 13696.67 | 9896.11 | 9522.07 | 9437.79 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.57 | 21.11 | 3.91 | 12.18 | 0.00 | 0.39 | 41.26 | 10.97 | 0.06 | -0.01 | 203.68 | 31.17 | 1.19 | 606.54 | 13280.26 | 9611.29 | 9252.12 | 9169.35 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.45 | 21.07 | 3.06 | 9.53 | -0.01 | 0.31 | 41.19 | 25.95 | 0.14 | -0.02 | 260.10 | 31.19 | 1.19 | 601.93 | 13067.48 | 9465.99 | 9114.47 | 9032.46 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.52 | 21.09 | 3.55 | 11.05 | 0.00 | 0.35 | 41.21 | 16.49 | 0.10 | -0.01 | 224.40 | 31.18 | 1.19 | 601.26 | 13029.81 | 9439.62 | 9089.32 | 9007.48 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.45 | 21.07 | 3.08 | 9.60 | -0.01 | 0.31 | 41.16 | 25.45 | 0.16 | -0.02 | 258.15 | 31.19 | 1.19 | 602.87 | 13105.53 | 9491.49 | 9138.51 | 9056.39 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.44 | 21.07 | 2.99 | 9.32 | -0.01 | 0.30 | 41.21 | 27.48 | 0.12 | -0.03 | 265.92 | 31.20 | 1.19 | 605.26 | 13217.95 | 9568.46 | 9211.48 | 9128.95 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.45 | 21.07 | 3.05 | 9.50 | -0.01 | 0.30 | 41.19 | 26.16 | 0.13 | -0.02 | 260.91 | 31.20 | 1.19 | 603.76 | 13149.46 | 9521.76 | 9167.26 | 9084.97 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.50 | 21.09 | 3.34 | 10.40 | -0.01 | 0.33 | 41.26 | 20.17 | 0.07 | -0.02 | 238.44 | 31.20 | 1.19 | 612.26 | 13550.42 | 9795.92 | 9427.08 | 9343.33 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.46 | 21.08 | 3.06 | 9.52 | -0.01 | 0.31 | 41.24 | 25.99 | 0.09 | -0.03 | 260.39 | 31.21 | 1.19 | 621.21 | 13968.27 | 10080.21 | 9696.11 | 9610.94 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.49 | 21.09 | 3.30 | 10.28 | -0.01 | 0.33 | 41.25 | 20.91 | 0.07 | -0.02 | 241.21 | 31.20 | 1.19 | 624.82 | 14135.95 | 10193.90 | 9803.60 | 9717.88 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.54 | 21.10 | 3.71 | 11.53 | 0.00 | 0.37 | 41.21 | 13.98 | 0.10 | -0.01 | 214.93 | 31.17 | 1.19 | 632.43 | 14505.88 | 10445.71 | 10041.93 | 9954.94 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.39 | 21.06 | 2.63 | 8.19 | -0.01 | 0.26 | 41.16 | 37.20 | 0.18 | -0.03 | 302.52 | 31.22 | 1.19 | 599.71 | 12963.12 | 9394.45 | 9046.64 | 8965.01 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.43 | 21.07 | 2.93 | 9.11 | -0.01 | 0.29 | 41.18 | 29.09 | 0.15 | -0.02 | 271.95 | 31.20 | 1.19 | 597.48 | 12852.55 | 9318.06 | 8974.03 | 8892.86 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.40 | 21.06 | 2.73 | 8.50 | -0.01 | 0.27 | 41.16 | 34.27 | 0.17 | -0.03 | 291.46 | 31.21 | 1.19 | 594.59 | 12721.51 | 9228.46 | 8889.12 | 8808.42 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.42 | 21.07 | 2.78 | 8.67 | -0.01 | 0.28 | 41.23 | 32.74 | 0.11 | -0.03 | 285.85 | 31.22 | 1.19 | 599.26 | 12933.80 | 9373.61 | 9026.67 | 8945.21 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.44 | 21.07 | 2.97 | 9.25 | -0.01 | 0.30 | 41.23 | 28.03 | 0.10 | -0.03 | 268.05 | 31.21 | 1.19 | 613.09 | 13583.50 | 9817.93 | 9447.77 | 9363.94 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.51 | 21.09 | 3.43 | 10.69 | -0.01 | 0.34 | 41.24 | 18.44 | 0.08 | -0.02 | 231.86 | 31.19 | 1.19 | 622.82 | 14049.15 | 10135.65 | 9748.69 | 9663.22 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.48 | 21.08 | 3.20 | 9.96 | -0.01 | 0.32 | 41.25 | 22.97 | 0.08 | -0.02 | 249.00 | 31.20 | 1.19 | 617.82 | 13803.04 | 9967.29 | 9589.11 | 9504.53 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.43 | 21.07 | 2.84 | 8.86 | -0.01 | 0.28 | 41.24 | 31.13 | 0.10 | -0.03 | 279.79 | 31.22 | 1.19 | 614.26 | 13636.61 | 9853.98 | 9481.87 | 9397.86 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.43 | 21.07 | 2.88 | 8.97 | -0.01 | 0.29 | 41.19 | 30.25 | 0.14 | -0.03 | 276.35 | 31.21 | 1.19 | 608.87 | 13381.84 | 9680.00 | 9317.04 | 9233.95 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.40 | 21.06 | 2.68 | 8.34 | -0.01 | 0.27 | 41.18 | 35.81 | 0.16 | -0.03 | 297.31 | 31.22 | 1.19 | 601.26 | 13025.58 | 9436.34 | 9086.12 | 9004.32 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.57 | 21.11 | 4.03 | 12.53 | 0.00 | 0.40 | 41.14 | 9.46 | 0.15 | 0.01 | 197.70 | 31.14 | 1.19 | 621.09 | 13958.75 | 10073.35 | 9689.51 | 9604.40 |
| 6.22 | 2.76 | 20052.95 | 2.10 | 79.57 | 21.11 | 3.97 | 12.34 | 0.00 | 0.40 | 41.20 | 10.27 | 0.10 | 0.00 | 200.91 | 31.16 | 1.19 | 632.93 | 14523.47 | 10457.04 | 10052.48 | 9965.47 |

| 9184.27 | | 7768.08 | | 296.33 | | SUMS | | | | | AVERAGE | | SUMS | | | | | | | | | | | | | | | | |
|-----------------|------------------|-----------|-----------------|-----------------------------------|--------|----------------|-----------------|-----------------------|--------------------------|-----------|---------|----------|--------|-----------------|------------|-----------------|--------------------------|--------------|-------------|----------------|----|----------|--|-------|--|------|--|------|--|
| 135380.59 | | 131034.17 | | 47301.75 | | 849306.57 | | -9404.71 | | 582918.42 | | 22257.52 | | 4872.01 | | 35837.30 | | 624.45 | | 35212.9 | | 111581.0 | | 620.1 | | 77.9 | | -2.9 | |
| emperature | | Room Temp | | Energy Losses (KJ/kg of Dry Fuel) | | | | | | | | | | Total Loss Rate | Total Loss | Chemical Loss 1 | Sensible and Latent Loss | Total Output | Chem Loss 2 | Grams Produced | | | | | | | | | |
| CH ₄ | H ₂ O | K | CO ₂ | O ₂ | CO | N ₂ | CH ₄ | H ₂ O Comb | H ₂ O Fuel MC | | | | | | | | | | | | CO | HC | | | | | | | |
| 12032.04 | 9924.60 | 294.82 | 484.57 | 425.65 | 116.23 | 2865.00 | -18.33 | 1681.13 | 64.23 | 5618.49 | 0.00 | 0 | 0.00 | 0 | 0 | 0.00 | 0.00 | | | | | | | | | | | | |
| 12744.57 | 10429.11 | 294.82 | 513.81 | 269.87 | 52.41 | 2375.27 | -18.72 | 1696.92 | 64.83 | 4954.38 | 253.08 | 2 | 251.43 | 771 | 2 | 0.26 | -0.02 | | | | | | | | | | | | |
| 13931.86 | 11257.31 | 294.65 | 559.11 | 182.16 | 24.79 | 2172.69 | -15.16 | 1722.31 | 65.81 | 4711.71 | 167.43 | 0 | 167.11 | 545 | 0 | 0.08 | -0.01 | | | | | | | | | | | | |
| 14159.00 | 11414.67 | 294.54 | 567.15 | 207.57 | 32.82 | 2284.80 | -14.90 | 1727.19 | 66.00 | 4870.63 | 151.44 | 1 | 150.91 | 472 | 1 | 0.10 | -0.01 | | | | | | | | | | | | |
| 14541.35 | 11673.89 | 294.76 | 581.15 | 222.80 | 33.37 | 2374.63 | -16.10 | 1735.42 | 66.31 | 4997.59 | 199.79 | 1 | 199.13 | 602 | 1 | 0.13 | -0.01 | | | | | | | | | | | | |
| 14105.08 | 11376.49 | 294.65 | 564.83 | 261.76 | 40.49 | 2474.37 | -19.29 | 1726.54 | 65.96 | 5114.65 | 193.11 | 1 | 192.35 | 564 | 1 | 0.15 | -0.01 | | | | | | | | | | | | |
| 13658.08 | 11069.39 | 294.54 | 546.46 | 295.91 | 78.70 | 2552.74 | -8.77 | 1715.68 | 65.59 | 5246.31 | 198.08 | 3 | 195.53 | 559 | 3 | 0.28 | -0.01 | | | | | | | | | | | | |
| 14324.14 | 11527.86 | 294.54 | 573.66 | 110.78 | 20.99 | 1952.21 | -6.30 | 1729.66 | 66.14 | 4447.15 | 148.15 | 0 | 147.68 | 520 | 0 | 0.07 | 0.00 | | | | | | | | | | | | |
| 14349.80 | 11544.24 | 294.65 | 574.76 | 64.67 | 15.77 | 1788.67 | -2.15 | 1729.67 | 66.16 | 4237.54 | 122.35 | 0 | 121.97 | 457 | 0 | 0.04 | 0.00 | | | | | | | | | | | | |
| 13788.45 | 11158.38 | 294.65 | 553.20 | 127.87 | 34.25 | 1962.62 | -3.54 | 1717.81 | 65.70 | 4457.90 | 178.21 | 1 | 177.03 | 623 | 1 | 0.13 | 0.00 | | | | | | | | | | | | |
| 14086.49 | 11362.55 | 294.76 | 564.46 | 199.83 | 31.58 | 2250.01 | -14.47 | 1725.51 | 65.94 | 4822.86 | 192.81 | 1 | 192.15 | 609 | 1 | 0.12 | -0.01 | | | | | | | | | | | | |
| 13623.11 | 11041.73 | 294.87 | 547.89 | 105.44 | 16.46 | 1867.62 | -8.16 | 1714.74 | 65.56 | 4309.55 | 114.86 | 0 | 114.65 | 420 | 0 | 0.04 | 0.00 | | | | | | | | | | | | |
| 13385.80 | 10878.17 | 294.76 | 538.21 | 245.67 | 40.16 | 2349.31 | -18.75 | 1710.93 | 65.36 | 4930.89 | 153.32 | 1 | 152.68 | 470 | 1 | 0.12 | -0.01 | | | | | | | | | | | | |
| 13345.19 | 10848.22 | 294.93 | 537.00 | 155.62 | 29.67 | 2021.31 | -10.11 | 1708.95 | 65.33 | 4507.76 | 170.20 | 1 | 169.49 | 587 | 1 | 0.11 | -0.01 | | | | | | | | | | | | |
| 13429.27 | 10906.69 | 294.93 | 539.44 | 241.60 | 46.51 | 2337.90 | -15.32 | 1711.40 | 65.40 | 4926.92 | 164.14 | 1 | 163.14 | 504 | 1 | 0.15 | -0.01 | | | | | | | | | | | | |
| 13554.21 | 10993.42 | 294.93 | 544.69 | 262.94 | 35.21 | 2427.58 | -23.01 | 1715.04 | 65.50 | 5027.94 | 156.34 | 0 | 155.98 | 467 | 0 | 0.10 | -0.01 | | | | | | | | | | | | |
| 13477.67 | 10940.88 | 294.87 | 541.68 | 249.11 | 38.38 | 2370.35 | -19.81 | 1713.01 | 65.44 | 4958.16 | 143.15 | 1 | 142.64 | 436 | 1 | 0.11 | -0.01 | | | | | | | | | | | | |
| 13924.08 | 11249.64 | 294.87 | 559.08 | 197.59 | 19.30 | 2227.84 | -19.73 | 1722.63 | 65.80 | 4772.51 | 148.39 | 0 | 148.42 | 475 | 0 | 0.06 | -0.01 | | | | | | | | | | | | |
| 14392.38 | 11569.23 | 295.04 | 576.04 | 262.02 | 26.86 | 2502.55 | -24.59 | 1733.20 | 66.19 | 5142.26 | 182.73 | 0 | 182.67 | 530 | 0 | 0.09 | -0.02 | | | | | | | | | | | | |
| 14581.18 | 11696.87 | 295.15 | 583.15 | 213.13 | 21.32 | 2344.03 | -19.90 | 1736.61 | 66.34 | 4944.66 | 208.66 | 0 | 208.61 | 638 | 0 | 0.09 | -0.01 | | | | | | | | | | | | |
| 14995.53 | 11979.99 | 294.98 | 597.76 | 146.04 | 30.09 | 2139.57 | -6.51 | 1743.78 | 66.67 | 4717.40 | 178.11 | 1 | 177.26 | 579 | 1 | 0.11 | 0.00 | | | | | | | | | | | | |
| 13269.98 | 10797.54 | 294.76 | 533.58 | 349.46 | 51.19 | 2712.05 | -29.61 | 1709.73 | 65.27 | 5391.66 | 167.65 | 1 | 167.01 | 456 | 1 | 0.15 | -0.02 | | | | | | | | | | | | |
| 13148.61 | 10711.18 | 294.93 | 529.28 | 271.10 | 42.98 | 2418.41 | -21.88 | 1706.10 | 65.16 | 5011.15 | 178.07 | 1 | 177.36 | 535 | 1 | 0.15 | -0.01 | | | | | | | | | | | | |
| 13002.71 | 10610.28 | 294.82 | 523.61 | 316.30 | 50.36 | 2567.34 | -25.89 | 1703.44 | 65.04 | 5200.20 | 173.24 | 1 | 172.47 | 495 | 1 | 0.16 | -0.02 | | | | | | | | | | | | |
| 13239.08 | 10773.74 | 294.98 | 533.22 | 306.92 | 32.58 | 2557.00 | -31.44 | 1709.21 | 65.24 | 5172.74 | 160.84 | 0 | 160.82 | 463 | 0 | 0.10 | -0.02 | | | | | | | | | | | | |
| 13962.24 | 11274.17 | 295.04 | 560.07 | 275.17 | 29.60 | 2509.99 | -26.21 | 1724.19 | 65.83 | 5138.64 | 171.19 | 0 | 171.10 | 497 | 0 | 0.09 | -0.02 | | | | | | | | | | | | |
| 14482.15 | 11631.72 | 294.93 | 579.37 | 186.93 | 23.90 | 2240.54 | -15.36 | 1734.02 | 66.26 | 4815.66 | 213.91 | 0 | 213.55 | 677 | 0 | 0.10 | -0.01 | | | | | | | | | | | | |
| 14208.33 | 11442.07 | 295.15 | 569.32 | 228.99 | 23.83 | 2366.62 | -21.68 | 1728.88 | 66.03 | 4961.99 | 176.33 | 0 | 176.27 | 536 | 0 | 0.08 | -0.01 | | | | | | | | | | | | |
| 14021.93 | 11314.67 | 295.09 | 562.31 | 306.77 | 29.88 | 2629.40 | -30.41 | 1725.97 | 65.88 | 5289.79 | 187.97 | 0 | 188.01 | 525 | 0 | 0.10 | -0.02 | | | | | | | | | | | | |
| 13737.84 | 11118.81 | 295.09 | 551.22 | 292.83 | 40.68 | 2551.79 | -24.52 | 1719.14 | 65.65 | 5196.79 | 196.21 | 1 | 195.64 | 561 | 1 | 0.15 | -0.02 | | | | | | | | | | | | |
| 13341.31 | 10844.39 | 295.04 | 536.39 | 337.91 | 45.94 | 2677.11 | -29.95 | 1711.23 | 65.32 | 5343.95 | 178.03 | 0 | 177.53 | 490 | 0 | 0.15 | -0.02 | | | | | | | | | | | | |
| 14382.57 | 11561.35 | 295.15 | 574.30 | 95.34 | 45.09 | 1898.78 | 6.25 | 1729.17 | 66.18 | 4415.10 | 225.53 | 3 | 222.99 | 799 | 3 | 0.22 | 0.01 | | | | | | | | | | | | |
| 15016.65 | 11992.47 | 295.15 | 598.43 | 107.43 | 29.60 | 2002.20 | -1.56 | 1743.56 | 66.69 | 4546.34 | 181.75 | 1 | 180.67 | 620 | 1 | 0.11 | 0.00 | | | | | | | | | | | | |

CAUTION: HOT WHILE IN OPERATION. DO NOT TOUCH. KEEP CHILDREN AND CLOTHING AWAY. CONTACT MAY CAUSE SKIN BURNS. KEEP FURNISHINGS AND OTHER COMBUSTIBLE MATERIAL FAR AWAY FROM THE APPLIANCE. SEE NAMEPLATE AND INSTRUCTIONS.



MISE EN GARDE: CHAUD EN FONCTIONNEMENT NE TOUCHEZ PAS, GARDEZ LES ENFANTS ET LES VÊTEMENTS À L'ÉCART. LE CONTACT PEUT CAUSER DES BRÛLURES DE LA PEAU. GARDER L'AMEUBLEMENT ET AUTRES COMBUSTIBLES MATÉRIEL LOIN DE L'APPAREIL. VOIR PLAQUE NOM ET INSTRUCTIONS.



Report Number:
24-266

UL 1482-2022
CAN/ULC-S627:2023
ASTM E2779, 40CFR60 AAA
Emissions rate 0.36 g/hr
Tested in accordance with ASTM E2779
U.S. ENVIRONMENTAL PROTECTION AGENCY: Certified to comply with 2020 particulate emissions standards.

SERIAL / EN SÉRIE #

Model / Modèle Mini Me Pellet

PREVENT HOUSE FIRES

Install and use only in accordance with manufacturer's installation and operating instructions. Contact local building or fire officials about restrictions and installation inspections in your area. Do not obstruct the space beneath heater.

WARNING - NOT SUITABLE FOR MOBILE HOME INSTALLATION

Inspect and clean chimney frequently - Under Certain Conditions of Use, Creosote Buildup May Occur Rapidly. Do not connect this unit to a chimney serving another appliance. Do not use a grate or elevate fire. Build wood fire directly on hearth.

DANGER: Risk of electrical shock. Disconnect power supply before servicing.

Replace glass only with 3/16" Neo-Ceram available from your dealer.

Do not overfire - if heater or chimney connector glows, you are overfiring.

OPERATE ONLY WITH DOORS CLOSED

Do **NOT** operate before fully assembling components. **WARNING:** Only use approved fuel listed in owners manual.

Follow cleaning procedures in the manual carefully.

Stove has detachable legs. Never install the stove without legs attached. Refer to owner's manual.

DO NOT OBSTRUCT THE SPACE BENEATH THE HEATER.

PRÉVENTION DES INCENDIES DE MAISON

Installer et n'utiliser qu'en conformité avec du fabricant installation et mode d'emploi. Contact local fonctionnaires de bâtiment ou d'incendie sur les restrictions et inspection des installations dans votre région. Ne pas obstruer l'espace sous le chauffe-eau.

AVERTISSEMENT -PAS ADAPTÉ À L'INSTALLATION D'UNE MAISON MOBILE

Inspecter et nettoyer la cheminée fréquemment - Sous Certain Conditions d'utilisation, l'accumulation de créosote peut se produire rapidement. Ne pas connecter cette unité à une cheminée desservant une autre appareil. N'utilisez pas de grille ni de feu surélevé. Faire un feu de bois directement sur foyer.

DANGER: Risque de choc électrique. Déconnecter l'alimentation fournir avant l'entretien. Remplacer la vitre seulement avec 3/16 po de Neo-Ceram disponible de votre revendeur.

Ne pas surchauffer - si le chauffage ou le connecteur de cheminée brille, vous êtes surfait. **FONCTIONNER UNIQUEMENT AVEC LES PORTES FERMÉES**

Ne **PAS** utiliser avant d'assembler complètement les composants.

AVERTISSEMENT: N'utilisez que du carburant approuvé répertorié dans les propriétaires manuel.

Suivez les procédures de nettoyage du manuel attentivement. Le poêle a des pieds amovibles. Ne jamais installer le poêle sans jambes attachées. Reportez-vous au manuel du propriétaire.

NE PAS OBSTRUER L'ESPACE SOUS LE RADIATEUR.

VENT SPECIFICATIONS:


SINGLE WALL: 6 in (6 inches) (152 mm) diameter, minimum 24 MSG black or blued steel connector pipe, with a listed factory-built UL103HT* Class "A" chimney, suitable for use with solid fuels, or a masonry chimney, and the referenced clearances.
DOUBLE WALL: 6 inch (6 inches) (152 mm) diameter, Class "A" chimney, or a masonry chimney and the referenced clearances.

SPÉCIFICATIONS DE VENTILATION:

MUR SIMPLE: 6 po (6 po) (152 mm) de diamètre, Tuyau de raccordement en acier au moins 24 MSG noir ou bleui, avec une classe UL103HT * classée en usine, classée "A" cheminée, utilisable avec des combustibles solides, ou une maçonnerie cheminée, et les dégagements référencés.
DOUBLE MUR: 6 pouces (6 pouces) (152 mm) de diamètre, systèmes de ventilation à basse température "A" cheminée, ou une cheminée en maçonnerie et le espaces libres référencés.

FLOOR PROTECTION:


Floor protector must be 1/2 in. minimum non-combustible material extending beneath heater and to front/sides/rear as indicated on the diagram below. Exception: Non-combustible floor protections must extend beneath the flue pipe when installed with horizontal venting and extend 2 inches (51mm) beyond each side.



PROTECTION DE PLANCHER:

Le protecteur de plancher doit être de 1/2 po minimum, matériau non combustible s'étendant sous le réchauffeur et à l'avant / côtés / arrière comme indiqué sur le schéma ci-dessous. Exception: Les protections de plancher incombustibles doivent s'étendre sous le conduit de fumée lorsqu'il est installé avec ventilation horizontale et étendre 2 pouces (51mm) de chaque côté.

MIN CLEARANCES TO COMBUSTIBLE MATERIALS: Inches & (Millimeters)



Front View Floor Installation


CAUTION: Hot Parts.

Do Not Operate Unit with Shield Removed.

A non combustible floor protector must be used if mounting the stove on the floor. See Clearances on this decal. Listed factory-built Class "A" chimney, or a masonry chimney. Maximum depth of Alcove shall be no more than 48 inches (1219mm) with a minimum height of 84.0 inches (2134mm) from floor to bottom of ceiling and the referenced clearances.

(*In Canada must comply with Standard CAN/ULC-S629-M87 for the 650°C Factory-built chimney.)

PETITS DÉGAGEMENTS AUX MATÉRIAUX COMBUSTIBLES: Pouces & (Millimètres)



Top View Floor Installation

ATTENTION: Pièces chaudes.

Ne pas utiliser l'unité avec le bouclier retiré.

Un protecteur de sol incombustible doit être utilisé si le poêle est monté sur le sol. Voir les dégagements sur cet autocollant. Cheminée de classe «A» construite en usine une cheminée de maçonnerie. La profondeur maximale de l'alcôve ne doit pas dépasser 1219 mm (48 po) avec un minimum de hauteur de 84,0 pouces (2134 mm) du plancher au plafond et des dégagements référencés. (** Au Canada doit être conforme à la norme CAN / ULC-S629-M87 pour la cheminée de 650°C fabriquée en usine.)

This wood heater needs periodic inspection and repair for proper operation. Consult the owner's manual for further information. It is against federal regulations to operate this wood heater in a manner inconsistent with the operating instructions in the owner's manual.



Manufactured by:
509 Fabrication, Inc.
dba Flame Innovation
6512 W. Seltice Way
Post Falls, ID 83854
509-993-3767
Info@509Fab.com
Developed by Ryan Baker
and Dusty Henderson

Ce poêle à bois a besoin d'une inspection et d'une réparation périodiques pour fonctionner correctement. Consultez le manuel du propriétaire pour plus d'informations. C'est contre le fédéral règlements pour faire fonctionner ce poêle à bois d'une manière incompatible avec instructions d'utilisation dans le manuel du propriétaire.

2024 2025 2026 2027 2028 2029 JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC

DO NOT REMOVE THIS LABEL / NE PAS ENLEVER CETTE ÉTIQUETTE

FLAME INNOVATION



UL 1482-2022 CAN/ULC-S627:2023
ASTM E2779, 40 CFR 60 AAA
Project # 24-266

Mini Me Pellet

Mini Me Pellet Tiny Stove Installation and Operation Manual

| Run Number | Date | Segments | | Run Time (min) | Heat Output (BTU/hr) | 1st Hr Emissions (g/hr) | Integrated Total (g/hr) | CO Emissions (g/min) | Overall CO Emissions (g/min) | Heating Efficiency (%HHV) | Overall Heating Efficiency (%HHV) |
|------------|-----------|----------|------|----------------|----------------------|-------------------------|-------------------------|----------------------|------------------------------|---------------------------|-----------------------------------|
| | | Setting | BR | | | | | | | | |
| 2 | 8/14/2024 | OA | 1.22 | 360 | 17609 | 1.2 | 0.36 | 0.22 | 0.22 | 76% | 76% |
| | | H | 2.07 | 60 | 29388 | | | 0.17 | | 74% | |
| | | M | 1.34 | 120 | 19167 | | | 0.23 | | 75% | |
| | | L | 0.86 | 180 | 12567 | | | 0.23 | | 77% | |

EPA UL / CSA MOBILE HOME APPROVED USA / CANADA

This stove needs to be installed with the correct pipe as tested and listed below. Failure to do so will void the warranty of the stove.

Mini Me Non-Electric, Gravity Fed Pellet Stove w/ 38-40 lb. Hopper and removable pellet adapter. Pellet Feed Shut off Tool. Brick Fire Pot and Removable Ash Pan.

Manufactured by 509 Fabrications, Inc.
 DBA, Flame Innovation
 6512 W. Seltice Way
 Post Falls, ID 83854 USA

info@509Fab.com



Proudly Made in the USA

Rev. 7.1

03/2025

CAUTION: This unit must be installed in accordance with these instructions and must comply with local building and fire codes. Failure to do so could result in a chimney or house fire. Keep children, furniture, fixtures, and all combustible materials away from any heating appliance. Refer to this owner's manual for all clearances to combustible materials.

This pellet heater needs periodic inspection and repair for proper operation. This pellet heater has a manufacturer set minimum low burn rate that must not be altered. It is against federal regulations to alter this setting or otherwise operate this pellet heater in a manner inconsistent with the operating instructions in this manual.

Disclaimer: All Pellet stoves burn differently in how they are controlled, Type and BTU content of pellets used, Elevation and height of chimney, etc. Pellets Tested are soft wood pellets with a moisture content of approx. 9% produced consistent burn times of 10 plus hours. Hardwood Pellets were not tested.

It is the consumer's responsibility to ensure the chimney system is safe and in good operating condition. **The manufacturer will not be held responsible for an accident attributed to a unit connected to a faulty chimney system or improper chimney parts.**

WARRANTY

This stove carries a 5-year warranty on the stove body. No warranty on paint, glass, or consumable parts such as bricks and pellet adapter OR AIR PORTS THAT ARE CONSUMABLE. Any shipping damage must be reported immediately upon receiving shipment to ensure replacement or repair from a warranty claim through the shipping company. Any AND ALL warranty claims must be submitted in writing with pictures to our email info@509fab.com. WE WILL TAKE CARE OF YOU AS SOON AS POSSIBLE BY SENDING REPLACEMENT PARTS OR HAVE YOU PURCHASE PARTS THAT ARE CONSUMABLE, NOT WARRANTY DAMAGED.

***IMPROPER INSTALLATION:** The manufacturer will not be held responsible for damage caused by the malfunction of a stove due to improper installation, CHIMNEY FIRES OR OVER-FIRING THE STOVE. It is especially important to use only specified Components when installing. Do not use makeshift methods or material which may compromise the installation. Improper Parts used can cause chimney fire and poor stove performance including exposure to carbon Monoxide. 509 Fabrications, Inc. DBA Flame Innovation will not be liable for consequential or indirect damage to property or persons resulting from the use of this product. Consult a professional installer if you have any questions.

SAVE THESE INSTRUCTIONS

ANY AND ALL SAFETY PRECAUTIONS MUST BE TAKEN AT ALL TIMES DURING OPERATION AND MAINTENANCE OF YOUR STOVE. Read this entire manual before you install and use your new room heater. If this heater is not professionally installed, a structure fire may result. To reduce the risk of fire, follow the installation instructions. Failure to follow instructions may result in property damage, bodily injury, or even death.

CAUTION: *Stove is heavy (107 #) In addition, when handling any sheet metal products, be aware that there may be sharp edges or burrs. Although we make every effort to eliminate any sharp edges, please use caution when handling any metal parts. Remember to always allow the stove to completely cool down before performing any maintenance.*

CAUTION: If you have any doubt concerning your ability to complete your installation in a professional-like manner after reading these instructions, you should obtain the services of an installer who is versed in all aspects as to the correct and safe installation. Do not use temporary, makeshift compromises during installation.

Precautionary Statements

Flame Innovation highly recommends the use of **Smoke Detectors and Carbon Monoxide Detectors** with any hearth product, including this unit. Follow all manufacturer's instructions when using smoke or Carbon Monoxide detectors. **DO NOT INSTALL THIS STOVE IN A SLEEPING ROOM**

CAUTION ONCE AGAIN PLEASE READ AND FOLLOW. If you have any doubt concerning your ability to complete your installation in a professional-like manner after reading these instructions, you should obtain the services of an installer who is versed in all aspects as to the correct and safe installation. Do not use temporary, makeshift components during installation.

WARNING: THINGS TO REMEMBER IN CASE OF A CHIMNEY FIRE: 1. CLOSE DRAFT CONTROL 2. PUT IN THE PELLET STOP TOOL 3. CALL THE FIRE DEPARTMENT

BEFORE INSTALLATION OF YOUR APPLIANCE

HOT WHILE IN OPERATION. KEEP CHILDREN, CLOTHING AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS. DO NOT BURN GARBAGE OR FLAMMABLE FLUIDS.

1. Check with the building inspector's office for compliance with local codes; a permit may be required.
2. A 4" diameter Class A Flue pipe is required for proper performance. 2' to 3' Single wall Stainless Steel pipe can be installed off the top of the stove if you can maintain 12" Clearance to combustibles until the use of Class A HT Insulated pipe is required.
3. Always connect this unit to a chimney and up through and NEVER vent to another room or inside a building.
4. DO NOT connect to any duct work to which another appliance is connected, such as a furnace.
5. DO NOT connect this unit to a Chimney Flue serving another appliance.
6. **DO NOT USE CHEMICALS OR FLUIDS TO START THE FIRE.**
7. The connector pipe and chimney should be inspected periodically and cleaned if necessary.
8. Remember the clearance distances when you place furniture or other objects within the area. (**DO NOT** store wood, flammable liquids or other combustible materials too close to the unit.)
9. Contact your local fire authority for information on how to handle a chimney fire. Have a clearly understood plan to handle a chimney fire. In a chimney fire, turn the air control to a closed position, **SLIDE IN THE PELLET SHUTOFF TOOL** and **CALL THE FIRE DEPARTMENT.**
10. DO NOT tamper with the combustion air control beyond normal adjustment.
11. Once the required draw is obtained, operate only with door closed; open feed lid slowly when refueling.
12. Clean the stove glass before lighting the stove.
13. Visit our web site at FlameInnovation.com or email us at Cody@509Fab.com / Dusty@509Fab.com

ALWAYS PROVIDE A SOURCE OF FRESH AIR INTO THE ROOM WHERE THE UNIT IS INSTALLED. FAILURE TO DO SO MAY RESULT IN AIR STARVATION OF OTHER FUEL BURNING APPLIANCES AND THE POSSIBLE DEVELOPMENT OF HAZARDOUS CONDITIONS IN SMALL AREAS.

Note on Outside Air Hookup: The Mini Me Pellet Stove comes with an ash pan with a 3" Fresh air outlet on the rear bottom of the stove. **We highly recommend fresh air for tiny spaces.** This involves connecting an aluminum flex pipe (usually three inches (3") in diameter from the air inlet pipe located on the back leg and to the ash Pan adapter through your floor or wall. The outside end of this pipe should be covered in some manner (i.e., with a screen) to keep it clear of foreign matter. Be sure to keep it above the snowdrift line and clear of leaves and other debris. It is not recommended to use a screen with openings smaller than: ¼"x ¼" **DO NOT USE A SCREEN SO FINE IT INHIBITS AIR FLOW.**

FLUE SYSTEM

The Mini Me Pellet Stove is designed for use with a 4" Flue System. **DO NOT USE BIGGER PIPE.** Use a Minimum 24ga. Stainless Steel pipe, up until Minimum 18" from the ceiling, before transitioning to Class A 4" Pipe for 2" Clearance to combustibles around the pipe only, not the stove at any time.

(The black or non-painted single wall connector pipe should be at least 24ga. Stainless Steel and a minimum of 12 inches (12.0") from a combustible wall and eighteen inches (18.0") from ceiling before transitioning to the Class A pipe to go through the wall or ceiling.

MINIMUM OF 7 TO 10 FT OF PIPE WITH AT LEAST ½ BEING INSULATED PIPE IS REQUIRED TO BURN.

It is permissible to use single wall pipe and Class A pipe both if you follow your counties rules and regulations with no single wall pipe penetrating any surface without 18" Clearance to combustibles around it. It is recommended in this situation to convert to Class A pipe at the ceiling box transition.

Canada: A Chimney connector shall not pass through an attic or roof space, closet or similar concealed space, or a floor, or ceiling. Where passage through a wall or partition of combustible construction is desired. The installation shall conform to CAN/CSA-B365. Installation code for Solid-Fuel-Burning Appliances and equipment.

It is not permissible to connect this unit to a chimney that is servicing another unit.

Flue Size-The proper flue size is determined by measuring the inside diameter of the flue collar on the unit. This stove is equipped with a four-inch (4") TOP EXHAUST FLUE COLLAR. Therefore, the connector pipe should be four inches (4") only and never less in diameter than the collar on the stove. Your unit may require an adapter which will reduce the 4" connector pipe by 1/8". This is necessary to accommodate pipe variation from different manufacturers and maintain a good seal. All Joints should be sealed and checked for leaks.

ALL CHIMNEY PIPES AFTER BURNING AND INSTALLING SHOULD BE CLEANED AND INSPECTED ON A REGULAR BASIS DEPENDING ON HOW MUCH YOU ARE BURNING.

It is the consumer's responsibility to ensure the chimney system is safe and in good operating condition. **The manufacturer will not be held responsible for an accident attributed to a unit connected to a**

faulty chimney system. Shipping damage must be reported within 10 days of receiving shipment to ensure replacement or repair from a warranty claim through the shipping company.

***IMPROPER INSTALLATION:** The manufacturer will not be held responsible for damage caused by the malfunction of a stove due to improper installation, CHIMNEY FIRES OR OVER-FIRING THE STOVE. It is especially important to use only specified Components when installing. Do not use makeshift methods or material which may compromise the installation. Improper Parts used can cause chimney fire and poor stove performance including exposure to carbon Monoxide. Flame Innovation will not be liable for consequential or indirect damage to property or persons resulting from the use of this product. Consult a professional installer if you have any questions.

INSTALLATION

1. Remove all parts from inside the stove body including touch up paint, fire poker, etc.
2. Select the proper location for the stove. These appliances must not be installed any closer than the minimum clearance to combustibles noted on the decal on the stove.
3. The stove must be installed on a non-combustible surface.
4. If non-combustible materials have been installed on the walls, obtain the minimum clearances from either the manufacturer of these materials or the local building inspector's office.
5. Install the first section of single wall stovepipe INSIDE the Flue collar on the top of the stove, between the stove and the chimney. We recommend sealing with high-temp., 2000-degree stove pipe sealant. Attach mounting screws in holes provided in Flue collar, Or Install the Chimney Pipe Adapter Part into the stove collar and use 4" Class A HT Pipe from stove to chimney cap.
6. Remember to Pre-drill your fastening points even if you are using a self-drilling screw
7. A clearance of 12 inches (12") between the 4" single wall stovepipe and combustible materials is required. A clearance of 2" can be maintained when using the UL approved Class A Insulated pipe. Check with authorities having legal control in your area with any questions and to verify clearances.
8. All the pipe sections **MUST BE** connected with the male (crimped single wall pipe) end toward the stove.
9. Fasten the stove pipe to the flue collar using three sheet metal screws. Do the same at each additional joint to make the entire installation rigid.
10. Maintain the required diameter flue for the entire installation according to local rules and regulations.
11. It is not recommended to use 90-degree elbows. If you must go out a side wall, then plan to use 45-degree elbows. One inside and one outside. This will not slow the draft as much as 2 90-degree elbows. 90 Degree elbows will slow the amount of draw, and possibly cause smoke spillage. **45-degree elbows are preferred.** It is recommended that no more than two 90-degree bends be used in the stovepipe installation if 90-degree elbows are used.
12. An In-Line damper is not required in this installation in the stove pipe above the stove. Remove the damper plate in the chimney or secure it in the OPEN position if you buy a

chimney pipe with a damper inside. FAILURE TO FOLLOW THE MINIMUM CLEARANCE REQUIREMENTS MAY RESULT IN AN UNSAFE INSTALLATION.

13. Single wall flue pipe assemblies must not exceed 12 feet (12') in overall length. Single wall flue pipe assemblies for wall tents, camping, etc. must not exceed 12 feet (12') in overall length and pass through a wall or ceiling without the proper clearances to combustibles (most areas 18") and proper metal box separators to surround the pipe and protect the wall and ceiling. Some cases at higher elevations above 5000 ft (about 1.52 km). may need additional Pipe sections.

14. ALWAYS Check for Leaks

15. Minimum stove pipe required at 2000 ft (about 609.6 m. Elevation) is 7 FT.

Higher elevations require more exhaust pipe lengths to draft correctly.

INSTALLATION Cont'd

THIS ROOM HEATER MUST BE CONNECTED TO:





- 1.) A chimney complying with the requirements for Type-HT Chimneys in the Standard for Chimneys, Factory-Built, Residential Type and Building Heating Appliance, UL 103 or
- 2.) A code-approved masonry chimney with a flue liner.
- 3.) DO NOT INSTALL IN AN ALCOVE.
- 4.) DO NOT CONNECT TO OR USE IN CONJUNCTION WITH ANY AIR DISTRIBUTION DUCTWORK UNLESS SPECIFICALLY APPROVED FOR SUCH INSTALLATIONS.
- 5.) DO NOT INSTALL IN ANY FIREPLACE.

Canada: A Chimney connector shall not pass through an attic or roof space, closet or similar concealed space, or a floor, or ceiling. Where passage through a wall or partition of combustible construction is desired. The installation shall conform to CAN/CSA-B365. Installation code for Solid-Fuel-Burning Appliances and equipment.

CANADA


Chimney Must be Labeled CAN/ULC-S629 or Code Compliant Chimney or Single Wall Stainless Steel Chimney where Clearance to Combustibles is Met

IT IS RECOMMENDED TO USE 4" CLASS A INSULATED STOVE PIPE. OPTIONAL 2 FT SECTION OF SINGLE WALL PIPE CAN BE USED DIRECTLY OFF THE STOVE AS LONG AS THE WALL IS PROTECTED AND CORRECT CLEARANCES CAN BE MAINTAINED.



Examples of single wall 4" to Class A 4" Chimney at ceiling

Note: You must Maintain 18" From Ceiling with single wall Pipe and minimum 12" From walls with 1" Air Gap behind Non-Flammable wall boards.



Corner Storage Cabinet / Pedestal

FLOOR AND WALL PROTECTION

1. You will not need any floor protection if your floor is constructed of a non-combustible material such as brick, metal, or concrete. If your floor is constructed with a combustible material such as hardwood, carpet, or linoleum, you must place protection between the stove and the combustible material. There are many floor and wall board manufacturers. The type of board you choose should be U.L. rated and a listed Fiber Board. After examining the area you plan to place your stove and determining it requires a board, the next step is to select the proper size. The stove you choose will determine the size board that is required. The approved protector board should be large enough to provide a minimum of eight inches (8") behind the unit, eight inches (8") on either side and sixteen inches (16") in the front (18" Canada) where the door is located. This stove requires a minimum of 42.0" D x 36.25" W for floor protection.
2. **Installation on a Concrete Floor** An appliance mounted on a concrete floor does not require floor protection. Carpeting and any other combustible material must not cover the Floor Protector. If a combustible surface is applied to the concrete floor, a clearance must be maintained equivalent to the area reserved for the floor protector. Floor Protection Foot-Print Minimum Size 42.0" x 36.25"

Installation on a Combustible Floor If the appliance is to be installed on a combustible floor or a combustible floor covering, it must be installed on a 1" thick non-combustible millboard floor protector or a durable equivalent, with a "R" factor of no less than "2." The pad must be installed beneath the unit, extending 16" (U.S.) on the side equipped with a door, and 8" on all other sides. The pad must cover any horizontal chimney connector flue runs and extend 2" beyond each side.

An R-2 Hearth Pad is Required for Free-Standing Installation

Type 2 – Traditional Hearth Pads

Fully non-combustible, with an R-value of **2.24 or 1.592** (R-value information), it provides protection well above the minimum requirements for Type 2 hearth pads (minimum requirement of R-value=1.0).

Your hearth pad is the layer of material that sits between your stove or fireplace and the floor or subfloor under it. Often made of natural stone tile, ceramic tile, thin set cement

board and other building materials, the hearth pad protects the subfloor from the heat of the fire above it. Its R-value, or thermal resistance, tells you how well it insulates the subfloor. To find the R-value, you need to know what materials the hearth pad is made of and their relative R-values, K-values, or C-values. These other two values measure thermal conductivity.

Look at the edge of the hearth pad, so you can see a cross-section of all its materials. If you have already installed the hearth pad, you might have to remove a decorative tile bevel or some other sort of edging to see the cross-section.

Measure the height in inches of each material used in the hearth pad. For example, if the hearth pad has a layer of cement board on the bottom, a layer of thin set in the middle and a layer of ceramic or stone tile on top, measure the height of each layer.

Consult an R-value chart to determine the R-value of each layer. Hearth manufacturers, insulation manufacturers and utility companies may have these charts on their websites or in their stores or offices.

Add the R-values of all the layers in the hearth pad to find the hearth pad's total R-value.

Measure the thickness of any layers of the hearth pad for which you know the K-value. You do not need to measure the layers for which you know the C-value.

Divide 1 by the K-value of the layer. Multiply the result by the thickness of the layer. This gives you, its R-value. For example, if you have a 1/2-inch layer of a material with a K-value of 0.3, divide 1 by 0.3 to get 3.333, then multiply that by 0.5 to get an R-value of 1.667.

Divide 1 by the C-value of a layer. This gives you the R-value. For example, if you have a layer with a C-value of 1.15, divide 1 by 1.15 to get an R-value of 0.87.

Repeat these calculations for any remaining layers. Add the R-values together to get the total R-value for the hearth pad.

MASONRY CHIMNEY

Ensure that a masonry chimney meets the minimum standards of the National Fire Protection Association (NFPA) by having it inspected by a professional. Make sure there are no cracks, loose mortar or other signs of deterioration and blockage. Have the chimney cleaned before the stove is installed and operated. When connecting the stove through a combustible wall to a masonry chimney, special methods are needed. Refer to Combustible Wall Chimney Connector Pass-Throughs.

MASONRY FIREPLACE

There are listed kits available to connect a stove to a masonry fireplace. The kit is an adapter that is installed at the location of the fireplace damper. The existing damper may have to be removed to allow installation.

METHOD A.

12" (304.8 mm) Clearance to Combustible Wall Member: Using a minimum thickness 3.5" (89 mm) brick and a 5/8" (15.9 mm) minimum wall thickness clay liner, construct a wall pass-through. The clay liner must conform to ASTM C315 (Standard Specification for Clay Fire Linings) or its equivalent. Keep a minimum of 12" (304.8 mm) of brick masonry between the clay liner and wall combustibles. The clay liner shall run from the brick masonry outer surface to the inner surface of the chimney flue liner but not past the inner surface. Firmly grout or cement the clay liner in place to the chimney flue liner.

METHOD B.

9" (228.6 mm) Clearance to Combustible Wall Member: Using a 6" (152.4 mm) inside diameter, listed, factory-built Solid-Pak chimney section with insulation of 1" (25.4 mm) or more, build a wall passthrough with a minimum 9" (228.6 mm) air space between the outer wall of the chimney length and wall combustibles. Use sheet metal supports fastened securely to wall surfaces on all sides, to maintain the 9" (228.6 mm) air space. When fastening supports to chimney length, do not penetrate the chimney liner (the inside wall of the Solid-Pak chimney). The inner end of the Solid-Pak chimney section shall be flush with the inside of the masonry chimney flue, and sealed with a non-water-soluble refractory cement. Use this cement to seal to the brick masonry penetration.

METHOD C.

6" (152.4 mm) Clearance to Combustible Wall Member: Starting with a minimum 24 gage (.024" [.61 mm (about 0.02 in)]) 6" (152.4 mm) metal chimney connector, and a minimum 24 gage ventilated wall thimble which has two air channels of 1" (25.4 mm) each, construct a wall pass-through. There shall be a minimum 6" (152.4) mm separation area containing fiberglass insulation, from the outer surface of the wall thimble to wall combustibles. Support the wall thimble, and cover its opening with a 24- gage minimum sheet metal support. Maintain the 6" (152.4 mm) space. There should also be a support sized to fit and hold the metal chimney connector. See that the supports are fastened securely to wall surfaces on all sides. Make sure fasteners used to secure the metal chimney connector does not penetrate chimney flue liner.

METHOD D.


2" (50.8 mm) Clearance to Combustible Wall Member: Start with a solid-pack listed factory-built chimney section at least 12" (304 mm) long, with insulation of 1" (25.4 mm) or more, and an inside diameter of 8" [51 mm (about 2.01 in)] larger than the [152.4 mm (about 6 in)] chimney connector. Use this as a pass-through for a minimum 24-gage single wall steel chimney connector. Keep solid-pack section concentric with and spaced 1" (25.4 mm) off the chimney connector by way of sheet metal support plates at both ends of chimney section. Cover opening with and support chimney section on both sides with 24 ga. minimum sheet metal supports. See that the supports are fastened securely to wall surfaces on all sides. Make sure fasteners used to secure chimney Flue liner.



NOTES:

1. Connectors to a masonry chimney, excepting method B, shall extend in one continuous section through the wall pass-through system and the chimney wall, to but not past the inner flue liner face.

1. A chimney connector shall not pass through an attic or roof space, closet or similar concealed space, or a floor, or ceiling.





2. **THE Mini Me Pellet Model DOES NOT HAVE A REAR EXHAUST OUTLET, THEREFOR DO NOT INSTALL IN OR UP A BUILT IN FIREPLACE / HEARTH FIREPLACE. DO NOT MOUNT THE STOVE IN FRONT OF A BUILT IN FIREPLACE AND RUN THE CHIMNEY UP THROUGH THE OPENING AT GROUND LEVEL. ONLY INSTALL AS DESCRIBED ABOVE BY A THROUGH WALL PENETRATION TO THE CHIMNEY LINER.**









Class A Pipe from 18" before ceiling or wall penetration above 2 ft single wall pipe off stove. Continue use of Class A pipe through ceiling and outside. Wall Exit use 45-degree elbow inside, Class A through wall and 45 class A degree elbow outside and class A Vertical to Chimney Cap.

Clearance to Combustibles USA



Floor Protection R-2

Clearance To Combustibles Canada




Canada: To comply with CSA B365, Installation Code for Solid-Fuel-Burning Appliances and Equipment, any combustible covering beneath the appliance and/or within the area extending horizontally at least 450 mm (18 in) beyond the appliance on any side equipped with a door, and at least 200 mm (8 in) beyond the appliance on other sides, shall be protected by a continuous, durable, non-combustible pad that will provide ember protection. The 450 mm (18 in) ember protection required on any side with a door shall extend for the full width of the appliance plus the 200 mm (8 in) required on each side of the appliance without a door. Where an appliance is installed less than 200 mm (8 in) from a wall, the ember pad needs only extend to the base of the wall. An ember pad shall not be placed on top of a carpet unless the pad is structurally supported to prevent displacement and distortion.

NOTE: Do not install the chimney directly at the outlet of the appliance. A chimney connector (flue pipe) is required unless the appliance is specifically approved for that type of installation.

- If the stove is installed in a transportable building, the chimney must be removed.
- Completely seal all penetrations with high temp. sealant of the chimney and silicone sealant for fresh air holes to maintain continuity of the air barrier system.


Wall Protection for “Free Standing” Installation

In some areas local codes may require thirty-six inches (36”) from a combustible, therefore it is important that you check with local officials. If you need to place your unit closer to a combustible wall, some protection will be necessary. A one-inch (1”) air space must be between the board and the wall. If you have a ceiling flue hook-up, you will need protection from the floor to the ceiling if you do not meet the normal clearances. If you have a wall flue hook up, you will need wall protection at least twelve inches (12”) above the wall thimble.



Outside Air Connection

The stove can accept a 3-inch aluminum flex tube for outside air under the stove draft. Make sure when connecting the fresh air tube to the outside that you cover the end with a screen of some sort, but not a screen that would restrict air in-flow. Utilize a screen with wider openings. The firepot air inlets are removable to clean the stove, and come standard with a built-in ash pan and fresh air inlet / outlet in the back leg of the stove.




BUILDING A FIRE

To start the fire, make sure the ash is out of the pot by removing the front bricks and pushing the ash to the side or remove air inlets and push ash through the openings with the damper all the way out so it will land in the ash pan below.

BUILDING A FIRE Cont'd

1. Replace the front bricks and air inlets you removed.
2. Pull the locking handle under stove out and slide towards the front of the stove into the locking position for your damper to set up against to set the EPA Mandated lowest setting on the stove.
3. Pull out damper handle to the second line on the handle (HIGH Setting.)
4. Fill up the hopper with the number of pellets you want to burn.
5. Use breaching tool. (See note)




USE PROVIDED PELLET BREACH TOOL WITH THE SPRING END UP. RUN DOWN THROUGH THE PELLETS WITH THE ROD AND INTO THE AREA OF THE PELLET ADAPTER AFTER FILLING TO THE BOTTOM OF THE HOPPER TO ENSURE THAT YOU DID NOT GET A BREACH IN PELLETS BEFORE LIGHTING THE FIRE AND FILLING THE HOPPER WITH DESIRED AMOUNT OF PELLETS YOU WANT TO BURN.

Open the door of the stove and use a propane torch to light the pellets on the left and right and center of the pot moving back and forth. Hold the torch on each section for about 20 to 30 seconds and repeat. Close the door and see if you have a flame. If you do, then the stove will continue to light on its own. If you do not have a flame after closing the door, then repeat the lighting procedure. Make sure to close the door immediately after starting the fire. After a couple of times lighting the stove, you will figure out what works best for you. Slide the damper to the medium position between the 2 lines on the damper slide. The stove burns best with the damper in the center position between the 2 lines on the damper slide for a medium burn.




Pellet Breach Tool

Damper Lock / Stop Position @ lowest setting. Move to slide closed.



AIR PORTS AND REPLACEMENT

Pellet air ports seen in picture with extended round tubes are welded to the 1x3" tube steel. They must be placed in their holes leading to the ash pan / Fresh air box to burn correctly. If the round tubes in the air ports are burned out to the flat surface, you must purchase these consumable parts from us at flameinnovation.com.



(Damper can be moved slightly to the first mark under the indicator for lower burning, but it is only recommended for short periods. Risk of burning up the feed tube after extended periods of burn time unless you scoop the ash out of the pot regularly using the ash scoop provided. The second mark on the damper handle is the high setting. The damper stop pull rod under the stove must always be in the locked position so the stove can not be turned down lower than the EPA Mandated setting. Different lengths of chimney, and the 2 types of chimneys used for configuration, elevation, and temperature play roles in how the fire will burn.

FIRST FIRE

Remember to ventilate well. The stove paint will “cure” as you burn and smell some. Flat spots on the painted surface are normal. Shiny spots on the painted surface (before burning) are normal.

1. Do not use a grate or elevate the fire inside the firebox.
2. Use only Natural pellets, preferable soft wood blends with low ash content marked on the bag. You will find a brand you like the best. (Hardwood pellets burn cooler and are not recommended)
3. When the stove is used for the first time, solvents in the paint will smoke off as the stove “cures.” As well as smoke coming off the stove pipe.

NEVER USE PELLETS THAT HAVE ADDITIVES IN THEM LIKE WAX, OILS, OR OTHER BINDING AGENTS. PURE SAWDUST PELLETS ONLY. THE USE OF THESE OTHER TYPES OF PELLETS CAN CAUSE A FIRE THAT IS OUT OF CONTROL VERY QUICKLY DUE TO THE ADDITIVES.

CLEAN AND INSPECT YOUR CHIMNEY REGULARILY AND WATCH OUTSIDE FREQUENTLY TO LOOK FOR SMOKE TO INSURE CORRECT DRAFT PLACEMENT FOR EFFECTIVE CLEAN EFFICIENT BURNING.


ALWAYS STORE YOUR PELLETS IN A WELL-VENTILATED AREA AWAY FROM DIRECT MOISTURE.

DO NOT BURN: Pellets with Additives, Treated Wood, Regular Wood, Garbage, Solvents, Trash, Cardboard, Colored Paper, or Coal. Just Pellets. (spiders are ok)

NEVER USE GASOLINE, GASOLINE-TYPE LANTERN FUEL, KEROSENE, CHARCOAL LIGHTER FLUID, OR SIMILAR LIQUIDS TO START OR 'FRESHEN UP' A FIRE IN THIS HEATER. KEEP ALL SUCH LIQUIDS WELL AWAY FROM THE HEATER WHILE IT IS IN USE.

SHUTTING DOWN THE STOVE WITH PELLETS IN THE HOPPER

Note: It is always best to let the stove burn out of pellets instead of using the tool to stop the pellet feed. Only put in enough pellets to burn the length of time you want to burn.




The Mini Me can be shut down with pellets still inside the hopper. **Do not touch the damper setting.** The damper must be left open to let the stove burn while it finishes the pellets inside the feed tube. Slide the pellet shutoff tool into the slot at the bottom right side of the hopper and push in until the tool reaches the shutoff line scribed into the tool. You may have to wiggle it and slide it side to side to get it to go into the slot, but it will work. Leave the stove running as-is without moving the damper to the closed position. If you slide the damper lock out of the way and slide the damper closed, it will smoke and not burn correctly.


CLEANING THE STOVE

The Mini Me Pellet has a removeable pellet adapter and bricks.

1. The pellet adapter must be removed using the provided tool w/ hook. Clean and inspect the adapter at least once a week.
2. Use a wire brush to remove any debris inside of the adapter. Keeping the surface smooth will help with breaching of the pellets.
3. Remove the top bricks and pull the damper slide tool out from under the stove to remove the damper.
4. Scrape the ash into the air inlet holes to land in the ash pan below. If you can vacuum the stove out with an approved ash vac it will be easier and faster. (See ash disposal)
5. Replace the damper and move the damper slide / stop to the locking position and pull the damper back to the stop to be ready for the next burn
6. Replace the bricks in the firebox.
7. Replace the pellet adapter making sure the 2 leg posts on the corners are facing the door with the center post in the back.

NOTE: You can use the tool provided to clean out the pot while in operation to lift some ash out. Make sure to slide in the pellet stop tool below the hopper before opening the door to eliminate smoke rising through the hopper or pellets burning up the tube.






Pellet Adapter


1. Reach under the cooled down stove and pull up on the damper lock spring.
2. Slide the spring handle towards the rear of the stove to the stopped position.
3. Pull out the damper handle and remove it from the stove.
4. Remove the front and side bricks.
5. Pull out the air inlet tubes including the round tube inserts and place outside the stove.
6. Slide the ash in the burn pot area into the air inlet holes emptying the ash into the ash pan below the stove.
7. If a full cleanout is required, remove the back 2 bricks, and use an approved ash vacuum to remove all the rest of the ash from the stove.
8. Replace the back 2 bricks making sure they are installed without any gaps in between them.
9. Set the air inlets back into the air chamber holders.
10. Place the round tube inserts back into the air inlets, making sure the longer tubes on each are opposite. **See Pics**
11. Place front bricks and side bricks back into position making sure there are no gaps.
12. Empty Ash Pan and vacuum contents into an approved metal container to dispose of any hot ashes.

13. Inspect ashes before dumping them out of your approved container for heat, and live coals.



(See Ash Disposal Section)

ALWAYS INSPECT THE PELLET ADAPTER WHEN THE STOVE IS OUT OF PELLETS AND COOLED. LOOK FOR ANY HARD ASH DEBRIS INSIDE THE ADAPTER IN THE LOWER SECTION. USE METAL BRISTLE BRUSH TO CLEAN OUT THE ADAPTER AND RE-INSTALL AS DESCRIBED IN THE MANUAL.



Ash Pan is shown with mounting brackets, and fresh air intake in the back leg of the stove.

ASH DISPOSAL Regularly inspect the ash build-up in your unit and remove, as necessary. Ashes can be removed from the unit by shoveling out bottom to ash pan after removing the front firebrick. Use an ASH VACUUM if desired when the stove is completely out.

Caution: The ashes can be extremely hot!! Never remove red-hot ashes from the appliance; allow ashes to cool before cleaning. Ashes should be placed in a metal container with an airtight lid. The ashes should be placed outside on a noncombustible surface and completely away from any combustible materials. The ashes should remain in the airtight container until they have completely cooled.



MINI ME PELLETT ADAPTER INSTALL INSTRUCTIONS

Remove pellet adapter from packaging and make sure there is nothing in the center to obstruct the pellets after installation.

Place your fire poker tool across the fire pot to catch the pellet adapter when it slides down the tube.

Open the lid on your Mini Me Pellet stove and insert the pellet adapter into the tube with the 3 prongs facing down and the round disc with the round hole facing up.

Slide the pellet adapter down as far as you can by hand and then let it go. The pellet adapter will stop when it hits the fire rod tool. Lift and slide the tool out of the stove. You may have to lift the pellet adapter up slightly to slide the tool out. The 2 legs that are on the corners of the pellet adapter should face the door with the other leg being center in the back.

Make sure the fire pot is clean and then fill the hopper with the desired number of pellets. **Remember to use the pellet breach tool before filling up the hopper.**

Close the lid and set the damper to the medium position and use a torch (**BY FAR THE BEST WAY TO LIGHT THE STOVE**) or gel or preferred lighting method to light the pellets. If you are lighting it with a torch, make sure to close the door and look for flames. If there are not visible flames, open the door and continue to light with the torch until it stays lit when you close the door. Leave the damper in the middle setting.

Let the stove get to temperature. Do not let the flame be lazy in movement. You want the flame to be active and vibrant to keep creosote levels down and avoid burning up into the tube.

Keep the fire pot clean between burns. This really helps with how the stove will perform. Depending on the size of your ash vac you can clean the pot out by using the tool provided or removing a couple of the bricks and pushing the ash out of the pot. Only vacuum when the stove is out and cold.


Note: When buying pellets, look at the size of them. If there are a lot of really long pellets visible in the bag, then look at another brand of pellets with shorter length pellets. This will help the stove not to clog. If it does clog you can tap on the tube, open the door, and tap on the feet of the pellet adapter, or run the pellet breach tool down through the center of the hopper and into the pellet adapter area.

INSPECT THE PELLETT ADAPTER FOR WEAR ON THE EDGES AND THE FEET OF THE ADAPTER. If any feet are broken off or burned through or there are holes near the bottom on the square portion by the feet, it is time to purchase another pellet adapter.

******* SPECIAL NOTE: LEAVE THE DAMPER OPEN TO BURN THE PELLETS THAT ARE LEFT IN THE FIREPOT AND LET THE STOVE BURN OUT. *DO NOT CLOSE THE DAMPER***

DRAFT / AIR CONTROLS

1. Pull the damper handle out past the high mark under stove out and slide the other handle under the stove up and forward towards the front of the stove until it stops. This will lock the damper into the lowest setting when you slide the damper back in so it cannot be run lower than the EPA mandated setting.
2. Pulling the damper out runs the stove on high. See marks on damper and align with the indicator plate for correct adjustment.
3. We suggest to run the damper in the spot located between the high mark and the low mark for full time burning.



EPA Efficiency


EPA Testing Efficiency was determined in accordance with CSA B415.1 using HHV at maximum, medium, and minimum burn rates. This pellet heater burns efficiently, (See Chart page 1), on all settings, however using pellets that are not dry or are poor quality will directly affect how the stove performs and can significantly reduce efficiency. Locating the stove in the most central location of the structure for more even heating will result in the best efficiency of the fuel that you put in this pellet heater. This pellet heater has been tested and found to produce minimal smoke and CO, but under certain conditions both will be produced. A CO / “Carbon Monoxide” detector is recommended in the area of the heater and or fuel storage areas. Areas containing hydronic heaters, or other burning devices should have Carbon Monoxide detectors.

GLASS CARE

The following use and safety tips should be observed: **NEVER POUR WATER ON HOT GLASS**

1. Inspect the glass regularly for cracks or breaks. Surface scratches are acceptable and normal, but if this glass becomes cracked in any area, the unit should be shut down and the window replaced with high-temperature Neo-Ceram glass ONLY. (5.50” x 8.50”)
2. Do not slam the door or otherwise impact the glass. When closing doors, make sure that foreign objects do not protrude and impact the glass.

3. Do not clean the glass with materials which may scratch (or otherwise damage) the glass. Scratches on the glass can develop into cracks or breaks.
4. Never attempt to clean the glass while the unit is hot. If the deposit is not very heavy, normal glass cleaners are adequate with a plain, non-abrasive scouring pad. Heavier deposits may be removed with a razor blade scraper.
5. NEVER put substances that can ignite explosively inside the unit, since even small explosions in confined areas can blow out the glass.
6. Inspect the glass and door seal periodically to ensure proper seal. If the gaskets become frayed or worn, replace them immediately. Contact your dealer or Customer Service at (509)-993-3767 OR (208)-660-3109 OR Info@509Fab.com for approved replacement parts.



Glass Gasket Replacement

After extensive use, the sealing material which provides glass and door seal may need to be replaced if it does not sustain its resilience. Inspect the glass and door seal periodically to ensure proper seal. If the gaskets become frayed or worn, replace them immediately.

The following steps should be followed for replacement of the glass gasket:

1. Ensure that the appliance is not in operation and is thoroughly cooled.
 2. Remove the screws and glass clip Brackets.
 3. Lift glass out from glass clips.
 4. Remove the old gasket and clean the glass.
 5. Replace the new gasket, starting at the bottom of the glass and working along the edges. Be sure to center the gasket channel on the glass.
 6. Trim the gasket to length and butt the ends together.
 7. Replace the glass in the door, being sure not to overtighten the nuts, this will break the glass.
- REPLACE GLASS ONLY WITH HIGH-TEMPERATURE NEO-CERAM OF THE PROPER SIZE AND THICKNESS. 5.50" X 8.50" You may order parts and options on our web site: FlameInnovation.com or by calling (509) 993-3767 OR (208) 660-3109 OR Info@509Fab.com

Door Gasket

The door gasket is 3/4" Rope Gasket. You will have to dig the gasket out of the channel and then clean all the old gasket cement out of the channel for the new sealant to adhere correctly when putting in new fire rope. Use only 3/4" Fire Rope to replace the door gasket. You can find it on our website if you cannot find it locally. Use high Temp Stove Gasket Sealer on all 3 sides of the channels to secure rope in place. Place a weight, like a big book, over the gasket overnight and then re-install the door. **IMPORTANT NOTE:** A clean surface is crucial to sealing your new gasket properly. **DO NOT** Try and re-seal over old gasketing Cement.

CREOSOTE

When Pellets are burned slowly, they produce tar and other organic vapors. These combine with moisture to form creosote. Creosote vapors condense in the relatively cool chimney flue of a slow-burning fire – as a result, creosote residue accumulates on the lining of the flue. If ignited, this creosote makes an extremely hot fire. The chimney should be inspected regularly during the heating season to determine if a creosote build-up has accumulated. If it has, the creosote should be removed to reduce the risk of chimney fire.


WAYS TO PREVENT AND KEEP UNIT FREE OF CREOSOTE

1. Burn with the air control at the set position between the high and low mark or towards the high mark if wanting more heat. **REMEMBER IT TAKES ABOUT AN HOUR FOR THE STOVE TO SPEED UP OR SLOW DOWN BECAUSE WE ARE HEATING UP THE METAL OR COOLING IT DOWN.**
2. Do not over fire the stove OR RAISE THE PELLETS ADAPTER FOR MORE FUEL.
3. **BURN DRY PELLETS ONLY.**
4. Establish a routine for fuel, burning and firing technique. Check daily for creosote build-up until experience shows you how often you need to clean to be safe. Keep in mind that the hotter the fire, the less creosote is deposited, and weekly cleanings may be necessary in milder weather, although monthly cleanings may be enough in the coldest months. Contact your local authority for information on how to handle a chimney fire and have a clearly understood plan to handle a chimney fire.

WARNING: THINGS TO REMEMBER IN CASE OF A CHIMNEY FIRE:

1. CLOSE DRAFT CONTROL.
1. a. SLIDE IN THE PELLET STOPPER IMMEDIATELY.
2. CALL THE FIRE DEPARTMENT.

BRICK CARE AND LAYOUT



Inspect your bricks each time you start a fire for correct placement, checking for broken or dislodged bricks. If broken or dislodged bricks are found, they need to be replaced in position or replaced entirely if damaged.

What can cause a poor draft?

There are several common factors that can contribute to poor draft in a stove.

A. Atmospheric Pressure and Air Supply

Atmospheric pressure affecting the draft from a chimney can be outside the home, inside the home, or both. Outside the home, a high-pressure (clear and cool) day creates a better draft in the chimney than a low-pressure (overcast and damp) day. Inside the home, household appliances, such as forced-air furnaces or clothes dryers, compete for air, often resulting in inadequate amounts of air available to fuel a fire and creating a condition known as negative pressure. Extreme conditions of negative pressure can cause the combustion by-products to be drawn from the chimney and into the house. This condition is commonly known as “down drafting.”

B. Air Availability

There are several factors that can affect the amount of air available in the home. Increased amounts of insulation, vinyl windows, extra caulking in various places and door seals can all keep heat in but may also make a home too airtight. If you are in doubt as to whether there is sufficient air in your home for your stove, refrain from using those appliances known to consume air when possible or open a door or a window to allow some air to enter the home.

C. Environmental Conditions

Towering trees, a low-lying house location (such as in a valley), tall buildings or structures surrounding your house and even windy conditions can cause poor draft or down drafting.

C. Cold Chimney Temperature

Avoid cold chimney temperatures by burning a hot fire for the first fifteen to forty minutes after building a fire, being careful not to over-fire. If any part of the chimney or parts of the stove start to glow, you are over-firing the stove. Where possible, install a temperature gauge on the chimney so temperature drops can be seen.

D. Chimney Installation and Maintenance

Avoid using too many elbows or long horizontal runs. If in doubt, contact a chimney expert and/or chimney manufacturer for help. Clean your chimney, rain cap(s) and especially the spark arrester regularly to prevent creosote build-up – which can significantly reduce chimney draw and possibly create a chimney fire.

Should I close or open the air control fully when shutting down the stove?

When shutting down the stove. Leave the damper in the MEDIUM position. This will allow chimney temperatures to remain as high as possible for as long as possible. Remember, cold chimney temperatures create creosote. Burning all the fuel out of the stove is the best way to leave your stove between fires.

NEVER POUR WATER ON THE FIRE, IN THE FIRE, OR ON THE STOVE TO EXTINGUISH FLAMES. TURN THE DAMPER TO THE OFF POSITION BY SLIDING THE HANGING HANDLE UNDER THE STOVE UP AND TOWARDS THE BACK OF THE STOVE TO UNLOCK THE LOW SETTING SO THE DAMPER WILL SLIDE PAST IT AND COMPLETELY SHUT OFF THE AIR TO THE FIRE **AND INSTALL THE PELLET SHUT OFF SLIDE PLATE AS SOON AS POSSIBLE.**

NOTE: This Manual is intended as an aid and does not supersede any local, state or like requirements. Check with officials or authorities having legal control in your area.

IF INSTALLED IN A MOVING STRUCTURE, IT IS HIGHLY RECOMMENDED TO TAKE OFF YOUR CHIMNEY CAP AND INSTALL A PLUG BEFORE BEING MOBILE IN YOUR STRUCTURE TO AVOID ASH BLOWING INSIDE THE STRUCTURE.

NEVER MOVE THE STRUCTURE WITH A LIT FIRE.



Chimney Plug Shown for Reference

NOTE:

Parts and accessories are also available on our web site: Flameinnovation.com

If you have any questions or problems, contact the Manufacturer or Dealer.



509 Fabrications, Inc.
DBA, Flame Innovation
6512 W. Seltice Way
Post Falls, ID 83854
509-993-3767
208-660-3109
Info@509Fab.com



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
11785 SE Hwy 212 STE#305
Clackamas, OR 97015

Report Number: DIRI0182484A0912013i231228

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|-------|-------------|-------------------|----------------|---------------|--------------|
| Scale | Digiweigh | DWP12i 300kg x 0. | 82484A0912013i | #050 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| lbs | 0.01 | QC033 | 12/28/23 | 12/14/22 | 12/2024 |

FUNCTIONAL CHECKS

| SHIFT TEST | | LINEARITY | | REPEATABILITY | | ENVIRONMENTAL CONDITIONS | | |
|---|--------------------------------|---|--------------------------------|---|--------------------------------|--------------------------|-------------------------------------|--------------------------|
| Test Wt: | Tol: | Test Wt: | Tol: | Test Wt: | Tol: | | | |
| 100 | 0.05 | HB44 | HB44 | 100 | 0.01 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| As-Found: | | As-Found: | | As-Found: | | Good Fair Poor | | |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Temperature: 19.3°C | | |
| As-Left: | | As-Left: | | As-Left: | | | | |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | | | |

CALIBRATION DATA

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|---------|----------------------|
| 400 | 399.87 | 400.01 | 0.006 |
| 200 | 200.00 | 200.00 | 0.005 |
| 100 | 100.02 | 100.02 | 0.005 |
| 75 | 75.02 | 75.02 | 0.005 |
| 50 | 50.02 | 50.02 | 0.005 |
| 25 | 25.00 | 25.00 | 0.005 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|--------------------|-----------|-------------|---------------|----------|--------------|----------|
| Avoirdupois Cast W | Rice Lake | 25 and 50lb | PWO990-CA | 7/18/22 | 7/2024 | 20221688 |

Permanent Information Concerning this Equipment:

Comments/Information Concerning this Calibration

12/28/23: RH-42.5%

Report prepared/reviewed by: R.A. Date: 12-28-23

Technician: C.Call

Signature: [Signature]

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy. Calibrations comply with ISO/IEC 17025 and ANSI/Z540-1-1994 quality standards.

Member: National Conference of Standards Laboratories and Weights & Measures

Dry Gas Meter Calibration

DUT

| | |
|-------------------------|--------------|
| Manufacturer: | Apex |
| Model: | XC-60 |
| Lab ID #: | 53 |
| Serial #: | 1902130 |
| Calibration Date: | 8/1/2024 |
| Calibration Expiration: | 2/1/2025 |
| Barometric Pressure: | 29.93 in. Hg |



| Equipment Used: | Ref. Std. DGM | Thermometer | Barometer | Manometer |
|------------------------------|---------------|-------------|-----------|-----------|
| Manufacturer: | Apex | Fuke | Aquatech | Dwyer |
| Model: | SK25DA | 52 II | DBX2 | W17AE |
| Lab ID#: | 47 | 196 | 202 | 124 |
| Calibration Expiration Date: | 5/1/2025 | 1/3/2025 | 6/17/2025 | 6/16/2025 |
| Calibration γ Factor: | 0.998 | | | |

Use in accordance with EPA Method 5, sections 10.3 and 16.1. Use only calibrated, NIST traceable reference standard DGM. Calibrate over expected operating flow range of DUT.

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 196.683 | 150.909 | 260.397 |
| Standard DGM Temperature (°F) | 76.0 | 77.0 | 77.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 7.090 | 5.446 | 9.498 |
| DGM Temperature (°F) | 90.0 | 92.0 | 95.0 |
| DGM Pressure (in H ₂ O) | 3.34 | 1.59 | 2.35 |
| Net Volume for Standard DGM (ft ³) | 6.946 | 5.329 | 9.196 |
| Net Volume for DGM (ft ³) | 7.090 | 5.446 | 9.498 |
| Dry Gas Meter γ Factor | 0.995 | 1.000 | 0.993 |
| γ Factor Deviation From Average | 0.995 | 1.000 | 0.993 |

Average Gas Meter γ Factor

0.996

Measurement Uncertainty: Total measurement uncertainty +/- 0.748% RD, K=2

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Dry Gas Meter Calibration

DUT

Manufacturer: Apex
 Model: XC-60
 Lab ID #: 54
 Serial #: 1902133
 Calibration Date: 8/1/2024
 Calibration Expiration: 2/1/2025
 Barometric Pressure: 29.93 in. Hg



| Equipment Used: | Ref. Std. DGM | Thermometer | Barometer | Manometer |
|---------------------------------------|---------------|-------------|-----------|-----------|
| Manufacturer: Apex | | Fuke | Aquatech | Dwyer |
| Model: SK25DA | | 52 II | DBX2 | W17AE |
| Lab ID#: 47 | | 196 | 202 | 124 |
| Calibration Expiration Date: 5/1/2025 | | 1/3/2025 | 6/17/2025 | 6/16/2025 |
| Calibration γ Factor: 0.998 | | | | |

Use in accordance with EPA Method 5, sections 10.3 and 16.1. Use only calibrated, NIST traceable reference standard DGM. Calibrate over expected operating flow range of DUT.

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 156.724 | 182.210 | 191.576 |
| Standard DGM Temperature (°F) | 73.0 | 74.0 | 75.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 5.412 | 6.423 | 6.840 |
| DGM Temperature (°F) | 77.0 | 82.0 | 88.0 |
| DGM Pressure (in H ₂ O) | 2.83 | 3.29 | 1.54 |
| Net Volume for Standard DGM (ft ³) | 5.535 | 6.435 | 6.765 |
| Net Volume for DGM (ft ³) | 5.412 | 6.423 | 6.840 |
| Dry Gas Meter γ Factor | 1.021 | 1.007 | 1.007 |
| γ Factor Deviation From Average | 1.021 | 1.007 | 1.007 |

Average Gas Meter γ Factor

1.012

Measurement Uncertainty: Total measurement uncertainty +/- 0.748% RD, K=2

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Technician:

Report and Certificate of Calibration



www.Cal-Cert.com

Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620



Report #: 33086-203325-4525 **Customer PO#:** 1109
Customer Name: PFS TECO
Customer Address: 1507 Matt Pass
City: Cottage Grove **State:** WI **Zip:** 53527
Contact: Ethan Frederick
Service Address: 11785 SE Highway 212, Suite 305 Clackamas, OR 97015

Calibration Standards

| |
|--|
| 10-01442 Compound Gauge Fluke SN: 4582643 Cal: 01/26/2024 Due: 01/31/2025 Vendor: Fluke Report #: EVL943251 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/24/2024 Due: 01/31/2025 Range: 122 °F 95 %RH Report #: 32568-205513-3646 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|---------------------|----------------------------|-----------------|
| Calibration Date: | February 26, 2024 | Reference: | ASME B40.100 |
| Recommended Due Date: | February 26, 2025 | Cal-Cert Procedure: | CP-003 |
| Calibration Frequency: | 12 Months | Indicating System: | Digital |
| Manufacturer: | Newport Industries | Temperature: | 64 °F |
| Type: | Pressure Transducer | Humidity: | 36% RH |
| Model Number: | Unknown | Cal Factor: | None |
| Serial #: | Unknown | Asset #: | 54B |
| Capacity: | 1 PSI | Service Location: | Service Address |
| Tolerance: | ± 1.00% of Span | As Found: | Pass |
| Gauge Class: | A | As Left: | Pass |

| Instrument Range: | | 1.00 | | Range Resolution: | | 0.01 | | Mode Verified: | | Pressure | |
|-------------------|-------------------|----------------------------------|-------|----------------------------------|-------|-----------|------------------------|----------------|------|----------|-------|
| UUT Reading | Standard As Found | Standard Verification Reading #1 | Error | Standard Verification Reading #2 | Error | Tolerance | Expanded Uncertainty ± | PSI | PSI | PSI | PSI |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.005 | 0.00 | 0.00 | 0.01 | 0.005 |
| 0.10 | 0.10 | 0.10 | 0.00 | 0.10 | 0.00 | 0.01 | 0.005 | 0.10 | 0.10 | 0.01 | 0.005 |
| 0.25 | 0.25 | 0.25 | 0.00 | 0.25 | 0.00 | 0.01 | 0.006 | 0.25 | 0.25 | 0.01 | 0.006 |
| 0.50 | 0.50 | 0.50 | 0.00 | 0.50 | 0.00 | 0.01 | 0.014 | 0.50 | 0.50 | 0.01 | 0.014 |
| 0.75 | 0.75 | 0.75 | 0.00 | 0.74 | -0.01 | 0.01 | 0.018 | 0.75 | 0.74 | 0.01 | 0.018 |
| 1.00 | 1.00 | 1.00 | 0.00 | 0.99 | -0.01 | 0.01 | 0.013 | 1.00 | 0.99 | 0.01 | 0.013 |
| 0.75 | 0.76 | 0.76 | 0.01 | 0.76 | 0.01 | 0.01 | 0.005 | 0.75 | 0.76 | 0.01 | 0.005 |
| 0.50 | 0.50 | 0.50 | 0.00 | 0.51 | 0.01 | 0.01 | 0.015 | 0.50 | 0.51 | 0.01 | 0.015 |
| 0.25 | 0.25 | 0.25 | 0.00 | 0.26 | 0.01 | 0.01 | 0.017 | 0.25 | 0.26 | 0.01 | 0.017 |
| 0.10 | 0.11 | 0.11 | 0.01 | 0.11 | 0.01 | 0.01 | 0.008 | 0.10 | 0.11 | 0.01 | 0.008 |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.005 | 0.00 | 0.00 | 0.01 | 0.005 |

Manufacturer: Newport Industries

Type: Pressure Transducer

Serial #: Unknown

Remarks:

**We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs.
Cleaning and preventative maintenance were performed as part of this service.**

**Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
A2LA is recognized under the ILAC mutual recognition agreement (MRA).**

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NC SL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above. Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Steven White

Date: February 26, 2024

Technical Manager: Marshall Doyle

Signature:



Report and Certificate of Calibration



www.Cal-Cert.com



Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620

Report #: 33086-203326-4525 **Customer PO#:** 1109
Customer Name: PFS TECO
Customer Address: 1507 Matt Pass
City: Cottage Grove **State:** WI **Zip:** 53527
Contact: Ethan Frederick
Service Address: 11785 SE Highway 212, Suite 305 Clackamas, OR 97015

Calibration Standards

| |
|--|
| 10-01442 Compound Gauge Fluke SN: 4582643 Cal: 01/26/2024 Due: 01/31/2025 Vendor: Fluke Report #: EVL943251 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/24/2024 Due: 01/31/2025 Range: 122 °F 95 %RH Report #: 32568-205513-3646 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|---------------------|----------------------------|-----------------|
| Calibration Date: | February 26, 2024 | Reference: | ASME B40.100 |
| Recommended Due Date: | February 26, 2025 | Cal-Cert Procedure: | CP-003 |
| Calibration Frequency: | 12 Months | Indicating System: | Digital |
| Manufacturer: | Newport Industries | Temperature: | 64 °F |
| Type: | Pressure Transducer | Humidity: | 36% RH |
| Model Number: | Unknown | Cal Factor: | None |
| Serial #: | Unknown | Asset #: | 54C |
| Capacity: | 5 In H2O | Service Location: | Service Address |
| Tolerance: | ± 1.00% of Span | As Found: | Pass |
| Gauge Class: | A | As Left: | Pass |

| Instrument Range: | | 5.00 | | Range Resolution: | | 0.01 | | Mode Verified: | | Pressure | |
|-------------------|-------------------|----------------------------------|--------|----------------------------------|--------|-----------|------------------------|----------------|--|----------|--|
| UUT Reading | Standard As Found | Standard Verification Reading #1 | Error | Standard Verification Reading #2 | Error | Tolerance | Expanded Uncertainty ± | | | | |
| In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | | | | |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.05 | 0.005 | | | | |
| 0.50 | 0.50 | 0.50 | 0.00 | 0.48 | -0.02 | 0.05 | 0.045 | | | | |
| 1.25 | 1.25 | 1.25 | 0.00 | 1.23 | -0.02 | 0.05 | 0.036 | | | | |
| 2.50 | 2.49 | 2.49 | -0.01 | 2.49 | -0.01 | 0.05 | 0.006 | | | | |
| 3.75 | 3.74 | 3.74 | -0.01 | 3.74 | -0.01 | 0.05 | 0.007 | | | | |
| 5.00 | 4.98 | 4.98 | -0.02 | 4.99 | -0.01 | 0.05 | 0.026 | | | | |
| 3.75 | 3.74 | 3.74 | -0.01 | 3.74 | -0.01 | 0.05 | 0.023 | | | | |
| 2.50 | 2.50 | 2.50 | 0.00 | 2.49 | -0.01 | 0.05 | 0.014 | | | | |
| 1.25 | 1.26 | 1.26 | 0.01 | 1.24 | -0.01 | 0.05 | 0.042 | | | | |
| 0.50 | 0.51 | 0.51 | 0.01 | 0.50 | 0.00 | 0.05 | 0.04 | | | | |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.01 | 0.01 | 0.05 | 0.005 | | | | |

Manufacturer: Newport Industries

Type: Pressure Transducer

Serial #: Unknown

Remarks:

**We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs.
Cleaning and preventative maintenance were performed as part of this service.**

**Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
A2LA is recognized under the ILAC mutual recognition agreement (MRA).**

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NCSS Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above. Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Steven White

Date: February 26, 2024

Technical Manager: Marshall Doyle

Signature:



Dry Gas Meter Calibration

DUT

Manufacturer: Apex
 Model: XC-50-DIR
 Lab ID #: 203
 Serial #: A2204292
 Calibration Date: 8/2/2024
 Calibration Expiration: 2/2/2025
 Barometric Pressure: 29.96 in. Hg



| Equipment Used: | Ref. Std. DGM | Thermometer | Barometer | Manometer |
|---------------------------------------|---------------|-------------|-----------|-----------|
| Manufacturer: Apex | Apex | Fuke | Aquatech | Dwyer |
| Model: SK25DA | SK25DA | 52 II | DBX2 | W17AE |
| Lab ID#: 47 | 47 | 196 | 202 | 124 |
| Calibration Expiration Date: 5/1/2025 | 5/1/2025 | 1/3/2025 | 6/17/2025 | 6/16/2025 |
| Calibration γ Factor: 0.998 | 0.998 | | | |

Use in accordance with EPA Method 5, sections 10.3 and 16.1. Use only calibrated, NIST traceable reference standard DGM. Calibrate over expected operating flow range of DUT.

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 176.263 | 245.171 | 145.418 |
| Standard DGM Temperature (°F) | 79.0 | 80.0 | 81.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 6.331 | 8.851 | 5.233 |
| DGM Temperature (°F) | 96.0 | 98.0 | 98.0 |
| DGM Pressure (in H ₂ O) | 1.10 | 0.81 | 1.41 |
| Net Volume for Standard DGM (ft ³) | 6.225 | 8.658 | 5.135 |
| Net Volume for DGM (ft ³) | 6.331 | 8.851 | 5.233 |
| Dry Gas Meter γ Factor | 1.009 | 1.007 | 1.007 |
| γ Factor Deviation From Average | 1.009 | 1.007 | 1.007 |

Average Gas Meter γ Factor

1.008

Measurement Uncertainty: Total measurement uncertainty +/- 0.748% RD, K=2

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Technician:

Report and Certificate of Calibration



www.Cal-Cert.com



Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620

Report #: 33086-203319-4525 **Customer PO#:** 1109
Customer Name: PFS TECO
Customer Address: 1507 Matt Pass
City: Cottage Grove **State:** WI **Zip:** 53527
Contact: Ethan Frederick
Service Address: 11785 SE Highway 212, Suite 305 Clackamas, OR 97015

Calibration Standards

| |
|--|
| 10-01442 Compound Gauge Fluke SN: 4582643 Cal: 01/26/2024 Due: 01/31/2025 Vendor: Fluke Report #: EVL943251 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/24/2024 Due: 01/31/2025 Range: 122 °F 95 %RH Report #: 32568-205513-3646 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|---------------------|----------------------------|-----------------|
| Calibration Date: | February 26, 2024 | Reference: | ASME B40.100 |
| Recommended Due Date: | February 26, 2025 | Cal-Cert Procedure: | CP-003 |
| Calibration Frequency: | 12 Months | Indicating System: | Digital |
| Manufacturer: | Red Lion | Temperature: | 65 °F |
| Type: | Pressure Transducer | Humidity: | 36% RH |
| Model Number: | Unknown | Cal Factor: | None |
| Serial #: | Unknown | Asset #: | 203B |
| Capacity: | 1 In H2O | Service Location: | Service Address |
| Tolerance: | ± 1.00% of Span | As Found: | Pass |
| Gauge Class: | A | As Left: | Pass |

| Instrument Range: | | 1.00 | | Range Resolution: | | 0.001 | | Mode Verified: | | Pressure | |
|-------------------|-------------------|----------------------------------|--------|----------------------------------|--------|-----------|------------------------|----------------|--|----------|--|
| UUT Reading | Standard As Found | Standard Verification Reading #1 | Error | Standard Verification Reading #2 | Error | Tolerance | Expanded Uncertainty ± | | | | |
| In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | | | | |
| 0.000 | 0.000 | 0.000 | 0.00 | 0.000 | 0.00 | 0.01 | 0.0005 | | | | |
| 0.100 | 0.098 | 0.098 | 0.00 | 0.099 | 0.00 | 0.01 | 0.0036 | | | | |
| 0.250 | 0.252 | 0.252 | 0.00 | 0.250 | 0.00 | 0.01 | 0.0055 | | | | |
| 0.500 | 0.502 | 0.502 | 0.00 | 0.499 | 0.00 | 0.01 | 0.0065 | | | | |
| 0.750 | 0.751 | 0.751 | 0.00 | 0.748 | 0.00 | 0.01 | 0.0086 | | | | |
| 1.000 | 1.001 | 1.001 | 0.00 | 0.998 | 0.00 | 0.01 | 0.0068 | | | | |
| 0.750 | 0.752 | 0.752 | 0.00 | 0.749 | 0.00 | 0.01 | 0.0073 | | | | |
| 0.500 | 0.501 | 0.501 | 0.00 | 0.499 | 0.00 | 0.01 | 0.0065 | | | | |
| 0.250 | 0.251 | 0.251 | 0.00 | 0.250 | 0.00 | 0.01 | 0.0024 | | | | |
| 0.100 | 0.103 | 0.103 | 0.00 | 0.101 | 0.00 | 0.01 | 0.0057 | | | | |
| 0.000 | 0.001 | 0.001 | 0.00 | 0.000 | 0.00 | 0.01 | 0.0005 | | | | |

Manufacturer: Red Lion

Type: Pressure Transducer

Serial #: Unknown

Remarks:

**We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs.
Cleaning and preventative maintenance were performed as part of this service.**

**Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
A2LA is recognized under the ILAC mutual recognition agreement (MRA).**

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NC SL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above. Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer:

Steven White

Date:

February 26, 2024

Technical Manager:

Marshall Doyle

Signature:



Report and Certificate of Calibration



www.Cal-Cert.com

Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620



Report #: 33086-203320-4525 **Customer PO#:** 1109
Customer Name: PFS TECO
Customer Address: 1507 Matt Pass
City: Cottage Grove **State:** WI **Zip:** 53527
Contact: Ethan Frederick
Service Address: 11785 SE Highway 212, Suite 305 Clackamas, OR 97015

Calibration Standards

| |
|--|
| 10-01442 Compound Gauge Fluke SN: 4582643 Cal: 01/26/2024 Due: 01/31/2025 Vendor: Fluke Report #: EVL943251 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/24/2024 Due: 01/31/2025 Range: 122 °F 95 %RH Report #: 32568-205513-3646 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|---------------------|----------------------------|-----------------|
| Calibration Date: | February 26, 2024 | Reference: | ASME B40.100 |
| Recommended Due Date: | February 26, 2025 | Cal-Cert Procedure: | CP-003 |
| Calibration Frequency: | 12 Months | Indicating System: | Digital |
| Manufacturer: | Red Lion | Temperature: | 66 °F |
| Type: | Pressure Transducer | Humidity: | 38% RH |
| Model Number: | Unknown | Cal Factor: | None |
| Serial #: | Unknown | Asset #: | 203C |
| Capacity: | 5 In H2O | Service Location: | Service Address |
| Tolerance: | ± 1.00% of Span | As Found: | Pass |
| Gauge Class: | A | As Left: | Pass |

| Instrument Range: | | 5.00 | | Range Resolution: | | 0.01 | | Mode Verified: | | Pressure | |
|-------------------|-------------------|----------------------------------|--------|----------------------------------|--------|-----------|------------------------|----------------|--|----------|--|
| UUT Reading | Standard As Found | Standard Verification Reading #1 | Error | Standard Verification Reading #2 | Error | Tolerance | Expanded Uncertainty ± | | | | |
| In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | In H2O | | | | |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.05 | 0.005 | | | | |
| 0.50 | 0.50 | 0.50 | 0.00 | 0.49 | -0.01 | 0.05 | 0.038 | | | | |
| 1.25 | 1.25 | 1.25 | 0.00 | 1.22 | -0.03 | 0.05 | 0.067 | | | | |
| 2.50 | 2.48 | 2.48 | -0.02 | 2.47 | -0.03 | 0.05 | 0.021 | | | | |
| 3.75 | 3.72 | 3.72 | -0.03 | 3.71 | -0.04 | 0.05 | 0.043 | | | | |
| 5.00 | 5.00 | 5.00 | 0.00 | 4.99 | -0.01 | 0.05 | 0.045 | | | | |
| 3.75 | 3.72 | 3.72 | -0.03 | 3.71 | -0.04 | 0.05 | 0.034 | | | | |
| 2.50 | 2.49 | 2.49 | -0.01 | 2.47 | -0.03 | 0.05 | 0.05 | | | | |
| 1.25 | 1.23 | 1.23 | -0.02 | 1.23 | -0.02 | 0.05 | 0.008 | | | | |
| 0.50 | 0.50 | 0.50 | 0.00 | 0.49 | -0.01 | 0.05 | 0.018 | | | | |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.05 | 0.005 | | | | |

Manufacturer: Red Lion

Type: Pressure Transducer

Serial #: Unknown

Remarks:

**We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs.
Cleaning and preventative maintenance were performed as part of this service.**

**Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
A2LA is recognized under the ILAC mutual recognition agreement (MRA).**

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NC SL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above. Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Steven White

Date: February 26, 2024

Technical Manager: Marshall Doyle

Signature:



Dry Gas Meter Calibration

DUT

| | |
|-------------------------|--------------|
| Manufacturer: | Apex |
| Model: | XC-60 |
| Lab ID #: | 55 |
| Serial #: | 810016 |
| Calibration Date: | 8/3/2024 |
| Calibration Expiration: | 2/3/2025 |
| Barometric Pressure: | 29.98 in. Hg |



| Equipment Used: | Ref. Std. DGM | Thermometer | Barometer | Manometer |
|------------------------------|---------------|-------------|-----------|-----------|
| Manufacturer: | Apex | Fuke | Aquatech | Dwyer |
| Model: | SK25DA | 52 II | DBX2 | W17AE |
| Lab ID#: | 47 | 196 | 202 | 124 |
| Calibration Expiration Date: | 5/1/2025 | 1/3/2025 | 6/17/2025 | 6/16/2025 |
| Calibration γ Factor: | 0.998 | | | |

Use in accordance with EPA Method 5, sections 10.3 and 16.1. Use only calibrated, NIST traceable reference standard DGM. Calibrate over expected operating flow range of DUT.

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 226.392 | 146.151 | 296.953 |
| Standard DGM Temperature (°F) | 81.0 | 82.0 | 82.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 8.064 | 5.174 | 10.408 |
| DGM Temperature (°F) | 85.0 | 86.0 | 86.0 |
| DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.00 |
| Net Volume for Standard DGM (ft ³) | 7.995 | 5.161 | 10.487 |
| Net Volume for DGM (ft ³) | 8.064 | 5.174 | 10.408 |
| Dry Gas Meter γ Factor | 0.997 | 1.003 | 1.013 |
| γ Factor Deviation From Average | 0.997 | 1.003 | 1.013 |

Average Gas Meter γ Factor

1.004

Measurement Uncertainty: Total measurement uncertainty +/- 0.748% RD, K=2

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Technician:

Report and Certificate of Calibration



Portland Laboratory
5777 SE International Way
Milwaukie, OR 97222
800-356-4662
503-654-9620

Anaheim Laboratory
120 S. Chaparral Ct Suite 110
Anaheim Hills, CA 92808
888-700-4100
714-696-5300

www.Cal-Cert.com

Report #: 30452-28785-3646 **Customer PO#:** 1100
Customer Name: PFS TECO
Customer Address: 11785 SE Highway 212, Suite 305
City: Clackamas **State:** OR **Zip:** 97015
Contact: John Steinert
Service Address: 5777 SE International Way Milwaukie, OR 97222

Calibration Standards

| |
|--|
| LP-00051 Electrical Meter Fluke SN: 9663004 Cal: 01/10/2023 Due: 01/10/2024 Vendor: Fluke Report #: EVL861119 |
| LP-01333 Electrical Meter IET Labs, Inc. SN: E3-1842499 Cal: 01/19/2023 Due: 01/31/2024 Vendor: Transcat Calibration Lab Report #: 5-G584Z-20-1 |
| LP-01347 Thermo-Hygrometer Comark SN: 06210350163 Cal: 04/18/2023 Due: 04/30/2024 Vendor: Cal-Cert Range: 122 °F 95 %RH Report #: 28945-67214-3646 |

Instrument Data

| | | | |
|-------------------------------|----------------------|----------------------------|-------------------------|
| Calibration Date: | August 9, 2023 | Reference: | Manufactures Tolerances |
| Recommended Due Date: | August 9, 2024 | Cal-Cert Procedure: | CP-080 |
| Calibration Frequency: | 12 Months | Indicating System: | Digital |
| Manufacturer: | Delmhorst | Temperature: | 74 °F |
| Type: | Resistivity Meter | Humidity: | 36% RH |
| Model Number: | MCS-1 | Asset #: | #094 |
| Serial #: | #094 | Service Location: | Cal-Cert Lab |
| Capacity: | 120 Megaohms | As Found: | Pass |
| Tolerance: | 3.00 % of indication | As Left: | Pass |

| Instrument Range: | 120 Megaohms | | Resolution: | 0.001 | Mode Verified: | Resistance |
|-------------------|-----------------|-------------------|-------------|-------------------|----------------|------------|
| Standard Reading | UUT As Found | UUT Reading #1 | Error | UUT Reading #2 | Error | |
| 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | |
| 1.100 | 1.095 | 1.095 | -0.005 | 1.095 | -0.005 | |
| 54.545 | 54.719 | 54.719 | 0.173 | 54.719 | 0.173 | |
| 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | |

Expanded Uncertainty± 2.50 Megaohms

Remarks:

100Mohm std Parallel with 120Mohm UUT= 54.545Mohms

We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs.
 Cleaning and preventative maintenance were performed as part of this service.

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ANSI/NCSL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above.

Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Brent Enbysk **Date:** August 9, 2023
Technical Manager: Marshall Doyle **Signature:** *M Doyle*



CERTIFICATE OF CALIBRATION

| | | | |
|----------------------------|--|----------------------------|-----------------------|
| CUSTOMER: | PFS-TECO : CLACKAMAS, OR | CALIBRATION DATE: | 06/17/2024 |
| PO NUMBER: | 1120 | CALIBRATION DUE: | 06/17/2025 |
| INST. MANUFACTURER: | DWYER | PROCEDURE: | T.O.33K6-4-1769-1 |
| INST. DESCRIPTION: | VELOMETER | CALIBRATION FLUID: | AIR @ 14.7 PSIA 70°F |
| MODEL NUMBER: | 471 | RECEIVED CONDITION: | WITHIN MFG. SPECS. |
| SERIAL NUMBER: | CP288559 ID# 095 | LEFT CONDITION: | WITHIN MFG. SPECS. |
| RATED ACCURACY: | SEE NOTES BELOW. | AMBIENT CONDITIONS: | 763mm HGA 53% RH 70°F |
| UNCERTAINTY GIVEN: | ± 0.43% RD ; k=2 | CERTIFICATE FILE #: | 490265.2024 |
| NOTES: | ± 3.0% FS (0-500 / 0-1500) ** ± 4.0% F.S. (0-5000) **± 5.0% F.S. (0-15000) ** ± 2 °F | | |

Q.MANUAL IM 2.0 REV 2020.2 DATED 7-27-2020

DECISION RULE: SIMPLE ACCEPTANCE. MEASUREMENT UNCERTAINTIES NOT TAKEN INTO CONSIDERATION WHEN DETERMINING PASS/FAIL

| UUT INDICATED | DM.STD. ACTUAL | UUT INDICATED | DM STD. ACTUAL |
|---------------|----------------|---------------|----------------|
| FT/MIN | FT/MIN | DEG. F | DEG. F |
| 70 | 73 | 0 TO 200°F | 0 TO 200°F |
| 126 | 130 | 44.7 | 44.1 |
| 242 | 249 | 71.8 | 71.0 |
| 495 | 508 | 99.9 | 99.3 |
| 521 | 533 | | |
| 1039 | 1066 | | |
| 1490 | 1530 | | |
| 507 | 522 | | |
| 3214 | 3311 | | |
| 4998 | 5156 | | |
| 6975 | 7182 | | |
| 14853 | 15322 | | |

STANDARDS USED:

| STANDARD | DUE | DATE |
|---|-----|----------|
| A312 ± .02% RD -140 TO 1372 DEG °C TRACE# 2023004415 | DUE | 11/13/24 |
| A800 flow nozzles +/- .2% RD (.2-5, 5-100, 100-1650 SCFM)TRACE# 144613547,1424683640,1583314714 | DUE | 02/14/25 |

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) and the Unit Under Test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed according to the shown procedure. The use of IAS/ILAC logo indicates calibrations are in accordance to ISO/IEC 17025:2017.

Dick Munns Company - 11133 Winners Circle, Los Alamitos, CA 90720
Phone: 714-827-1215 - www.dickmunns.com

This Calibration Certificate shall not be reproduced except, in full, without approval by Dick Munns Company. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Issuing Date:

Approved By:

Cal. Technician:

Calibrated at: Lab

On-Site (Customer's)

06/17/2024

[Signature]

[Signature]

Page 1 of 1

Certificate of Calibration

Certificate Number: 743892



JJ Calibrations, Inc.
 7724 SE Aspen Summit Drive
 Portland, OR 97266-9217
 Phone 503.786.3005
 FAX 503.786.2994

PFS TECO

11785 SE Hwy 212
 Suite 305
 Clackamas, OR 97015

PO: 1033
 Order Date: 03/08/2021
 Authorized By: N/A



Property #: 097
 User: N/A
 Department: N/A
 Make: Unknown
 Model: 10 Lbs.
 Serial #: 097
 Description: Mass
 Procedure: DCN 500901
 Accuracy: Raw Data

Calibrated on: 03/18/2021
 *Recommended Due: 03/18/2026
 Environment: 19 °C 41 % RH
 * As Received: Other - See Remarks
 * As Returned: Other - See Remarks
 Action Taken: Calibrated
 Technician: 126

Remarks: * Many factors may cause the unit to drift out of calibration before the recommended due date. Any reported error is the absolute value between the reference and the unit. Uncertainties include the effects of the unit.

Data is provided for your determination of acceptability. Received/returned without accessories.

Standards Used

| Std ID | Manufacturer | Model | Nomenclature | Due Date | Trace ID |
|--------|---------------|-------------------------|---------------|------------|----------|
| 484A | Rice Lake | 1kg-10kg (Class ASTM 1) | Mass Set, | 05/28/2021 | 699197 |
| 503A | Rice Lake | 1mg-200g (Class 0) | Mass Set, | 09/11/2021 | 729241 |
| 550A | And (A&D) Co. | HP-30K | Balance 30 Kg | 12/31/2021 | 739307 |
| 723A | Rice Lake | 1mg-200g (Class 0) | Mass Set, | 06/09/2021 | 723431 |

Parameter

Measurement Data

| Measurement Description | Range | Unit | Reference | Min | Max | *Error | UUT | Uncertainty |
|-------------------------|-------|------|---------------|-----------|-----------|-----------|----------------|------------------------|
| Before/After | | | | | | | | Accredited = \bar{U} |
| Mass | | | | | | | | |
| Raw Data | | g | 4535.92370000 | 0.0000000 | 0.0000000 | 0.1785299 | 4536.1022299 g | 3.5E-01 \bar{U} |

This instrument has been calibrated in accordance with the JJ Calibrations Quality Assurance Manual and is traceable to either the SI or to National Institute of Standards and Technology (NIST). The quality system and this certificate are in compliance with ANSI/NCSL Z540-1-1994, ISO/IEC 17025-2017, ISO 10012-1, the ISO 9000 family and QS 9000. The expanded uncertainties of measurements for this calibration are based upon 95% (2 sigma) confidence limits. Unless stated in the comments, certificates reflect the "Simple Acceptance Rule" as specified by JCGM 106:2012. Unless otherwise stated, a test accuracy ratio (TAR) of 4:1, if achievable, is maintained. The results reported herein apply only to the calibration of the item described above. This report may not be reproduced, except in full, without written approval of JJ Calibrations.

Reviewer

3 Issued 03/25/2021

Rev # 15

Inspector



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
11785 SE Hwy 212 STE#305
Clackamas, OR 97015

Report Number: DIRI0134307497240612

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|---------|-------------|--------------|---------------|---------------|--------------|
| Balance | Sartorius | ENTRIS224-1S | 34307497 | #107 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| g | 0.0001 | QC012 | 6/12/24 | 12/28/23 | 12/2024 |

FUNCTIONAL CHECKS

| ECCENTRICITY | | LINEARITY | | STANDARD DEVIATION | | | ENVIRONMENTAL CONDITIONS |
|---|--------------------------------|---|--------------------------------|--------------------|-------------|---------------|---|
| Test Wt: | Tol: | Test Wt: | Tol: | Test Wt: | Tol: | | |
| 100 | 0.0003 | 50 x 4 | 0.0002 | 100 | 0.0001 | | <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> |
| As-Found: | | As-Found: | | 1. 99.9999 | 5. 99.9999 | 9. 100.0000 | Good Fair Poor |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | 2. 99.9999 | 6. 100.0000 | 10. 100.0001 | |
| As-Left: | | As-Left: | | 3. 100.0000 | 7. 100.0000 | Result | Temperature: 23.1°C |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | 4. 100.0000 | 8. 100.0000 | 0.00006 | |

A2LA ACCREDITED SECTION OF REPORT

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|----------|----------------------|
| 200 | 199.9984 | 200.0000 | 0.00018 |
| 100 | 99.9991 | 99.9999 | 0.00018 |
| 50 | 49.9996 | 50.0001 | 0.00017 |
| 20 | 19.9998 | 20.0000 | 0.00017 |
| 0.1 | 0.1000 | 0.1000 | 0.00017 |
| 0.05 | 0.0499 | 0.0500 | 0.00017 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|------------|---------------|-------------|---------------|----------|--------------|---------|
| Weight Set | R.L./Troemner | 10kg to 1mg | G782 | 4/27/24 | 4/2025 | 2024090 |

Permanent Information Concerning this Equipment:

6 month calibration cycle

Comments/Info Concerning this Calibration:

06/12/2024: Cleaned, leveled, and adjusted span. RH=37.8%

Report prepared/reviewed by: TLP

Date: 06-12-2024

Technician: T. Peterson

Signature: [Signature]

THIS CERTIFICATE SHALL NOT BE REPRODUCED WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation and readability of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy. Calibrations comply with ISO/IEC 17025 and ANSI/Z540-1-1994 quality standards. Results relate only to the item(s) tested. Unless otherwise noted, statements of conformity do not include measurement

Member: National Conference of Standards Laboratories and Weights & Measures



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: PFS-TECO
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 05/09/22
Purchase Order: 1067
Traceable Number: 20220682

Test Item: 200 mg and 100 mg Individual Weights
Serial No.: Listed in Table

Manufacturer: Troemner
Customer ID: Listed in Table

| <u>Material</u> | <u>Assumed Density</u> | <u>Range</u> | <u>Tolerance Class</u> |
|-----------------|------------------------|-----------------|------------------------|
| Stainless Steel | 7.95 g/cm ³ | 200 mg & 100 mg | ASTM Class 1 |

Method and Traceability

The procedure used for this calibration is NIST IR 6969 SOP 4 Double Substitution Weighing Design. Standards used for comparison are traceable to the National Institute of Standards and Technology (reports on file) and are part of a comprehensive measurement assurance program for ensuring continued accuracy and traceability within the level of uncertainty reported. The Traceable Number listed above is Traceable to National Standards through an unbroken chain of comparison each having stated uncertainties.

Standards Used:

100 g to 1 mg Working Standards Were Calibrated: 07/02/21 Due: 07/31/22 Standards ID: 723318
Mass Comparators Used: MET-05 Tested by: D. Thompson

Conventional Mass: “The conventional value of the result of weighing a body in air is equal to the mass of a standard, of conventionally chosen density, at a conventionally chosen temperature, which balances this body at this reference temperature in air of conventionally chosen density. International Recommendation 33 (OIML IR 33 1973, 1979). “Conventional Value of the Result of Weighing in Air” (Previously known as “Apparent Mass vs. 8.0 g/cm³).


Uncertainty Statement: The uncertainty conforms to the ISO Guide to the Expressions of Uncertainty in Measurement. Uncertainty as reported is based on a coverage factor $k=2$ for an approximate 95 percent level of uncertainty. Uncertainty components include the standard deviation of the process, the uncertainty of the standard used, an uncertainty component associated with the potential drift of the standard used, and the estimated uncertainty related to measuring and determining the air buoyancy effect.

Conventional Mass Values are listed on page 2 of this report.

page 1 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 05/09/22


Signature David S. Thompson

This document shall not be reproduced, except in full, without the written approval of Quality Control Services Mass Laboratory.

Member: National Conference of Standards Laboratories and Weights & Measures



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: PFS-TECO
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 05/09/22
Purchase Order: 1067
Traceable Number: 20220682

Test Item: 200 mg and 100 mg Individual Weights
Serial No.: Listed in Table

Manufacturer: Troemner
Customer ID: Listed in Table

Laboratory Environment at time of test

| Temperature °C | Pressure mmHg | Humidity %RH |
|----------------|----------------|--------------|
| 21.93 to 21.94 | 760.7 to 760.8 | 47.8 to 47.9 |

Conventional Mass Value

| Nominal Value | As Found Value (g) | As Found Correction* (mg) | As Left Value (g) | As Left Correction* (mg) | Uncertainty (mg) | Tolerance (mg) |
|----------------------------|--------------------|---------------------------|-------------------|--------------------------|------------------|----------------|
| 200 mg, 1000101395, #109-B | 0.2000082 | 0.0082 | 0.2000082 | 0.0082 | 0.0014 | 0.010 |
| 100 mg, 1000126267, #109-A | 0.1000065 | 0.0065 | 0.1000065 | 0.0065 | 0.0014 | 0.010 |

*Correction is the difference between the conventional mass value of a weight and its nominal value.

Comments: These weights were received in good condition and were within ASTM Class 1 tolerances As Found.


Recalibration Due: The customer has requested a 5-year calibration cycle. The calibration due date for these weights is 05/09/27. The values listed above were found at the time of calibration. Any number of factors may cause these items to drift out of calibration before the calibration interval has expired.

Accredited by the American Association for Laboratory Accreditation (A2LA) under Calibration Laboratory Code 115953 and Certificate Number 1550.01. This laboratory meets the requirements of ISO/IEC 17025:2017 *General Requirements for the Competence of Testing and Calibration Laboratories*. This laboratory also meets the requirements of ANSI/NCSL Z540-1-1994 and any additional program requirements in the field of calibration.

page 2 to 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 05/09/22


Signature David S. Thompson

This document shall not be reproduced, except in full, without the written approval of Quality Control Services Mass Laboratory.

Member: National Conference of Standards Laboratories and Weights & Measures

Mettler Toledo
Service Business Unit Industrial
1900 Polaris Parkway
Columbus, OH 43240
1-800-523-5123



Accredited by the American Association
for Laboratory Accreditation (A2LA)
CALIBRATION CERT #1902.01

ISO 17025 Registered
ANSI/NCSL Z540-1 Accredited

Accuracy Calibration Certificate

Customer

Company: PFS-TECO
Address: 11785 SE Hwy 212; Ste 305
City: Clackamas **Contact:** John Steinert
Zip / Postal: 97015-9050
State / Province: Oregon

Weighing Device

Manufacturer: Mettler Toledo **Instrument Type:** Weighing Instrument
Model: PFD774-US11 **Asset Number:** 1
Serial No.: C112381341 **Terminal Model:** IND570
Building: N/A **Terminal Serial No.:** C101887027
Floor: N/A **Terminal Asset No.:** N/A
Room: N/A

| Range | Max. Capacity | Readability (d) |
|-------|---------------|-----------------|
| 1 | 1000 lb | 0.02 lb |

Procedure

Calibration Guideline: ASTM E898 - 20
METTLER TOLEDO Work Instruction: 30260953

This calibration certificate including procedures and uncertainty estimation also complies with EURAMET cg-18 v 4.0.

This calibration certificate contains measurements for As Found and As Left calibrations.

The sensitivity/span of the weighing instrument was adjusted before As Left calibration with an external weight.

| | Temperature | | Humidity | |
|----------|----------------|--------------|---------------|-------------|
| As Found | Start: 20.0 °C | End: 20.0 °C | Start: 44.0 % | End: 44.0 % |
| As Left | Start: 20.0 °C | End: 20.0 °C | Start: 44.0 % | End: 28.0 % |

Environmental conditions have been verified to ensure the accuracy of the calibration.

This certificate is issued in accordance with the conditions of accreditation granted by A2LA, which is based on ISO/IEC 17025. A2LA has assessed the measurement capability of the laboratory and its traceability to recognized national standards.

As Found Calibration Date: 16-Apr-2021
As Left Calibration Date: 16-Apr-2021
Issue Date: 16-Apr-2021
Requested Next Calibration Date: 30-Apr-2022

Authorized A2LA Signatory: 
Gary Sargent


Measurement Results

Repeatability

Test Load: 500 lb

| | As Found | As Left |
|---|----------|-----------|
| 1 | N/A | 500.00 lb |
| 2 | N/A | 500.00 lb |
| 3 | N/A | 500.02 lb |
| 4 | N/A | 500.00 lb |
| 5 | N/A | 500.00 lb |
| 6 | N/A | 500.00 lb |

○ As Found
◆ As Left



| | | |
|--------------------|-----|----------|
| Standard Deviation | N/A | 0.008 lb |
|--------------------|-----|----------|

The "d" in the graph represents the readability of the range/interval in which the test was performed.


The results of this graph are based upon the absolute values of the differences from the mean value.

Eccentricity


Test Load: 325 lb

| Position | As Found | As Left |
|----------|-----------|-----------|
| 1 | 325.00 lb | 325.00 lb |
| 2 | 325.00 lb | 325.00 lb |
| 3 | 325.00 lb | 325.00 lb |
| 4 | 325.00 lb | 325.00 lb |
| 5 | 325.00 lb | 325.00 lb |

| | | |
|-------------------|---------|---------|
| Maximum Deviation | 0.00 lb | 0.00 lb |
|-------------------|---------|---------|



As Found



As Left

The "d" in the graph represents the readability of the range/interval in which the test was performed.

Error of Indication


As Found

| | Reference Value | Indication | Error of Indication | Expanded Uncertainty | k |
|----------------|-----------------|------------|---------------------|----------------------|-----|
| 1 | 0 lb | 0.00 lb | 0.00 lb | N/A | N/A |
| 2 ¹ | 250 lb | 250.00 lb | 0.00 lb | N/A | N/A |
| 3 ¹ | 500 lb | 500.00 lb | 0.00 lb | N/A | N/A |
| 4 ¹ | 750 lb | 750.00 lb | 0.00 lb | N/A | N/A |
| 5 | 1000 lb | 1000.02 lb | 0.02 lb | N/A | N/A |
| 6 ¹ | 750 lb | 750.00 lb | 0.00 lb | N/A | N/A |
| 7 ¹ | 500 lb | 500.00 lb | 0.00 lb | N/A | N/A |
| 8 ¹ | 250 lb | 250.00 lb | 0.00 lb | N/A | N/A |
| 9 | 0 lb | 0.00 lb | 0.00 lb | N/A | N/A |

As Left

| | Reference Value | Indication | Error of Indication | Expanded Uncertainty | k |
|----------------|-----------------|------------|---------------------|----------------------|------|
| 1 | 0 lb | 0.00 lb | 0.00 lb | 0.023 lb | 2.28 |
| 2 ¹ | 250 lb | 250.00 lb | 0.00 lb | 0.051 lb | 2 |
| 3 ¹ | 500 lb | 500.00 lb | 0.00 lb | 0.10 lb | 2 |
| 4 ¹ | 750 lb | 750.00 lb | 0.00 lb | 0.15 lb | 2 |
| 5 | 1000 lb | 1000.02 lb | 0.02 lb | 0.17 lb | 2.05 |
| 6 ¹ | 750 lb | 750.00 lb | 0.00 lb | 0.15 lb | 2 |
| 7 ¹ | 500 lb | 500.00 lb | 0.00 lb | 0.10 lb | 2 |
| 8 ¹ | 250 lb | 250.00 lb | 0.00 lb | 0.051 lb | 2 |
| 9 | 0 lb | 0.00 lb | 0.00 lb | 0.023 lb | 2.28 |

¹The calculated uncertainty was replaced by the CMC (Calibration and Measurement Capabilities) value because the calculated uncertainty was smaller than the CMC value.



The uncertainty stated is the expanded uncertainty at calibration obtained by multiplying the standard combined uncertainty by the coverage factor k - which can be larger than 2 according to ASTM E898 and EURAMET cg-18. The value of the measurand lies within the assigned range of values with a probability of approximately 95%.

The user is responsible for maintaining environmental conditions and the settings of the weighing instrument when it was calibrated.

Test Equipment

All weights used for metrological testing are traceable to national or international standards. The weights were calibrated and certified by an accredited calibration laboratory.

Weight Set 1: NIST NIST-F

| | | | |
|---------------------|----------------------------|-----------------------|--------------------|
| Weight Set No.: | <u>182 50's & 25's</u> | Date of Issue: | <u>25-Jun-2019</u> |
| Certificate Number: | <u>OR-19-186-F</u> | Calibration Due Date: | <u>30-Jun-2021</u> |

Remarks

Equipment condition: Good

Calibration after installation

The recording of false fictitious or fraudulent statements or entries on this document may be punishable as a felony under federal Statute

End of Accredited Section

The information below and any attachments to this calibration certificate are not part of the accredited calibration.

Measurement Uncertainty of the Weighing Instrument in Use

Stated is the expanded uncertainty with k=2 in use. The formula shall be used for the estimation of the uncertainty under consideration of the errors of indication. The value R represents the net load indication in the unit of measure of the device.

Temperature coefficient for the evaluation of the measurement uncertainty in use: 10.0 · 10⁻⁶ / K

Temperature range on site for the evaluation of the measurement uncertainty in use: 10 K


Linearization of Uncertainty Equation

| Range | | | As Found | As Left |
|-------|---------|---------|----------|--|
| | d | Max | | |
| 1 | 0.02 lb | 1000 lb | N/A | $U_1 = 0.023 \text{ lb} + 0.0000986 \text{ lb/lb} \cdot R$ |


To optimize the stability of the linearization, besides of the zero load only increasing measurement points with a test load of 5% of the measurement range or larger are taken for the calculation of the linear equation.

Absolute and Relative Measurement Uncertainty in Use for Various Net Indications (Examples)

| Net Indication | As Found | | As Left | |
|----------------|----------|-----|----------|--------|
| 1.00 lb | N/A | N/A | 0.023 lb | 2.3% |
| 10.00 lb | N/A | N/A | 0.024 lb | 0.24% |
| 100.00 lb | N/A | N/A | 0.033 lb | 0.033% |
| 500.00 lb | N/A | N/A | 0.072 lb | 0.014% |
| 1000.00 lb | N/A | N/A | 0.12 lb | 0.012% |



As Found



As Left

Handbook 44 Tolerance Assessment(Acceptance)

Assessment done without considering measurement uncertainty.

The measurements from the attached calibration certificate were assessed against the Tolerances defined by NIST Handbook 44.


The range of measurements for both Eccentricity and Repeatability (if performed) tests is assessed against Maintenance Tolerances.

Overall **As Found** **As Left**

✔ ✔ ✔ = Passed
✘ = Failed

Weighing Device

| Range | Max. Capacity | Readability (d) | Verification Scale Interval (e) | Class |
|-------|---------------|-----------------|---------------------------------|-------|
| 1 | 1000 lb | 0.02 lb | 0.02 lb | III |



Tolerances according to NIST Handbook 44

| Test Load | | Tolerance |
|-----------|------------|-----------|
| From | To | |
| 0.00 lb | 0.00 lb | 0.005 lb |
| 0.02 lb | 10.00 lb | 0.01 lb |
| 10.02 lb | 40.00 lb | 0.02 lb |
| 40.02 lb | 80.00 lb | 0.03 lb |
| 80.02 lb | 1000.00 lb | 0.05 lb |

○ As Found
 ◆ As Left
 — Tolerance

Eccentricity and Repeatability

| Test | Test Load | Tolerance | As Found | | As Left | |
|----------------------------|-----------|-----------|--------------------|--------|--------------------|--------|
| | | | Max. Error / Range | Result | Max. Error / Range | Result |
| Eccentricity (Max. Error) | 325 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| Eccentricity (Range) | 325 lb | 0.1 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| Repeatability (Max. Error) | 500 lb | 0.05 lb | N/A | N/A | 0.02 lb | ✔ |
| Repeatability (Range) | 500 lb | 0.10 lb | N/A | N/A | 0.02 lb | ✔ |

Max. Error: Maximum of the absolute values of the individual errors.

Range: Difference between largest and smallest measurement value.

Error of Indication

| | Reference Value | Tolerance | As Found | | As Left | |
|---|-----------------|-----------|---------------------|--------|---------------------|--------|
| | | | Error of Indication | Result | Error of Indication | Result |
| 1 | 0 lb | 0.01 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 2 | 250 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 3 | 500 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 4 | 750 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 5 | 1000 lb | 0.05 lb | 0.02 lb | ✔ | 0.02 lb | ✔ |
| 6 | 750 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 7 | 500 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 8 | 250 lb | 0.05 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |
| 9 | 0 lb | 0.01 lb | 0.00 lb | ✔ | 0.00 lb | ✔ |

Report and Certificate of Calibration



www.Cal-Cert.com



Toll Free
800-356-4682

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620

Report #: 32102-201251-4686 Customer PO#: 1102
 Customer Name: PFS TECO
 Customer Address: 11785 SE Highway 212, Suite 305
 City: Clackamas State: OR Zip: 97015
 Contact: Ethan Frederick
 Service Address: 5777 SE International Way Milwaukie, OR 97222

Calibration Standards

| |
|--|
| 10-00954 Gage Block Set Shars SN: 120018 Cal: 05/26/2023 Due: 05/26/2025 Vendor: American Gage Report #: 109141 |
| LP-00397 Gage Block Set Mitutoyo SN: 509020 Cal: 12/28/2022 Due: 12/28/2024 Vendor: BHD Test and Measurement Report #: 99826 |
| LP-01757 Thermo-Hygrometer Comark SN: 06257740560 Cal: 04/28/2023 Due: 04/28/2024 Report #: 29096-209333-4201 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|----------------------|----------------------------|---------------------|
| Calibration Date: | December 6, 2023 | Reference: | Manufacturer's Spec |
| Calibration Due Date: | December 6, 2024 | Cal-Cert Procedure: | CP-115 |
| Calibration Frequency: | 12 Months | Indicating System: | Stamped |
| Manufacturer: | Starrett | Temperature: | 69 °F |
| Type: | Tape Measure | Humidity: | 51% RH |
| Model Number: | Exact | Asset #: | 207 |
| Serial #: | 138054-2203-00002249 | Service Location: | Cal-Cert Lab |
| Capacity: | 192.00 Inches | As Found: | Pass |
| | | As Left: | Pass |

| | | | |
|--------------------------|----------------|--------------------------|----------------|
| Instrument Range: | 192.000 Inches | Range Resolution: | 0.06250 Inches |
|--------------------------|----------------|--------------------------|----------------|

| Calibration Standard | As Found Reading | Verification Reading #1 | Verification Reading #2 |
|----------------------|------------------|-------------------------|-------------------------|
| 0.2500 | 0.2500 | 0.2500 | 0.2500 |
| 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 6.0000 | 6.0000 | 6.0000 | 6.0000 |
| 12.0000 | 12.0000 | 12.0000 | 12.0000 |
| 64.0000 | 64.0000 | 64.0000 | 64.0000 |
| 128.0000 | 128.0000 | 128.0000 | 128.0000 |
| 192.0000 | 192.0000 | 192.0000 | 192.0000 |

Expanded Uncertainty ± 0.07217 Inches

Remarks:

Metric scale not calibrated.

We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs. Cleaning and preventative maintenance were performed as part of this service.

Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
 A2LA is recognized under the ILAC mutual recognition agreement (MRA).

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NCSL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above. Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Scott McGuire Date: December 6, 2023

Technical Manager: Marshall Doyle Signature: *McDoyle*

Report and Certificate of Calibration



www.Cal-Cert.com



Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620

Report #: 31621-201253-5 **Customer PO#:** 1102
Customer Name: PFS TECO
Customer Address: 11785 SE Highway 212, Suite 305
City: Clackamas **State:** OR **Zip:** 97015
Contact: Ethan Frederick
Service Address: 5777 SE International Way Milwaukie, OR 97222

Calibration Standards

| |
|--|
| LP-00397 Gage Block Set Mitutoyo SN: 509020 Cal: 12/28/2022 Due: 12/28/2024 Vendor: BHD Test and Measurement Report #: 99826 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/30/2023 Due: 01/31/2024 Range: 122 °F 95 %RH Report #: 27747-205513-4239 |

Instrument Data

| | | | |
|-------------------------------|------------------|----------------------------|--------------------|
| Calibration Date: | October 23, 2023 | Reference: | ASME B89.1.14 2018 |
| Calibration Due Date: | October 23, 2024 | Cal-Cert Procedure: | CP-008 |
| Calibration Frequency: | 12 Months | Indicating System: | Digital |
| Manufacturer: | Mitutoyo | Temperature: | 66 °F |
| Type: | Digital Caliper | Humidity: | 51% RH |
| Model Number: | CD-P6"S | Asset #: | 208 |
| Serial #: | B22159310 | Service Location: | Cal-Cert Lab |
| Capacity: | 6 Inches | As Found: | PASS |
| Resolution: | 0.0005 Inches | As Left: | PASS |

| | | | |
|--------------------------|---------------|--------------------------|---------------|
| Instrument Range: | 6.0000 Inches | Range Resolution: | 0.0005 Inches |
|--------------------------|---------------|--------------------------|---------------|

| Outside Jaws / Linearity | | | | |
|--------------------------|----------|-------------------|-------------------|-------------|
| Calibration Standard | As Found | As Left Reading 1 | As Left Reading 2 | Tolerance ± |
| Inches | Inches | Inches | Inches | Inches |
| 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 0.0500 | 0.0495 | 0.0495 | 0.0495 | 0.0010 |
| 0.3000 | 0.3000 | 0.3000 | 0.3000 | 0.0010 |
| 0.6000 | 0.6000 | 0.6000 | 0.6000 | 0.0010 |
| 1.2000 | 1.1995 | 1.1995 | 1.1995 | 0.0010 |
| 2.4000 | 2.4000 | 2.4000 | 2.4000 | 0.0010 |
| 3.5000 | 3.5000 | 3.5000 | 3.5000 | 0.0010 |
| 5.0000 | 5.0000 | 5.0000 | 5.0000 | 0.0010 |
| 6.0000 | 5.9995 | 5.9995 | 5.9995 | 0.0010 |

Expanded Uncertainty ± 0.00036 Inches

| Scale Shift Verification | | | |
|--------------------------|------------|----------|-------------|
| | Target | Measured | Tolerance ± |
| Resolution Check | 0.1005 | 0.10050 | N/A |
| Depth | 1.000 | 1.00000 | 0.001 |
| Step | 1.000 | 1.00000 | 0.001 |
| Inside Jaws | 1.000 | 0.99950 | 0.001 |
| Inspections | | | |
| Jaws Parallel | Acceptable | | |

Remarks:

We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs. Cleaning and preventative maintenance were performed as part of this service.

Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
 A2LA is recognized under the ILAC mutual recognition agreement (MRA).

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NCSL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above. Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Cameron Walling **Date:** October 23, 2023
Technical Manager: Marshall Doyle **Signature:** *McDoyle*

Caliper CF-008-01

Revision 17 6/30/2023

Report and Certificate of Calibration



www.Cal-Cert.com

Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-9620



| | | | |
|--------------------------|---------------------------------|----------------------|-------|
| Report #: | 33086-206391-4525 | Customer PO#: | 1109 |
| Customer Name: | PFS TECO | | |
| Customer Address: | 1507 Matt Pass | | |
| City: | Cottage Grove | State: | WI |
| Contact: | Ethan Frederick | | |
| Service Address: | 11785 SE Highway 212, Suite 305 | Clackamas, OR | 97015 |
| Zip: | 53527 | | |

Calibration Standards

| |
|---|
| 13-01811 Thermocouple Meter/Calibrator Tegam SN: 2454186 Cal: 10/04/2023 Due: 02/28/2024 Range: 2400 °F Report #: 31363-217443-3646 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/24/2024 Due: 01/31/2025 Range: 122 °F 95 %RH Report #: 32568-205513-3646 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|----------------------|----------------------------|-------------------|
| Calibration Date: | February 26, 2024 | Reference: | Navair 17-20ST-95 |
| Recommended Due Date: | February 26, 2025 | Cal-Cert Procedure: | CP-013 |
| Calibration Frequency: | 12 Months | Indicating System: | Computer |
| Manufacturer: | National Instruments | Temperature: | 64 °F |
| Type: | Data Logger | Humidity: | 39% RH |
| Model Number: | NI 9213 | Asset #: | 215 Booth 1 |
| Serial #: | 1B182FB | Service Location: | Service Address |
| Resolution: | 0.1 °F | As Found: | Pass |
| Capacity: | 2,500 °F | As Left: | Pass |
| Tolerance: | ± 3.0 °F | | |
| Thermocouple Type: | K | | |

| Thermocouple METER FUNCTION | | | | | | |
|--------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Tunnel | 0.00 | 1.10 | 1.10 | 1.10 | 1.10 | 0.346 |
| | 500.00 | 501.10 | 501.10 | 501.10 | 1.10 | |
| | 1000.00 | 1001.10 | 1001.10 | 1001.10 | 1.10 | |
| | 1500.00 | 1501.20 | 1501.20 | 1501.20 | 1.20 | |
| | 2000.00 | 2001.30 | 2001.30 | 2001.30 | 1.30 | |
| | 2400.00 | 2401.40 | 2401.40 | 2401.40 | 1.40 | |
| | 0.00 | 1.20 | 1.20 | 1.20 | 1.20 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Flue | 0.00 | 0.80 | 0.80 | 0.80 | 0.80 | 0.346 |
| | 500.00 | 500.80 | 500.80 | 500.80 | 0.80 | |
| | 1000.00 | 1000.80 | 1000.80 | 1000.80 | 0.80 | |
| | 1500.00 | 1500.90 | 1500.90 | 1500.90 | 0.90 | |
| | 2000.00 | 2001.00 | 2001.00 | 2001.00 | 1.00 | |
| | 2400.00 | 2401.10 | 2401.10 | 2401.10 | 1.10 | |
| | 0.00 | 0.80 | 0.80 | 0.80 | 0.80 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Filter A | 0.00 | 0.60 | 0.60 | 0.60 | 0.60 | 0.346 |
| | 500.00 | 500.60 | 500.60 | 500.60 | 0.60 | |
| | 1000.00 | 1000.70 | 1000.70 | 1000.70 | 0.70 | |
| | 1500.00 | 1500.70 | 1500.70 | 1500.70 | 0.70 | |
| | 2000.00 | 2000.80 | 2000.80 | 2000.80 | 0.80 | |
| | 2400.00 | 2400.00 | 2400.00 | 2400.00 | 0.00 | |
| | 0.00 | 0.60 | 0.60 | 0.60 | 0.60 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Back | 0.00 | 0.40 | 0.40 | 0.40 | 0.40 | 0.346 |
| | 500.00 | 500.40 | 500.40 | 500.40 | 0.40 | |
| | 1000.00 | 1000.50 | 1000.50 | 1000.50 | 0.50 | |
| | 1500.00 | 1500.50 | 1500.50 | 1500.50 | 0.50 | |
| | 2000.00 | 2000.60 | 2000.60 | 2000.60 | 0.60 | |
| | 2400.00 | 2400.70 | 2400.70 | 2400.70 | 0.70 | |
| | 0.00 | 0.50 | 0.50 | 0.50 | 0.50 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Catalyst | 0.00 | 0.30 | 0.30 | 0.30 | 0.30 | 0.346 |
| | 500.00 | 500.20 | 500.20 | 500.20 | 0.20 | |
| | 1000.00 | 1000.30 | 1000.30 | 1000.30 | 0.30 | |
| | 1500.00 | 1500.40 | 1500.40 | 1500.40 | 0.40 | |
| | 2000.00 | 2000.40 | 2000.40 | 2000.40 | 0.40 | |
| | 2400.00 | 2400.40 | 2400.40 | 2400.40 | 0.40 | |
| | 0.00 | 0.20 | 0.20 | 0.20 | 0.20 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Meter A | 0.00 | 0.10 | 0.10 | 0.10 | 0.10 | 0.346 |
| | 500.00 | 500.10 | 500.10 | 500.10 | 0.10 | |
| | 1000.00 | 1000.20 | 1000.20 | 1000.20 | 0.20 | |
| | 1500.00 | 1500.20 | 1500.20 | 1500.20 | 0.20 | |
| | 2000.00 | 2000.30 | 2000.30 | 2000.30 | 0.30 | |
| | 2400.00 | 2400.30 | 2400.30 | 2400.30 | 0.30 | |
| | 0.00 | 0.10 | 0.10 | 0.10 | 0.10 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Left | 0.00 | 0.10 | 0.10 | 0.10 | 0.10 | 0.346 |
| | 500.00 | 500.10 | 500.10 | 500.10 | 0.10 | |
| | 1000.00 | 1000.20 | 1000.20 | 1000.20 | 0.20 | |
| | 1500.00 | 1500.20 | 1500.20 | 1500.20 | 0.20 | |
| | 2000.00 | 2000.20 | 2000.20 | 2000.20 | 0.20 | |
| | 2400.00 | 2400.20 | 2400.20 | 2400.20 | 0.20 | |
| | 0.00 | 0.10 | 0.10 | 0.10 | 0.10 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Right | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.346 |
| | 500.00 | 500.00 | 500.00 | 500.00 | 0.00 | |
| | 1000.00 | 1000.10 | 1000.10 | 1000.10 | 0.10 | |
| | 1500.00 | 1500.10 | 1500.10 | 1500.10 | 0.10 | |
| | 2000.00 | 2000.20 | 2000.20 | 2000.20 | 0.20 | |
| | 2400.00 | 2400.20 | 2400.20 | 2400.20 | 0.20 | |
| | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Filter B | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.346 |
| | 500.00 | 501.30 | 501.30 | 501.30 | 1.30 | |
| | 1000.00 | 1001.00 | 1001.00 | 1001.00 | 1.00 | |
| | 1500.00 | 1500.70 | 1500.70 | 1500.70 | 0.70 | |
| | 2000.00 | 2000.40 | 2000.40 | 2000.40 | 0.40 | |
| | 2400.00 | 2400.00 | 2400.00 | 2400.00 | 0.00 | |
| | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Top | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | 0.346 |
| | 500.00 | 499.90 | 499.90 | 499.90 | -0.10 | |
| | 1000.00 | 1000.10 | 1000.10 | 1000.10 | 0.10 | |
| | 1500.00 | 1500.10 | 1500.10 | 1500.10 | 0.10 | |
| | 2000.00 | 2000.10 | 2000.10 | 2000.10 | 0.10 | |
| | 2400.00 | 2400.10 | 2400.10 | 2400.10 | 0.10 | |
| | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | |

Remarks:

We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs.
Cleaning and preventative maintenance were performed as part of this service.

Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01.
A2LA is recognized under the ILAC mutual recognition agreement (MRA).

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NCSS Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above.

Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Steven White

Date: February 26, 2024

Technical Manager: Marshall Doyle

Signature: 

Report and Certificate of Calibration



www.Cal-Cert.com

Toll Free
800-356-4662

Address
5777 SE International Way
Milwaukie, OR 97222

Local
503-654-0620



Report #: 33086-206391-4525-B **Customer PO#:** 1109
Customer Name: PFS TECO
Customer Address: 1507 Matt Pass
City: Cottage Grove **State:** WI **Zip:** 53527
Contact: Ethan Frederick
Service Address: 11785 SE Highway 212, Suite 305 Clackamas, OR 97015

Calibration Standards

| |
|---|
| 13-01811 Thermocouple Meter/Calibrator Tegam SN: 2454186 Cal: 10/04/2023 Due: 02/28/2024 Range: 2400 °F Report #: 31363-217443-3646 |
| LP-01782 Thermo-Hygrometer Comark SN: 06247790052 Cal: 01/24/2024 Due: 01/31/2025 Range: 122 °F 95 %RH Report #: 32568-205513-3646 |
| |
| |

Instrument Data

| | | | |
|-------------------------------|----------------------|----------------------------|-------------------|
| Calibration Date: | February 26, 2024 | Reference: | Navair 17-20ST-95 |
| Recommended Due Date: | February 26, 2025 | Cal-Cert Procedure: | CP-013 |
| Calibration Frequency: | 12 Months | Indicating System: | Computer |
| Manufacturer: | National Instruments | Temperature: | 66 °F |
| Type: | Data Logger | Humidity: | 34% RH |
| Model Number: | NI 9213 | Asset #: | 215 Booth 1 |
| Serial #: | 1B182FB | Service Location: | Service Address |
| Resolution: | 0.1 °F | As Found: | Pass |
| Capacity: | 2,500 °F | As Left: | Pass |
| Tolerance: | ± 3.0 °F | | |
| Thermocouple Type: | K | | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|-------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Bottom | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | 0.346 |
| | 500.00 | 499.90 | 499.90 | 499.90 | -0.10 | |
| | 1000.00 | 1000.00 | 1000.00 | 1000.00 | 0.00 | |
| | 1500.00 | 1500.10 | 1500.10 | 1500.10 | 0.10 | |
| | 2000.00 | 2000.10 | 2000.10 | 2000.10 | 0.10 | |
| | 2400.00 | 2400.00 | 2400.00 | 2400.00 | 0.00 | |
| | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|-------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Meter B | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | 0.346 |
| | 500.00 | 499.90 | 499.90 | 499.90 | -0.10 | |
| | 1000.00 | 1000.10 | 1000.10 | 1000.10 | 0.10 | |
| | 1500.00 | 1500.10 | 1500.10 | 1500.10 | 0.10 | |
| | 2000.00 | 2000.20 | 2000.20 | 2000.20 | 0.20 | |
| | 2400.00 | 2400.20 | 2400.20 | 2400.20 | 0.20 | |
| | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Meter C | 0.00 | -0.20 | -0.20 | -0.20 | 0.20 | 0.346 |
| | 500.00 | 499.90 | 499.90 | 499.90 | -0.10 | |
| | 1000.00 | 1000.00 | 1000.00 | 1000.00 | 0.00 | |
| | 1500.00 | 1500.00 | 1500.00 | 1500.00 | 0.00 | |
| | 2000.00 | 2000.10 | 2000.10 | 2000.10 | 0.10 | |
| | 2400.00 | 2400.10 | 2400.10 | 2400.10 | 0.10 | |
| | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Filter C | 0.00 | -0.20 | -0.20 | -0.20 | 0.20 | 0.346 |
| | 500.00 | 499.90 | 499.90 | 499.90 | -0.10 | |
| | 1000.00 | 1000.00 | 1000.00 | 1000.00 | 0.00 | |
| | 1500.00 | 1500.10 | 1500.10 | 1500.10 | 0.10 | |
| | 2000.00 | 2000.10 | 2000.10 | 2000.10 | 0.10 | |
| | 2400.00 | 2400.10 | 2400.10 | 2400.10 | 0.10 | |
| | 0.00 | -0.10 | -0.10 | -0.10 | 0.10 | |

| Thermocouple LOGGING FUNCTION | | | | | | |
|----------------------------------|----------------------|--------------|-----------------------|-----------------------|---------------|-----------------------|
| Channel | Calibration Standard | UUT As Found | UUT As Left Reading 1 | UUT As Left Reading 2 | As Left Error | Expanded Uncertainty± |
| Ambient | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.346 |
| | 20.00 | 18.70 | 18.70 | 18.70 | -1.30 | |
| | 40.00 | 38.70 | 38.70 | 38.70 | -1.30 | |
| | 60.00 | 58.90 | 58.90 | 58.90 | -1.10 | |
| | 80.00 | 78.80 | 78.80 | 78.80 | -1.20 | |
| | 100.00 | 98.80 | 98.80 | 98.80 | -1.20 | |
| | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | |

Remarks:

15 Channels Tested, Ambient is Type T tested from 0-100°F per customer request.

We sincerely thank you for your business. Please call us at 503-654-9620 for all your sales and calibration needs. Cleaning and preventative maintenance were performed as part of this service.

Cal-Cert is accredited by A2LA under Calibration Laboratory Code #4986.01. A2LA is recognized under the ILAC mutual recognition agreement (MRA).

This certificate is hereby issued that the above instrument was tested for accuracy with calibrated standards traceable to the National Institute of Standards and Technology (NIST). The information provided on this form complies with the data gathering and reporting requirements of ISO/IEC 17025 and ANSI/NCSL Z540.1, and meets the requirements of all applicable references and Cal-Cert procedures listed above.

Any stated measurement uncertainty includes the uncertainty of the Calibration standards used, combined with the uncertainty of the measurement process using the RSS method with a k=2 for an approximate 95% level of confidence. The calibration process meets or exceeds a ratio of 4:1 unless otherwise stated.

All tolerances were derived from the applicable standards and pass/fail determination is based on those tolerances. The customer determined any recommended due dates indicated on the certificate.

This report shall not be reproduced except in full, without written approval from Cal-Cert.

Service Engineer: Steven White

Date: February 26, 2024

Technical Manager: Marshall Doyle

Signature: 



Making our world
more productive

DocNumber: 539508



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22023

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG TUALATIN OR H
10450 SW TUALATIN SHERWOOD ROAD
TUALATIN OR 97062-9547

Certificate Issuance Date: 05/08/2023
Linde Order Number: 72422600
Part Number: NI CD17C08E-AS
Customer PO Number: 80430965

Fill Date: 05/02/2023
Lot Number: 70086312207
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure and Volume: 1290 psig 99 ft3

Certified Concentration

| | | |
|------------------|-----------------|----------------------|
| Expiration Date: | 05/08/2031 | NIST Traceable |
| Cylinder Number: | CC505834 | Expanded Uncertainty |
| 16.98 % | Carbon dioxide | ± 0.13 % |
| 4.30 % | Carbon monoxide | ± 0.03 % |
| 17.16 % | Oxygen | ± 0.05 % |
| Balance | Nitrogen | |

ProSpec EZ Cert



Certification Information:

Certification Date: 05/08/2023 Term: 96 Months Expiration Date: 05/08/2031

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

CO2 responses have been corrected for Oxygen IR Broadening effect. O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon dioxide

Requested Concentration: 17 %
Certified Concentration: 16.98 %
Instrument Used: Horiba VIA-510 S/N 20C194WK
Analytical Method: NDIR
Last Multipoint Calibration: 04/25/2023

Reference Standard: Type / Cylinder #: NTRM / CC725981
Concentration / Uncertainty: 19.34 % ±0.03 %
Expiration Date: 01/12/2027
Traceable to: SRM # / Sample # / Cylinder #: NTRM / 190701 / CC725973
SRM Concentration / Uncertainty: 19.34% ±0.031%
SRM Expiration Date: 01/12/27

| First Analysis Data: | | | | Date | | | | |
|----------------------|-------|------------------|-------|---------|-------|-------|-------|------|
| Z: | 0 | R: | 19.34 | C: | 16.98 | Conc: | 16.97 | Date |
| R: | 19.36 | Z: | 0 | C: | 16.99 | Conc: | 16.98 | |
| Z: | 0 | C: | 17 | R: | 19.35 | Conc: | 16.99 | |
| UOM: % | | Mean Test Assay: | | 16.98 % | | | | |

| Second Analysis Data: | | | | Date | | | | |
|-----------------------|---|------------------|---|------|---|-------|---|------|
| Z: | 0 | R: | 0 | C: | 0 | Conc: | 0 | Date |
| R: | 0 | Z: | 0 | C: | 0 | Conc: | 0 | |
| Z: | 0 | C: | 0 | R: | 0 | Conc: | 0 | |
| UOM: % | | Mean Test Assay: | | 0 % | | | | |

2. Component: Carbon monoxide

Requested Concentration: 17 %
Certified Concentration: 16.98 %
Instrument Used: Horiba VIA-510 S/N 20C194WK
Analytical Method: NDIR
Last Multipoint Calibration: 04/25/2023

Reference Standard: Type / Cylinder #: NTRM / CC725981
Concentration / Uncertainty: 19.34 % ±0.03 %
Expiration Date: 01/12/2027
Traceable to: SRM # / Sample # / Cylinder #: NTRM / 190701 / CC725973
SRM Concentration / Uncertainty: 19.34% ±0.031%
SRM Expiration Date: 01/12/27

| First Analysis Data: | | | | Date | | | | |
|----------------------|-------|------------------|-------|---------|-------|-------|-------|------|
| Z: | 0 | R: | 19.34 | C: | 16.98 | Conc: | 16.97 | Date |
| R: | 19.36 | Z: | 0 | C: | 16.99 | Conc: | 16.98 | |
| Z: | 0 | C: | 17 | R: | 19.35 | Conc: | 16.99 | |
| UOM: % | | Mean Test Assay: | | 16.98 % | | | | |

| Second Analysis Data: | | | | Date | | | | |
|-----------------------|---|------------------|---|------|---|-------|---|------|
| Z: | 0 | R: | 0 | C: | 0 | Conc: | 0 | Date |
| R: | 0 | Z: | 0 | C: | 0 | Conc: | 0 | |
| Z: | 0 | C: | 0 | R: | 0 | Conc: | 0 | |
| UOM: % | | Mean Test Assay: | | 0 % | | | | |



Compressed gas, n.o.s.
(Carbon Monoxide, Carbon Dioxide, Oxygen,
Nitrogen)

UN1956

SPG 5P10162.5VM2
Part Number

Primary Standard, +/- 0.02% Absolute

| | | |
|-------------------------|------|-----------|
| 2.500 % Carbon Monoxide | CAS: | 630-08-0 |
| 10.00 % Carbon Dioxide | CAS: | 124-38-9 |
| 10.00 % Oxygen | CAS: | 7782-44-7 |
| Balance Nitrogen | CAS: | 7727-37-9 |

DANGER: CAUSES DAMAGE TO ORGANS THROUGH PROLONGED OR REPEATED EXPOSURE. CONTAINS GAS UNDER PRESSURE; MAY EXPLODE WHEN HEATED. MAY DAMAGE FERTILITY OR THE UNBORN CHILD. MAY INCREASE RESPIRATION AND HEARTRATE. Use only with equipment of compatible materials of construction and rated for cylinder pressure. Protect from sunlight when ambient temperature exceeds 52C (125F). Use a back flow preventive device in the piping. Close valve after each use and when empty. Do not open valve until connected to equipment prepared for use. Obtain special instructions before use. Protect from sunlight. Store in a well-ventilated place. IF exposed or concerned: Get medical advice. Store locked up. Dispose of contents/container in accordance with container/supplier owner instructions. Do not handle until all safety precautions have been read and understood. Do not breathe gas. Wash hands thoroughly after handling. Do not eat, drink, or smoke when using this product. Wear protective gloves, protective clothing, eye protection, and/or face protection. Read and follow the Safety Data Sheet (SDS) before use.

FIRST AID: IF ON SKIN: wash with plenty of water. IF INHALED: Remove person to fresh air and keep comfortable for breathing. IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses if present and easy to do - continue rinsing. IF exposed or concerned: Get medical advice.



WARNING: This product can expose you to Carbon Monoxide which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

Lot No: 1-053-122
Serial Number: CC341544
SPG 5P10162.5VM2
Part Number
PO #: 206483
Expires: 2-2024

NorLAB

To Order Call: 800-657-6672

In Emergency Call: 1-800-424-6300
Norlab, Inc.
898 W. Gower Road
Boise, Idaho 83703



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

Mr. John Steinert
Vice President
PFS TECO
11785 SE Hwy 212
Suite 305
Clackamas, OR 97015

02/04/2022

Dear Mr. Steinert,

I am writing you in response to your correspondence dated February 3, 2022, in which you request the use of an alternative testing procedure to demonstrate compliance with 40 CFR part 60, Subpart AAA – Standards of Performance for New Residential Wood Heaters (Subpart AAA). The Office of Air Quality Planning and Standards, as the delegated authority, must make the determination on any major alternatives to test methods and procedures required under 40 CFR parts 59, 60, 61, 63, and 65. Your proposed alternative test method and our approval decisions are discussed below.

According to the information provided, you seek an alternative test method for use when conducting testing on the United States Stove Company, Model KP5517 pellet heater. Currently, as required by section 60.534(a)(1)(i) of Subpart AAA, a manufacturer has the option to test their appliance in accordance with 40 CFR part 60, Appendix B, Method 28R for a crib fuel appliance or ASTM E2779-10 “Standard Test Method for Determining Particulate Matter Emissions from Pellet Heaters” (ASTM E2779-10) for a pellet fuel appliance. This request seeks an alternative to section 9.4.1.2 of ASTM E2779-10 which specifies test conditions for pellet heaters including the determination of the Medium Burn Rate Category and states that the medium burn rate must be $\leq 50\%$ of the maximum burn rate.

In your request, you state that the specification for determining the medium burn rate found in ASTM E2779-10 is incorrect, and the Medium Burn Rate Category should be defined as less than 50% of the midpoint point (this is defined in the attached Memo as 50% of the span between the Maximum Burn Rate and the Low Burn Rate) between the high and low burn rates. Furthermore, your request includes a memorandum dated February 2, 2022, titled “Appropriate Calculation of Medium Burn Rate Category in ASTM E-2779 Testing” (attached) which was sent to the EPA’s Office of Enforcement and Compliance Assurance. This memorandum states that an error had been uncovered in determining the appropriate Medium Burn Rate Category in ASTM E2779-10 for compliance pursuant to Subpart AAA. Specifically, section 9.4.1.2 of ASTM E2779-10 states that “the pellet heater shall be operated with the control or controls set in

the position(s) as needed to achieve a burn rate that is $\leq 50\%$ of the maximum burn rate.” Table 1 of ASTM E2779-10 also notes that the Medium Burn Rate Category test must be $\leq 50\%$ of the maximum burn rate. The memorandum states that this is incorrect as it assumes that zero is the other bound for determining half of the maximum burn rate, and that the correct approach in determining the Medium Burn Rate Category should be at a level below 50% of the span between the Maximum Burn Rate and the Low Burn Rate (a non-zero value).

We have reviewed your request and agree that the Medium Burn Rate Category should be defined as less than 50% of the span between the high and low burn rates. Meaning that the Medium Burn Rate Category should be at a level below 50% of the span between the Maximum Burn Rate and the Low Burn Rate (a non-zero value).

Based on the information provided and with the caveats set forth below, we are approving your request for an alternative methodology used when calculating the Medium Burn Rate Category to conduct certification testing as required by Subpart AAA, section 60.534(a)(1)(i) on pellet heaters. This approval is based on the understanding that the Medium Burn Rate Category is defined as less than 50% of the span between the high and low burn rates. Additionally, this approval is based on the understanding that the lowest heat output (Btu/hr) setting available to the user, and corresponds to the lowest burn rate to be evaluated during certification testing; this is consistent with Subpart AAA, section 60.534(a)(1), which states: “The burn rate for the low burn category must be no greater than the rate that an operator can achieve in home use and no greater than is advertised by the manufacturer or retailer.”

With this Alternate Test Method, the following changes to ASTM E2779-10 must be followed for certification testing:

1. Medium Burn Rate Category burn rate is defined as:

Nomenclature:

Max = Maximum burn rate (kg/h)

Min = Minimum burn rate (kg/h)

$$\frac{Max+Min}{2} \quad \text{Eq.1}$$


All other requirements of ASTM E-2779-10 must be followed during the testing, and all requirements of 40 CFR part 60, Subpart AAA must be satisfied as described in your test report. A copy of this letter must be included in each certification test report where this alternative test method is utilized.

Because this alternative method may be of use to others, we feel that it is reasonable that this approval be broadly applicable to all pellet heaters tested in accordance with ASTM E2779-10 “Standard Test Method for Determining Particulate Matter Emissions from Pellet Heaters” and subject to the requirements of §60.534(a)(1)(i) of Subpart AAA. For this reason, we will post this

letter as ALT-146 on our website at <https://www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods> for use by other interested parties. This alternative method approval is valid until such time that Subpart AAA is revised or replaced to require a different pellet heater certification method, and at such time, this alternative will be reconsidered and possibly withdrawn.

If you have additional questions regarding this approval, please contact Angelina Brashear of my staff at 919-541-4746 or brashear.angelina@epa.gov.

Sincerely,



Steffan M. Johnson
Group Leader
Measurement Technology Group

cc: Angelina Brashear – EPA/OAQPS/AQAD
Chuck French – EPA/OAQPS/SPPD
Rafael Sanchez – EPA/OECA
Robert Scinta – EPA/OECA
Michael Toney – EPA/OAQPS/AQAD
Nathan Topham – EPA/OAQPS/SPPD
John Voorhees – United States Stove Company
Chet Wayland – EPA/OAQPS/AQAD



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

MEMORANDUM

02/02/2022

SUBJECT: Appropriate calculation of Medium Burn Rate Category in ASTM E-2779 Testing

FROM: Steffan Johnson
Group Leader
Measurement Technology Group
Air Quality Assessment Division

**STEFFAN
JOHNSON** Digitally signed by
STEFFAN JOHNSON
Date: 2022.02.02
08:28:07 -05'00'

TO: Robert Scinta, P.E.
Chief, Air Branch
Monitoring, Assistance, and Media Programs Division
Office of Compliance, Office of Enforcement and Compliance Assurance

During a recent review of pellet heater compliance test reports, the Measurement Technology Group has uncovered an error in determining the appropriate Medium Burn Rate Category when using ASTM E-2779 for compliance pursuant to 40 CFR 60, subpart AAA. Specifically, the method requirements in section 9.4.1.2 and Table 1 of that test method incorrectly require that the Medium Burn Rate Category must fall below 50% of the maximum burn rate. This is not correct as this requirement assumes then that zero is the other bound for determining half of the maximum.

9.4.1.2 *Medium Burn Rate Category*—For burn rates in the medium segment, except as allowed in 9.4.1.4 or 9.4.1.5, the pellet heater shall be operated with the control or controls set in the position(s) as needed to achieve a burn rate that is $\leq 50\%$ of the maximum burn rate.

TABLE 1

| Burn Rate Segment | Maximum | Medium | Minimum |
|-------------------|---------------------|------------------------|----------------------|
| Description | Maximum achievable | $\leq 50\%$ of Maximum | Minimum achievable |
| Time at Burn Rate | 60 +5 / - 0 minutes | 120 +5 / - 0 minutes | 180 +5 / - 0 minutes |

The correct application of this requirement would be to determine the Medium Burn Rate Category at a level below 50% of the span between the Maximum Burn Rate and the Low Burn Rate (a non-zero value). Ergo, the correct calculation for finding that midpoint of 50% is defined as $\frac{Max+M}{2}$.

For example, if the Maximum Burn rate of an appliance is 1.79 kg/hr and the minimum is 1.23 kg/hr, the method would currently place the 50% requirement at 0.895 kg/hr. This is unachievable on this appliance and presents an impossible compliance requirement. Applying the equation laid out above the value of 1.51 is derived and, therefore, presents an appropriate and likely attainable emissions test requirement for the Medium Burn Rate Category.

During your reviews of such emissions tests, as reported to OECA and intended for compliance certification purposes, MTG recommends applying the above procedure in order to ascertain if a Medium Burn Rate was appropriately established during a compliance test.

CC:

Sarah Ayres - OECA

Angelina Brashear – OAQPS

Alice Edwards – Alaska DEC

Chuck French – OAQPS

Robert Lischinsky - OECA

Theresa Lowe - OAQPS

Rafael Sanchez – OECA

Robert Scinta - OECA

Mike Toney – OAQPS

Nathan Topham - OAQPS

Chet Wayland – OAQPS